



East Shore Road Quarterly PMs

Quarter: 4

East Shore Road

Headworks

Main Floor

-Classifier

Check & Adjust Belt Drive

Initial Date
GOC 11/5

-Climber Screen

Sluice Gates
Exercise and Grease

Initial Date
VZ 10/28

-Grit Pump

Clean and Inspect
Pumps & Check Valve

Initial Date
[] []

no check valves

Grit Chamber

-Grit Collector

Oil Drive Chain and
Adjust (Every 2 Months)

Initial Date
GOC 11/4

-Grease Worm

Gearbox Bearing

Initial Date
GOC 11/4

-Influent Channel

Drain and Flush

Initial Date
BS 11/4

De-Watering Building

Basement

-Grease Vari-Drives

Initial Date
GOC 11/5

Pump Station "A"

Building

-Brown & Brown Valve

Exercise and Grease

Initial Date
GOC 11/5

-Clean and Inspect

Check valves & Pump
Housing

Initial Date
VZ 10/30

Pump Station "B"

Building

-Brown & Brown Valve

Exercise and Grease

Initial Date
GOC 11/5

-Clean and Inspect

Check valves & Pump
Housing

Initial Date
VZ 10/30

Pump Station "C"

Building

-Brown & Brown Valve

Exercise and Grease

Initial Date
GOC 11/5

-Clean and Inspect

Check valves & Pump
Housing

Initial Date
VZ 10/30



East Shore Road Quarterly PMs

Quarter: 4

Secondary Tanks

-Inlet Valves

Exercise and Grease

Initial	Date
GOC	11/5

Chlorine Mixing Chamber

Chlorine Contact Chambers

-Sluice Gates

Exercise & Grease

Initial	Date
GOC	11/5

-Mixer

Grease Gearing

Initial	Date
GOC	11/5

Sand Filters

Sand Filters

-Grease Wheels

Initial	Date
GOC	11/5

-Oil and Adjust
Drive Chain

Initial	Date
GOC	11/5

-Influent and
Bypass Gates

Initial	Date
GOC	11/5

-Flush Underdrains

Initial	Date
V2	10/08

Sand Beds

-Re-grade Sand #1
(Every 4 Months)

Initial	Date
V2	9/08

-Re-grade Sand #2
(Every 4 Months)

Initial	Date
V2	9/08

Effluent Pump House

Basement

-Valves

Initial	Date
V2	10/28

All Buildings

All Buildings on East Shore Road

-Clean Windows

Initial	Date
✓	10/08