



East Shore Road Weekly PMs

Week of : 12/29/08

East Shore Road

Headworks

Main Floor

-Grit Cyclone

Check for Clogging,
Drain & Nozzle

Initial Date
AM 12/29

-Classifier

Hose Down,
Grease Lower Bearing (12 SHOTS/ON)
Check Gearbox Oil

Initial Date
AM 12/29

-Bubbler Panel

Check Operation,
Exercise Transfer Chasis

Initial Date
AM 12/29

-Hose Off Floor

Make sure entire
area is hosed down

Initial Date
AM 12/29

Grit Chamber

-Grit Collector

Check Gearbox Oil,
Worm Gearbox Oil (85-140 Gear Lube)

Initial Date
AM 12/29

Primary Tanks

-Drives

Check Gearbox Oil
(AGMA 5)

Initial Date
AM 12/29

-Raw Sludge

Pumping Station
Sludge Pumps, Check Gearbox Oil, Grease Pillow Block

Initial Date
AM 12/29

Digesters

Roof

-Flame Traps

Gas Compressors,
Gearbox,
Check Oil Level (Oils: #2 & 3 - 30 Wt. ; #1 - Synthetic Blower Oil)

Initial Date
AM 12/31

Main Floor

-Boilers

Water Pressure,
Expansion, Tank lvl, Drain Methane Lines (DIG. 3 only)

Initial Date
AM 12/31

-Sweep Floor

Sweep All Levels
of Digesters Building

Initial Date
AM 1/2

Basement

-Re-circulators

Grease Stuffing Box
(As Needed)

Initial Date
AM 12/31

-Digester Drip Traps

Drain Each

Initial Date
AM 12/31

De-Watering Building

Main Floor

-Emergency Eye

Wash / Shower,
Flush Out

Initial Date
AM 12/30

-Sweep Floor

Sweep Floor of
De-Watering Building

Initial Date
AM 1/2

Pump Station "A"

Building

-Re-Circulating

Pumps
Grease Stuffing Box, Hose Down Stuffing Box
(12 Shots (On))

Initial Date
AM 12/31

-Bubbler Panel

Check Operation,
Exercise Transfer Chasis

Initial Date
AM 12/31

-Hose Off Floor

Make sure entire
area is hosed down

Initial Date
AM 1/2

Pump Station "B"

Building

-Re-Circulating

Pumps
Grease Stuffing Box, Hose Down Stuffing Box
(NO GREASE)

Initial Date
AM 12/30

-Bubbler Panel

Check Operation,
Exercise Transfer Chasis

Initial Date
AM 12/30

-Sweep Floor

Sweep All Levels
of Building "B"

Initial Date
AM 1/2



East Shore Road Weekly PMs

Week of : 12/29/08

Pump Station "C"

Building

-Re-Circulating

Initial Date

AM 12/30

Pumps

Grease Stuffing Box, Hose Down Stuffing Box

(NO GREASE)

-Bubbler Panel

Initial Date

AM 12/30

Check Operation,

Exercise Transfer Chassis

-Sweep Floor

Sweep All Levels

of Building "C"

Initial Date

AM 1/2

Administration Building

Hypo Room

-Eye Wash/Shower

Initial Date

AM 12/30

Flush Out

Boiler Room

-Compressors

Initial Date

AM 12/30

(OFF) Drain Water

in Tanks, Check Oil Levels

Secondary Tanks

-Drives

Initial Date

AM 12/31

Check Gearbox Oil

(AGMA 5)

-Telescoping

Initial Date

AM 12/31

Valves

Check for Clogging

Sand Filters

-Drained, hosed down

Initial Date

AM 1/2

Re-grade sand if needed

Effluent Pump House

Main Floor

-Diesel

Initial Date

AM 12/30

Generator Kit

Check Oil Level,

Battery & Radiator

-Exercise Engine a min

Initial Date

AM 12/30

of 30 minutes:

3x/month w/o load

1x/month underload

Start End

14437 14445

-Bubbler Panels

Initial Date

AM 12/30

Check Operation,

Exercise Transfer Chassis

-Sweep Floor

Sweep All Levels

of Effluent Pump House

Initial Date

AM 1/2

All Buildings

All Rooms and Buildings of East Shore Road

-Light Bulbs

Initial Date

Check all bulbs

Replace any that need replacing