



# East Shore Road Weekly PMs

Week of : 09/29/08

## East Shore Road

### Headworks

#### Main Floor

-Grit Cyclone  
Check for Clogging,  
Drain & Nozzle

Initial Date  
BS 9.29

-Classifier  
Hose Down,  
Grease Lower Bearing (12 SHOTS/ON)  
Check Gearbox Oil

Initial Date  
BS 9.29

-Bubbler Panel  
Check Operation,  
Exercise Transfer Chasis

Initial Date  
BS 9.29

-Hose Off Floor  
Make sure entire  
area is hosed down

Initial Date  
BS 9.29

#### Grit Chamber

-Grit Collector  
Check Gearbox Oil,  
Worm Gearbox Oil (85-140 Gear Lube)

Initial Date  
BS 9.29

#### Primary Tanks

-Drives  
Check Gearbox Oil  
(AGMA 5)

Initial Date  
BS 9.29

-Raw Sludge  
Pumping Station  
Sludge Pumps, Check Gearbox Oil, Grease Pillow Block

Initial Date  
BS 9.29

### Digesters

#### Roof

-Flame Traps  
Gas Compressors,  
Gearbox,  
Check Oil Level (Oils: #2 & 3 - 30 Wt. ; #1 - Synthetic Blower Oil)

Initial Date  
BS 10.2

#### Main Floor

-Boilers  
Water Pressure,  
Expansion, Tank lvl, Drain Methane Lines (DIG. 3 only)

Initial Date  
BS 10.2

-Sweep Floor  
Sweep All Levels  
of Digesters Building

Initial Date  
BS 10.2

#### Basement

-Re-circulators  
Grease Stuffing Box  
(As Needed)

Initial Date  
BS 10.2

-Digester Drip Traps  
Drain Each

Initial Date  
BS 10.2

### De-Watering Building

#### Main Floor

-Emergency Eye  
Wash / Shower,  
Flush Out

Initial Date  
BS 10.2

-Sweep Floor  
Sweep Floor of  
De-Watering Building

Initial Date  
BS 10.2

### Pump Station "A"

#### Building

-Re-Circulating  
Pumps  
Grease Stuffing Box, Hose Down Stuffing Box  
(12 Shots (On))

Initial Date  
BS 10.2

-Bubbler Panel  
Check Operation,  
Exercise Transfer Chasis

Initial Date  
BS 10.2

-Hose Off Floor  
Make sure entire  
area is hosed down

Initial Date  
BS 10.2

### Pump Station "B"

#### Building

-Re-Circulating  
Pumps  
Grease Stuffing Box, Hose Down Stuffing Box  
(NO GREASE)

Initial Date  
BS 10.2

-Bubbler Panel  
Check Operation,  
Exercise Transfer Chasis

Initial Date  
BS 10.2

-Sweep Floor  
Sweep All Levels  
of Building "B"

Initial Date  
BS 10.3



# East Shore Road Weekly PMs

Week of : 09/29/08

## Pump Station "C"

### Building

#### -Re-Circulating

Initial Date

BS 10.2

#### Pumps

Grease Stuffing Box, Hose Down Stuffing Box  
(NO GREASE)

#### -Bubbler Panel

Initial Date

BS 10.2

Check Operation,  
Exercise Transfer Chassis

#### -Sweep Floor

Sweep All Levels  
of Building "C"

Initial Date

BS 10.3

## Administration Building

### Hypo Room

#### -Eye Wash/Shower

Initial Date

BS 10.2

Flush Out

### Boiler Room

#### -Compressors

Initial Date

BS 10.2

(OFF) Drain Water  
in Tanks, Check Oil Levels

## Secondary Tanks

#### -Drives

Initial Date

BS 10.2

Check Gearbox Oil  
(AGMA 5)

#### -Telescoping

Initial Date

BS 10.2

Valves  
Check for Clogging

## Sand Filters

#### -Drained, hosed down

Initial Date

BS 10.3

Re-grade sand if needed

## Effluent Pump House

### Main Floor

#### -Diesel

Initial Date

BS 10.2

Generator Kit  
Check Oil Level,  
Battery & Radiator

#### -Exercise Engine a min of 30 minutes:

Initial Date

BS 10.2

3x/month w/o load  
1x/month underload

Start End

4261 4274

#### -Bubbler Panels

Initial Date

BS 10.2

Check Operation,  
Exercise Transfer Chassis

#### -Sweep Floor

Sweep All Levels  
of Effluent Pump House

Initial Date

BS 10.3

## All Buildings

### All Rooms and Buildings of East Shore Road

#### -Light Bulbs

Initial Date

BS 10.3

Check all bulbs  
Replace any that need replacing