





# East Shore Road Multi Yeared PMs

2009

## Sludge Pumps ✓

### Grease Motor #1

-Grease Motor Bearings

(Every 2 Years)

Previous :

03/2007

Date

Initial	Performed	Reading
VR	4/9	199.1

Due

03/2009

Date

### Grease Motor #3

-Grease Motor Bearings

(Every 2 Years)

Previous :

03/2007

Initial	Performed	Reading
VR	4/9	5612.8

Due

03/2009

### Grease Motor #2

-Grease Motor Bearings

(Every 2 Years)

Previous :

03/2007

Date

Initial	Performed	Reading
VR	4/9	454.1

Due

03/2009

Date

### Grease Motor #4

-Grease Motor Bearings

(Every 2 Years)

Previous :

03/2007

Initial	Performed	Reading
VR	4/9	8688.9

Due

03/2009

## De-watering Building

### Main Floor

In Line Polymer Mix Valve

-Dismantle and Clean

(As Needed)

Date

Initial	Performed
VR	4/9
VR	9/9

Date

Initial	Performed

(additional entries)

### Basement

#### Grease Motor

-Grease Motor Bearings

(Every 2 Years)

Previous :

Due  
12/2011

Initial	Performed	Reading
VR	12/16	8560

## Pump Station "A"

### Grease Motor #1

-Grease Motor Bearings

(Every 2 Years)

Previous :

12/2008

Initial	Performed	Reading
X	X	X

12 SHOTS/OFF

Due  
12/2010

### Grease Motor #2

-Grease Motor Bearings

(Every 2 Years)

Previous :

12/2008

Initial	Performed	Reading
X	X	X

12 SHOTS/OFF

Due  
12/2010

### Grease Motor #3

-Grease Motor Bearings

(Every 2 Years)

Previous :

12/2008

Initial	Performed	Reading
X	X	X

12 SHOTS/OFF

Due  
12/2010

### Wet Well

Fully Clean Out

(Every 3 Years)

Previous :

Due  
12/2013

Initial	Performed
VR	12/13

~ probed well - clean

## Pump Station "B"

### Grease Motor #1

-Grease Motor Bearings

(Every 2 Years)

Previous :

12/2008

Initial	Performed	Reading
X	X	X

12 SHOTS/OFF

Due  
12/2010

### Grease Motor #2

-Grease Motor Bearings

(Every 2 Years)

Previous :

12/2008

Initial	Performed	Reading
X	X	X

12 SHOTS/OFF

Due  
12/2010

### Wet Well

Fully Clean Out

(Every 3 Years)

Previous :

Due  
12/2011

Initial	Performed
VR	12/16/09

probed well - clean

2009 - ✓  
2010  
East Shore Road - 2 M4



# East Shore Road Multi Yeared PMs

2009

## Pump Station "C"

### Grease Motor #1

Initial	Performed	Reading
X	X	X

(Every 2 Years) 12 SHOTS/OFF

Previous : Due  
12/2008 12/2010

### Grease Motor #2

Initial	Performed	Reading
X	X	X

(Every 2 Years) 12 SHOTS/OFF

Previous : Due  
12/2008 12/2010

## Wet Well

### Fully Clean Out

(Every 3 Years)

Previous : Due  
2006

Initial Performed  
VZ 12/17/09  
well clean - PR obcd

## Administration Building

### Hypo Room

#### Dismantle and Overhaul

#### Hypo Pumps

(as needed)

Initial	Performed	Reading
VZ	11/21/09	2W
VZ	5/11/09	2C
VZ	11/12/09	2C

### Well House

#### Change Oil

#### in Compressor

SAE 30-NON DETERGENT

(Every 2 Years)

Previous : Due  
2/10

Initial	Performed

## Trickling Filter B

### Change Upper

### Bearing Oil

(Every 2 Years)

Previous : Due  
6/11

Initial	Performed
VZ	6/15/09

## Trickling Filter C

### Secondary Sludge Pumping Station

#### --Pumps

#### Inspect and Change Oil #1

(Every 2 Years)

(DIELECTRIC OIL - SUBMERSABLE PUMP)

Previous : Due  
9/11

Initial	Performed	Reading
VZ	9/09	69554

#### --Pumps

#### Inspect and Change Oil #2

(Every 2 Years)

(DIELECTRIC OIL - SUBMERSABLE PUMP)

Previous : Due  
9/11

Initial	Performed	Reading
VZ	9/09	27342

## Final Tanks

### Grease Motor

#### -Grease Motor Bearings

(Every 2 Years)

Previous : Due  
2010

Initial	Performed	Reading
X	X	X

2009 - ✓

MY

2009 - ✓

2010 -



# East Shore Road Multi Yeared PMs

2009

## Chlorine Mixing Chamber

Grease Motor

Initial	Performed	Reading
X	X	X

-Grease Motor Bearings

(Every 2 Years)

Previous : 2000

Due 2010

## Effluent Pump House

### Effluent Pumps

Grease Motor #1

Initial	Performed	Reading
X	X	X

-Grease Motor Bearings

(Every 2 Years) 12 SHOTS/OFF

Previous : 12/2008

Due 12/2010

Grease Motor #2

Initial	Performed	Reading
X	X	X

-Grease Motor Bearings

(Every 2 Years) 12 SHOTS/OFF

Previous : 12/2008

Due 12/2010

Grease Motor #3

Initial	Performed	Reading
X	X	X

-Grease Motor Bearings

(Every 2 Years) 12 SHOTS/OFF

Previous : 12/2008

Due 12/2010

### Backwash Pumps

Grease Motor #1

Initial	Performed	Reading
X	X	X

-Grease Motor Bearings

(Every 2 Years) 8 SHOTS/OFF

Previous : 12/2008

Due 12/2010

Grease Motor #2

Initial	Performed	Reading
X	X	X

-Grease Motor Bearings

(Every 2 Years) 8 SHOTS/OFF

Previous : 12/2008

Due 12/2010

### Plant Water Pumps

Grease Motor #1

Initial	Performed	Reading
X	X	X

-Grease Motor Bearings

(Every 2 Years) 10 SHOTS/OFF

Previous : 12/2008

Due 12/2010

Grease Motor #2

Initial	Performed	Reading
X	X	X

-Grease Motor Bearings

(Every 2 Years) 10 SHOTS/OFF

Previous : 12/2008

Due 12/2010

Automatic Strainer

Initial	Performed
✓	12/2009

Change Gearbox Oil

85W/140

Previous : 12/2009

Due 12/2011

MY ✓