



# East Shore Road Weekly PMs

Week of : 1/12/09

## East Shore Road

### Headworks

#### Main Floor

##### -Grit Cyclone

Check for Clogging,  
Drain & Nozzle

Initial Date  
BS 1.12

##### -Classifier

Hose Down,  
Grease Lower Bearing (12 SHOTS/ON)  
Check Gearbox Oil

Initial Date  
BS 1.12

##### -Bubbler Panel

Check Operation,  
Exercise Transfer Chasis

Initial Date  
BS 1.12

##### -Hose Off Floor

Make sure entire  
area is hosed down

Initial Date  
BS 1.12

#### Grit Chamber

##### -Grit Collector

Check Gearbox Oil,  
Worm Gearbox Oil (85-140 Gear Lube)

Initial Date  
BS 1.12

#### Primary Tanks

##### -Drives

Check Gearbox Oil  
(AGMA 5)

Initial Date  
BS 1.12

##### -Raw Sludge

Pumping Station  
Sludge Pumps, Check Gearbox Oil, Grease Pillow Block

Initial Date  
BS 1.12

### Digesters

#### Roof

##### -Flame Traps

Gas Compressors,  
Gearbox,  
Check Oil Level (Oils: #2 & 3 - 30 Wt. ; #1 - Synthetic Blower Oil)

Initial Date  
BS 1.12

##### -Sweep Floor

Sweep All Levels  
of Digesters Building

Initial Date  
BS 1.16

#### Main Floor

##### -Boilers

Water Pressure,  
Expansion, Tank lvl, Drain Methane Lines (DIG. 3 only)

Initial Date  
BS 1.12

#### Basement

##### -Re-circulators

Grease Stuffing Box  
(As Needed)

Initial Date  
BS 1.12

##### -Digester Drip Traps

Drain Each

Initial Date  
BS 1.12

### De-Watering Building

#### Main Floor

##### -Emergency Eye

Wash / Shower,  
Flush Out

Initial Date  
BS 1.12

##### -Sweep Floor

Sweep Floor of  
De-Watering Building

Initial Date  
BS 1.16

### Pump Station "A"

#### Building

##### -Re-Circulating

##### Pumps

Grease Stuffing Box, Hose Down Stuffing Box  
(12 Shots (On))

Initial Date  
BS 1.14

##### -Bubbler Panel

Check Operation,  
Exercise Transfer Chasis

Initial Date  
BS 1.14

##### -Hose Off Floor

Make sure entire  
area is hosed down

Initial Date  
BS 1.14

### Pump Station "B"

#### Building

##### -Re-Circulating

##### Pumps

Grease Stuffing Box, Hose Down Stuffing Box  
(NO GREASE)

Initial Date  
BS 1.12

##### -Bubbler Panel

Check Operation,  
Exercise Transfer Chasis

Initial Date  
BS 1.12

##### -Sweep Floor

Sweep All Levels  
of Building "B"

Initial Date  
BS 1.16



# East Shore Road Weekly PMs

Week of : 1/12/09

## Pump Station "C"

### Building

-Re-Circulating

Initial Date  
BS 1.12

Pumps

Grease Stuffing Box, Hose Down Stuffing Box  
(NO GREASE)

-Bubbler Panel

Initial Date  
BS 1.12

Check Operation,

Exercise Transfer Chasis

-Sweep Floor

Sweep All Levels  
of Building "C"

Initial Date  
BS 1.16

## Administration Building

### Hypo Room

-Eye Wash/Shower

Initial Date  
BS 1.12

Flush Out

### Boiler Room

-Compressors

Initial Date  
BS 1.12

(OFF) Drain Water

in Tanks, Check Oil Levels

## Secondary Tanks

-Drives

Initial Date  
BS 1.16

Check Gearbox Oil  
(AGMA 5)

-Telescoping

Initial Date  
BS 1.16

Valves

Check for Clogging

## Sand Filters

-Drained, hosed down

Initial Date  
BS 1.16

Re-grade sand if needed

## Effluent Pump House

### Main Floor

-Diesel

Initial Date  
BS 1.14

Generator Kit

Check Oil Level,

Battery & Radiator

-Exercise Engine a min

Initial Date  
BS 1.14

of 30 minutes:

3x/month w/o load

Start End  
4461 4474

1x/month underload

-Bubbler Panels

Initial Date  
BS 1.14

Check Operation,

Exercise Transfer Chassis

-Sweep Floor

Sweep All Levels

of Effluent Pump House

Initial Date  
BS 1.16

## All Buildings

### All Rooms and Buildings of East Shore Road

-Light Bulbs

Initial Date  
BS 1.16

Check all bulbs

Replace any that need replacing