



# East Shore Road Weekly PMs

Week of : 10/26/09 - 10/30/09

## East Shore Road

### Headworks

#### Main Floor

##### -Grit Cyclone

Check for Clogging,  
Drain & Nozzle

Initial Date  
Bill 10-26

##### -Classifier

Hose Down,  
Grease Lower Bearing (12 SHOTS/ON)  
Check Gearbox Oil

Initial Date  
Bill 10-26

##### -Bubbler Panel

Check Operation,  
Exercise Transfer Chasis

Initial Date  
Bill 10-26

##### -Hose Off Floor

Make sure entire  
area is hosed down

Initial Date  
Bill 10-26

##### -Light Bulbs

Check all bulbs.  
Replace any that need  
replacing in Headworks Building

Initial Date  
Bill 10-26

#### Grit Chamber

##### -Grit Collector

Check Gearbox Oil,  
Worm Gearbox Oil (85-140 Gear Lube)

Initial Date  
Bill 10-26

#### Primary Tanks

##### -Drives

Check Gearbox Oil  
(AGMA 5)

Initial Date  
Bill 10-26

##### -Raw Sludge

Pumping Station  
Sludge Pumps, Check Gearbox Oil, Grease Pillow Block

Initial Date  
Bill 10-26

### Digesters

#### Roof

##### -Flame Traps

Gas Compressors,

Gearbox,

Check Oil Level (Oils: #2 & 3 - 30 Wt. ; #1 - Synthetic Blower Oil)

Initial Date  
Bill 10-29

##### -Sweep Floor

Sweep All Levels

of Digesters Building

Initial Date  
Bill 10-29

#### Main Floor

##### -Boilers

Water Pressure,

Expansion, Tank lvl, Drain Methane Lines (DIG. 3 only)

Initial Date  
Bill 10-29

#### Basement

##### -Re-circulators

Grease Stuffing Box  
(As Needed)

Initial Date  
Bill 10-29

##### -Digester Drip Traps

Drain Each

Initial Date  
Bill 10-29

### De-Watering Building

#### Main Floor

##### -Emergency Eye

Wash / Shower,  
Flush Out

Initial Date  
Bill 10-29

##### -Sweep Floor

Sweep Floor of  
De-Watering Building

Initial Date  
Bill 10-29

### Pump Station "A"

#### Building

##### -Re-Circulating

Pumps

Grease Stuffing Box, Hose Down Stuffing Box  
(12 Shots (On))

Initial Date  
Bill 10-26

##### -Bubbler Panel

Check Operation,  
Exercise Transfer Chasis

Initial Date  
Bill 10-26

##### -Hose Off Floor

Make sure entire  
area is hosed down

Initial Date  
Bill 10-26

##### -Light Bulbs

Check all bulbs.  
Replace any that need replacing  
in Pump Station "A"

Initial Date  
Bill 10-26



# East Shore Road Weekly PMs

10/26/09 - 10/30/09

## Pump Station "B"

### Building

-Re-Circulating

Initial Date

Bill 10.27

-Bubbler Panel

Initial Date

Bill 10.27

-Sweep Floor

Initial Date

Bill 10.27

Pumps

Grease Stuffing Box, Hose Down Stuffing Box  
(NO GREASE)

Check Operation,  
Exercise Transfer Chassis

Sweep All Levels  
of Building "B"

## Pump Station "C"

### Building

-Re-Circulating

Initial Date

Bill 10.27

-Bubbler Panel

Initial Date

Bill 10.27

-Sweep Floor

Initial Date

Bill 10.27

Pumps

Grease Stuffing Box, Hose Down Stuffing Box  
(NO GREASE)

Check Operation,  
Exercise Transfer Chassis

Sweep All Levels  
of Building "C"

-Light Bulbs

Initial Date

Bill 10.27

Check all bulbs.

Replace any that need replacing  
in Pump Station "C"

## Administration Building

-Light Bulbs

Initial Date

Bill 10.30

Check all bulbs.

Replace any that need replacing  
in Each Room of the Administration Building

-Toilet Paper and Paper Towels

Initial Date

Bill 10.30

Check all toilet paper  
and automatic paper towel dispensers in bathrooms  
kitchen area and downstairs. Replace if empty.

## Hypo Room

-Eye Wash/Shower

Initial Date

Bill 10.30

Flush Out

## Boiler Room

-Compressors

Initial Date

Bill 10.30

(OFF) Drain Water  
in Tanks, Check Oil Levels

## Final Tanks

-Drives

Initial Date

Bill 10.27

Check Gearbox Oil  
(AGMA 5)

-Telescoping

Initial Date

Bill 10.27

Valves  
Check for Clogging

## Sand Filters

-Drained, hosed down

Initial Date

Bill 10.28

Re-grade sand if needed

-Light Bulbs

Initial Date

Bill 10.28

Check all bulbs.  
Replace any that need replacing  
in Sand Filter Building

## Sand Beds

-Re-grade Sand #1

Initial Date

Bill 10.28

-Re-grade Sand #2

Initial Date

Bill 10.28

## Effluent Pump House

### Main Floor

-Diesel

Initial Date

Bill 10.29

Generator Kit

Check Oil Level,

Battery & Radiator

-Exercise Engine a min

Initial Date

Bill 10.29

of 30 minutes:

3x/month w/o load

1x/month underload

Start	End	Hours
4931	4941	1

-Bubbler Panels

Initial Date

Bill 10.29

Check Operation,  
Exercise Transfer Chassis

-Light Bulbs

Initial Date

Bill 10.29

Check all bulbs.

Replace any that need replacing  
in Effluent Pump House

-Sweep Floor

Initial Date

Bill 10.29

Sweep All Levels  
of Effluent Pump House