



East Shore Road Weekly PMs

Week of : 2/9/09 - 2/13/09

East Shore Road

Headworks

Main Floor

-Grit Cyclone

Check for Clogging,
Drain & Nozzle

Initial Date
BS 2.9

-Classifier

Hose Down,
Grease Lower Bearing (12 SHOTS/ON)
Check Gearbox Oil

Initial Date
BS 2.9

-Bubbler Panel

Check Operation,
Exercise Transfer Chasis

Initial Date
BS 2.9

-Hose Off Floor

Make sure entire
area is hosed down

Initial Date
BS 2.9

-Light Bulbs

Check all bulbs.
Replace any that need
replacing in Headworks Building

Initial Date
BS 2.9

Grit Chamber

-Grit Collector

Check Gearbox Oil,
Worm Gearbox Oil (85-140 Gear Lube)

Initial Date
BS 2.9

Primary Tanks

-Drives

Check Gearbox Oil
(AGMA 5)

Initial Date
BS 2.9

-Raw Sludge

Pumping Station
Sludge Pumps, Check Gearbox Oil, Grease Pillow Block

Initial Date
BS 2.9

Digesters

Roof

-Flame Traps

Gas Compressors,
Gearbox,
Check Oil Level (Oils: #2 & 3 - 30 Wt. ; #1 - Synthetic Blower Oil)

Initial Date
BS 2.9

-Sweep Floor

Sweep All Levels
of Digesters Building

Initial Date
BS 2.12

Main Floor

-Boilers

Water Pressure,
Expansion, Tank IV, Drain Methane Lines (DIG. 3 only)

Initial Date
BS 2.9

Basement

-Re-circulators

Grease Stuffing Box
(As Needed)

Initial Date
BS 2.9

-Digester Drip Traps

Drain Each

Initial Date
BS 2.9

De-Watering Building

Main Floor

-Emergency Eye

Wash / Shower,
Flush Out

Initial Date
BS 2.9

-Sweep Floor

Sweep Floor of
De-Watering Building

Initial Date
BS 2.10

Pump Station "A"

Building

-Re-Circulating

Pumps
Grease Stuffing Box, Hose Down Stuffing Box
(12 Shots (On))

Initial Date
BS 2.10

-Bubbler Panel

Check Operation,
Exercise Transfer Chasis

Initial Date
BS 2.10

-Hose Off Floor

Make sure entire
area is hosed down

Initial Date
BS 2.10

-Light Bulbs

Check all bulbs.
Replace any that need replacing
in Pump Station "A"

Initial Date
BS 2.10



East Shore Road Weekly PMs

2/9/09 - 2/13/09

Pump Station "B"

Building

-Re-Circulating

Initial Date
BS 2.9

-Bubbler Panel

Initial Date
BS 2.9

-Sweep Floor

Initial Date
BS 2.10

Pumps

Grease Stuffing Box, Hose Down Stuffing Box
(NO GREASE)

Check Operation,
Exercise Transfer Chassis

Sweep All Levels
of Building "B"

Pump Station "C"

Building

-Re-Circulating

Initial Date
BS 2.9

-Bubbler Panel

Initial Date
BS 2.9

-Sweep Floor

Initial Date
BS 2.10

Pumps

Grease Stuffing Box, Hose Down Stuffing Box
(NO GREASE)

Check Operation,
Exercise Transfer Chassis

Sweep All Levels
of Building "C"

-Light Bulbs

Initial Date
BS 2.9

Check all bulbs.
Replace any that need replacing
in Pump Station "C"

Administration Building

-Light Bulbs

Initial Date
BS 2.10

Check all bulbs.
Replace any that need replacing
in Each Room of the Administration Building

Hypo Room

-Eye Wash/Shower

Initial Date
BS 2.10

Flush Out

Boiler Room

-Compressors

Initial Date
BS 2.10

(OFF) Drain Water
in Tanks, Check Oil Levels

Final Tanks

-Drives

Initial Date
BS 2.10

Check Gearbox Oil
(AGMA 5)

-Telescoping

Initial Date
BS 2.10

Valves
Check for Clogging

Sand Filters

-Drained, hosed down

Initial Date
BS 2.13

Re-grade sand if needed

-Light Bulbs

Initial Date
BS 2.10

Check all bulbs.
Replace any that need replacing
in Sand Filter Building

Effluent Pump House

Main Floor

-Diesel

Initial Date
BS 2.9

Generator Kit

Check Oil Level,

Battery & Radiator

-Exercise Engine a min

Initial Date
BS 2.9

of 30 minutes:

3x/month w/o load

Start	End	Hours
4505	4517	1 1/2

1x/month underload

-Bubbler Panels

Initial Date
BS 2.9

Check Operation,
Exercise Transfer Chassis

-Sweep Floor

Initial Date
BS 2.12

Sweep All Levels
of Effluent Pump House

-Light Bulbs

Initial Date
BS 2.9

Check all bulbs.
Replace any that need replacing
in Effluent Pump House