



East Shore Road Weekly PMs

Week of : 3/16/09 - 3/20/09

East Shore Road

Headworks

Main Floor

-Grit Cyclone

Check for Clogging,
Drain & Nozzle

Initial Date
BS 3.16

-Classifier

Hose Down,
Grease Lower Bearing (12 SHOTS/ON)
Check Gearbox Oil

Initial Date
BS 3.16

-Bubbler Panel

Check Operation,
Exercise Transfer Chasis

Initial Date
BS 3.16

-Hose Off Floor

Make sure entire
area is hosed down

Initial Date
BS 3.16

-Light Bulbs

Check all bulbs.
Replace any that need
replacing in Headworks Building

Initial Date
BS 3.16

Grit Chamber

-Grit Collector

Check Gearbox Oil,
Worm Gearbox Oil (85-140 Gear Lube)

Initial Date
BS 3.16

Primary Tanks

-Drives

Check Gearbox Oil
(AGMA 5)

Initial Date
BS 3.16

-Raw Sludge

Pumping Station
Sludge Pumps, Check Gearbox Oil, Grease Pillow Block

Initial Date
BS 3.16

Digesters

Roof

-Flame Traps

Gas Compressors,
Gearbox,
Check Oil Level (Oils: #2 & 3 - 30 WL ; #1 - Synthetic Blower Oil)

Initial Date
BS 3.16

-Sweep Floor

Sweep All Levels
of Digesters Building

Initial Date
BS 3.16

Main Floor

-Boilers

Water Pressure,
Expansion, Tank VI, Drain Methane Lines (DIG. 3 only)

Initial Date
BS 3.16

Basement

-Re-circulators

Grease Stuffing Box
(As Needed)

Initial Date
BS 3.16

-Digester Drip Traps

Drain Each

Initial Date
BS 3.16

De-Watering Building

Main Floor

-Emergency Eye

Wash / Shower,
Flush Out

Initial Date
BS 3.16

-Sweep Floor

Sweep Floor of
De-Watering Building

Initial Date
BS 3.16

Pump Station "A"

Building

-Re-Circulating

Pumps
Grease Stuffing Box, Hose Down Stuffing Box
(12 Shots (On))

Initial Date
BS 3.16

-Bubbler Panel

Check Operation,
Exercise Transfer Chasis

Initial Date
BS 3.16

-Hose Off Floor

Make sure entire
area is hosed down

Initial Date
BS 3.16

-Light Bulbs

Check all bulbs.
Replace any that need replacing
in Pump Station "A"

Initial Date
BS 3.16



East Shore Road Weekly PMs

3/16/09 - 3/20/09

Pump Station "B"

Building

-Re-Circulating

Initial Date

BS 3.16

Pumps

Grease Stuffing Box, Hose Down Stuffing Box
(NO GREASE)

-Bubbler Panel

Initial Date

BS 3.16

Check Operation,
Exercise Transfer Chasis

-Sweep Floor

Initial Date

BS 3.16

Sweep All Levels
of Building "B"

Pump Station "C"

Building

-Re-Circulating

Initial Date

BS 3.16

Pumps

Grease Stuffing Box, Hose Down Stuffing Box
(NO GREASE)

-Bubbler Panel

Initial Date

BS 3.16

Check Operation,
Exercise Transfer Chasis

-Sweep Floor

Initial Date

BS 3.16

Sweep All Levels
of Building "C"

-Light Bulbs

Initial Date

BS 3.16

Check all bulbs.
Replace any that need replacing
in Pump Station "C"

Administration Building

-Light Bulbs

Initial Date

BS 3.16

Check all bulbs.
Replace any that need replacing
in Each Room of the Administration Building

Hypo Room

-Eye Wash/Shower

Initial Date

BS 3.16

Flush Out

Boiler Room

-Compressors

Initial Date

BS 3.16

(OFF) Drain Water
in Tanks, Check Oil Levels

Final Tanks

-Drives

Initial Date

BS 3.16

Check Gearbox Oil
(AGMA 5)

-Telescoping

Initial Date

BS 3.16

Valves
Check for Clogging

Sand Filters

-Drained, hosed down

Initial Date

BS 3.18

Re-grade sand if needed

-Light Bulbs

Initial Date

BS 3.16

Check all bulbs.
Replace any that need replacing
in Sand Filter Building

Effluent Pump House

Main Floor

-Diesel

Initial Date

BS 3.16

Generator Kit

Check Oil Level,

Battery & Radiator

-Exercise Engine a min

Initial Date

BS 3.16

of 30 minutes:

3x/month w/o load

Start End Hours

4563 4572 50m

1x/month underload

-Bubbler Panels

Initial Date

BS 3.16

Check Operation,
Exercise Transfer Chassis

-Sweep Floor

Initial Date

BS 3.16

Sweep All Levels
of Effluent Pump House

-Light Bulbs

Initial Date

BS 3.16

Check all bulbs.
Replace any that need replacing
in Effluent Pump House