



# East Shore Road Weekly PMs

Week of : 3/23/09 - 3/27/09

## East Shore Road

### Headworks

#### Main Floor

##### -Grit Cyclone

Check for Clogging,  
Drain & Nozzle

Initial Date  
BS 3.23

##### -Classifier

Hose Down,  
Grease Lower Bearing (12 SHOTS/ON)  
Check Gearbox Oil

Initial Date  
BS 3.23

##### -Bubbler Panel

Check Operation,  
Exercise Transfer Chasis

Initial Date  
BS 3.23

##### -Hose Off Floor

Make sure entire  
area is hosed down

Initial Date  
BS 3.23

##### -Light Bulbs

Check all bulbs.  
Replace any that need  
replacing in Headworks Building

Initial Date  
BS 3.23

#### Grit Chamber

##### -Grit Collector

Check Gearbox Oil,  
Worm Gearbox Oil (85-140 Gear Lube)

Initial Date  
BS 3.23

#### Primary Tanks

##### -Drives

Check Gearbox Oil  
(AGMA 5)

Initial Date  
BS 3.23

##### -Raw Sludge

Pumping Station  
Sludge Pumps, Check Gearbox Oil, Grease Pillow Block

Initial Date  
BS 3.23

### Digesters

#### Roof

##### -Flame Traps

Gas Compressors,

Gearbox,

Check Oil Level (Oils: #2 & 3 - 30 Wt. ; #1 - Synthetic Blower Oil)

Initial Date  
BS 3.23

##### -Sweep Floor

Sweep All Levels  
of Digesters Building

Initial Date  
BS 3.23

#### Main Floor

##### -Boilers

Water Pressure,  
Expansion, Tank lv, Drain Methane Lines (DIG. 3 only)

Initial Date  
BS 3.23

#### Basement

##### -Re-circulators

Grease Stuffing Box  
(As Needed)

Initial Date  
BS 3.23

##### -Digester Drip Traps

Drain Each

Initial Date  
BS 3.23

### De-Watering Building

#### Main Floor

##### -Emergency Eye

Wash / Shower,  
Flush Out

Initial Date  
BS 3.23

##### -Sweep Floor

Sweep Floor of  
De-Watering Building

Initial Date  
BS 3.23

### Pump Station "A"

#### Building

##### -Re-Circulating

Pumps  
Grease Stuffing Box, Hose Down Stuffing Box  
(12 Shots (On))

Initial Date  
BS 3.26

##### -Bubbler Panel

Check Operation,  
Exercise Transfer Chasis

Initial Date  
BS 3.26

##### -Hose Off Floor

Make sure entire  
area is hosed down

Initial Date  
BS 3.26

##### -Light Bulbs

Check all bulbs.  
Replace any that need replacing  
in Pump Station "A"

Initial Date  
BS 3.26



# East Shore Road Weekly PMs

3/23/09 - 3/27/09

## Pump Station "B"

### Building

#### -Re-Circulating

Initial Date

BS 3-23

#### Pumps

Grease Stuffing Box, Hose Down Stuffing Box  
(NO GREASE)

#### -Bubbler Panel

Initial Date

BS 3-23

Check Operation,  
Exercise Transfer Chassis

#### -Sweep Floor

Initial Date

BS 3-23

Sweep All Levels  
of Building "B"

## Pump Station "C"

### Building

#### -Re-Circulating

Initial Date

BS 3-23

#### Pumps

Grease Stuffing Box, Hose Down Stuffing Box  
(NO GREASE)

#### -Bubbler Panel

Initial Date

BS 3-23

Check Operation,  
Exercise Transfer Chassis

#### -Sweep Floor

Initial Date

BS 3-23

Sweep All Levels  
of Building "C"

#### -Light Bulbs

Initial Date

BS 3-23

Check all bulbs.  
Replace any that need replacing  
in Pump Station "C"

## Administration Building

#### -Light Bulbs

Initial Date

BS 3-25

Check all bulbs.  
Replace any that need replacing  
in Each Room of the Administration Building

## Hypo Room

#### -Eye Wash/Shower

Initial Date

BS 3-25

Flush Out

## Boiler Room

#### -Compressors

Initial Date

BS 3-25

(OFF) Drain Water  
in Tanks, Check Oil Levels

## Final Tanks

#### -Drives

Initial Date

BS 3-25

Check Gearbox Oil  
(AGMA 5)

#### -Telescoping

Initial Date

BS 3-25

Valves  
Check for Clogging

## Sand Filters

#### -Drained, hosed down

Initial Date

BS 3-27

Re-grade sand if needed

#### -Light Bulbs

Initial Date

BS 3-25

Check all bulbs.  
Replace any that need replacing  
in Sand Filter Building

## Effluent Pump House

### Main Floor

#### -Diesel

Initial Date

BS 3-23

#### Generator Kit

Check Oil Level,

Battery & Radiator

#### -Exercise Engine a min

Initial Date

BS 3-23

of 30 minutes:

3x/month w/o load

1x/month underload

Start	End	Hours
4572	4582	1

#### -Bubbler Panels

Initial Date

BS 3-23

Check Operation,  
Exercise Transfer Chassis

#### -Sweep Floor

Initial Date

BS 3-23

Sweep All Levels  
of Effluent Pump House

#### -Light Bulbs

Initial Date

BS 3-23

Check all bulbs.  
Replace any that need replacing  
in Effluent Pump House