



# East Shore Road Weekly PMs

Week of : 6/8/09 - 6/12/09

## East Shore Road

### Headworks

#### Main Floor

##### -Grit Cyclone

Check for Clogging,  
Drain & Nozzle

Initial Date  
Bill 6-8

##### -Classifier

Hose Down,  
Grease Lower Bearing (12 SHOTS/ON)  
Check Gearbox Oil

Initial Date  
Bill 6-8

##### -Bubbler Panel

Check Operation,  
Exercise Transfer Chasis

Initial Date  
Bill 6-8

##### -Hose Off Floor

Make sure entire  
area is hosed down

Initial Date  
Bill 6-8

##### -Light Bulbs

Check all bulbs.  
Replace any that need  
replacing in Headworks Building

Initial Date  
Bill 6-8

#### Grit Chamber

##### -Grit Collector

Check Gearbox Oil,  
Worm Gearbox Oil (85-140 Gear Lube)

Initial Date  
Bill 6-8

#### Primary Tanks

##### -Drives

Check Gearbox Oil  
(AGMA 5)

Initial Date  
Bill 6-8

##### -Raw Sludge

Pumping Station  
Sludge Pumps, Check Gearbox Oil, Grease Pillow Block

Initial Date  
Bill 6-8

### Digesters

#### Roof

##### -Flame Traps

Gas Compressors,  
Gearbox,  
Check Oil Level (Oils: #2 & 3 - 30 Wt. ; #1 - Synthetic Blower Oil)

Initial Date  
Bill 6-8

##### -Sweep Floor

Sweep All Levels  
of Digesters Building

Initial Date  
Bill 6-12

#### Main Floor

##### -Boilers

Water Pressure,  
Expansion, Tank lvl, Drain Methane Lines (DIG. 3 only)

Initial Date  
Bill 6-8

#### Basement

##### -Re-circulators

Grease Stuffing Box  
(As Needed)

Initial Date  
Bill 6-8

##### -Digester Drip Traps

Drain Each

Initial Date  
Bill 6-8

### De-Watering Building

#### Main Floor

##### -Emergency Eye

Wash / Shower,  
Flush Out

Initial Date  
Bill 6-9

##### -Sweep Floor

Sweep Floor of  
De-Watering Building

Initial Date  
Bill 6-12

### Pump Station "A"

#### Building

##### -Re-Circulating

Pumps  
Grease Stuffing Box, Hose Down Stuffing Box  
(12 Shots (On))

Initial Date  
Bill 6-8

##### -Bubbler Panel

Check Operation,  
Exercise Transfer Chasis

Initial Date  
Bill 6-8

##### -Hose Off Floor

Make sure entire  
area is hosed down

Initial Date  
Bill 6-8

##### -Light Bulbs

Check all bulbs.  
Replace any that need replacing  
in Pump Station "A"

Initial Date  
Bill 6-8



# East Shore Road Weekly PMs

## Pump Station "B"

6/8/09 - 6/12/09

### Building

-Re-Circulating

Initial Date  
Bill 6-8

-Bubbler Panel

Initial Date  
Bill 6-8

-Sweep Floor

Initial Date

### Pumps

Grease Stuffing Box, Hose Down Stuffing Box  
(NO GREASE)

Check Operation,  
Exercise Transfer Chassis

Sweep All Levels  
of Building "B"

## Pump Station "C"

### Building

-Re-Circulating

Initial Date  
Bill 6-8

-Bubbler Panel

Initial Date  
Bill 6-8

-Sweep Floor

Initial Date  
Bill 6-12

### Pumps

Grease Stuffing Box, Hose Down Stuffing Box  
(NO GREASE)

Check Operation,  
Exercise Transfer Chassis

Sweep All Levels  
of Building "C"

-Light Bulbs

Initial Date  
Bill 6-8

Check all bulbs.  
Replace any that need replacing  
in Pump Station "C"

## Administration Building

-Light Bulbs

Initial Date  
Bill 6-8

Check all bulbs.  
Replace any that need replacing  
in Each Room of the Administration Building

## Hypo Room

-Eye Wash/Shower

Initial Date  
Bill 6-8

Flush Out

## Boiler Room

-Compressors

Initial Date  
Bill 6-8

(OFF) Drain Water  
in Tanks, Check Oil Levels

## Final Tanks

-Drives

Initial Date  
Bill 6-9

Check Gearbox Oil  
(AGMA 5)

-Telescoping

Initial Date  
Bill 6-9

Valves  
Check for Clogging

## Sand Filters

-Drained, hosed down

Initial Date  
Bill 6-10

Re-grade sand if needed

-Light Bulbs

Initial Date  
Bill 6-10

Check all bulbs.  
Replace any that need replacing  
in Sand Filter Building

## Sand Beds

-Re-grade Sand #1

Initial Date  
Bill 6-10

(Every 3 Months)

-Re-grade Sand #2

Initial Date  
Bill 6-10

(Every 3 Months)

## Effluent Pump House

### Main Floor

-Diesel

Initial Date  
Bill 6-9

### Generator Kit

Check Oil Level,

Battery & Radiator

-Exercise Engine a min

Initial Date  
Bill 6-9

of 30 minutes:

3x/month w/o load

1x/month underload

Start End Hours

7717 7722 1/2

-Bubbler Panels

Initial Date  
Bill 6-9

Check Operation,  
Exercise Transfer Chassis

-Light Bulbs

Initial Date  
Bill 6-9

Check all bulbs.  
Replace any that need replacing  
in Effluent Pump House

-Sweep Floor

Initial Date  
Bill 6-9

Sweep All Levels  
of Effluent Pump House