



East Shore Road Weekly PMs

Week of : 9/14/09 - 9/18/09

East Shore Road

Headworks

Main Floor

-Grit Cyclone

Check for Clogging,
Drain & Nozzle

Initial Date
Bill 9.14

-Classifier

Hose Down,
Grease Lower Bearing (12 SHOTS/ON)
Check Gearbox Oil

Initial Date
Bill 9.14

-Bubbler Panel

Check Operation,
Exercise Transfer Chasis

Initial Date
Bill 9.14

-Hose Off Floor

Make sure entire
area is hosed down

Initial Date
Bill 9.14

-Light Bulbs

Check all bulbs.
Replace any that need
replacing in Headworks Building

Initial Date
Bill 9.14

Grit Chamber

-Grit Collector

Check Gearbox Oil,
Worm Gearbox Oil (85-140 Gear Lube)

Initial Date
Bill 9.14

Primary Tanks

-Drives

Check Gearbox Oil
(AGMA 5)

Initial Date
Bill 9.14

-Raw Sludge

Pumping Station
Sludge Pumps, Check Gearbox Oil, Grease Pillow Block

Initial Date
Bill 9.14

Digesters

Roof

-Flame Traps

Gas Compressors,
Gearbox,
Check Oil Level (Oils: #2 & 3 - 30 Wt ; #1 - Synthetic Blower Oil)

Initial Date
Bill 9.14

-Sweep Floor

Sweep All Levels
of Digesters Building

Initial Date
Bill 9.14

Main Floor

-Boilers

Water Pressure,
Expansion, Tank IV, Drain Methane Lines (DIG. 3 only)

Initial Date
Bill 9.14

Basement

-Re-circulators

Grease Stuffing Box
(As Needed)

Initial Date
Bill 9.14

-Digester Drip Traps

Drain Each

Initial Date
Bill 9.14

De-Watering Building

Main Floor

-Emergency Eye

Wash / Shower,
Flush Out

Initial Date
Bill 9.16

-Sweep Floor

Sweep Floor of
De-Watering Building

Initial Date
Bill 9.16

Pump Station "A"

Building

-Re-Circulating

Pumps
Grease Stuffing Box, Hose Down Stuffing Box
(12 Shots (On))

Initial Date
Bill 9.14

-Bubbler Panel

Check Operation,
Exercise Transfer Chasis

Initial Date
Bill 9.14

-Hose Off Floor

Make sure entire
area is hosed down

Initial Date
Bill 9.14

-Light Bulbs

Check all bulbs.
Replace any that need replacing
in Pump Station "A"

Initial Date
Bill 9.14



East Shore Road Weekly PMs

9/14/09 - 9/18/09

Pump Station "B"

Building

-Re-Circulating

Initial Date
Bill 9.17

Pumps

Grease Stuffing Box, Hose Down Stuffing Box
(NO GREASE)

-Bubbler Panel

Initial Date
Bill 9.17

Check Operation,
Exercise Transfer Chassis

-Sweep Floor

Initial Date
Bill 9.17

Sweep All Levels
of Building "B"

Pump Station "C"

Building

-Re-Circulating

Initial Date
Bill 9.17

Pumps

Grease Stuffing Box, Hose Down Stuffing Box
(NO GREASE)

-Bubbler Panel

Initial Date
Bill 9.17

Check Operation,
Exercise Transfer Chassis

-Sweep Floor

Initial Date
Bill 9.17

Sweep All Levels
of Building "C"

-Light Bulbs

Initial Date
Bill 9.17

Check all bulbs.
Replace any that need replacing
in Pump Station "C"

Administration Building

-Light Bulbs

Initial Date
Bill 9.18

Check all bulbs.
Replace any that need replacing
in Each Room of the Administration Building

-Toilet Paper and Paper Towels

Initial Date
Bill 9.18

Check all toilet paper
and automatic paper towel dispensers in bathrooms
kitchen area and downstairs. Replace if empty.

Hypo Room

-Eye Wash/Shower

Initial Date
Bill 9.18

Flush Out

Boiler Room

-Compressors

Initial Date
Bill 9.18

(OFF) Drain Water
in Tanks, Check Oil Levels

Final Tanks

-Drives

Initial Date
Bill 9.17

Check Gearbox Oil
(AGMA 5)

-Telescoping

Initial Date
Bill 9.17

Valves
Check for Clogging

Sand Filters

-Drained, hosed down

Initial Date
Bill 9.16

Re-grade sand if needed

-Light Bulbs

Initial Date
Bill 9.16

Check all bulbs.
Replace any that need replacing
in Sand Filter Building

Sand Beds

-Re-grade Sand #1

Initial Date
Bill 9.16

-Re-grade Sand #2

Initial Date
Bill 9.16

Effluent Pump House

Main Floor

-Diesel

Initial Date
Bill 9.17

Generator Kit

Check Oil Level,

Battery & Radiator

-Exercise Engine a min

Initial Date
Bill 9.17

of 30 minutes:

3x/month w/o load

1x/month underload

Start End Hours

4882 4892 1

-Bubbler Panels

Initial Date
Bill 9.17

Check Operation,
Exercise Transfer Chassis

-Light Bulbs

Initial Date
Bill 9.17

Check all bulbs.
Replace any that need replacing
in Effluent Pump House

-Sweep Floor

Initial Date
Bill 9.17

Sweep All Levels
of Effluent Pump House