



East Shore Road Multi Yeared PMs

Multi Yeared for:

2010

East Shore Road

Headworks

C. Limber

-Change Gearbox Oil

(Every Five Years)

		Date	
Initial	Performed	Reading	
✓		9/28	9350

Previous:

9/2005

Due	
9/2010	

-Grease Motor Bearings

(Every Five Years)

		Date	
Initial	Performed	Reading	
✓		9/25	9350

Previous:

9/2005

Due	
9/2010	

Grease Pump

Grease Motor #1

-Grease Motor Bearings

(Every 2 Years)

Previous:

12/2008

		Date	
Initial	Performed	Reading	
① ✓		9/25	16200

Due	
9/2010	

Grease Pump

Grease Motor #2

-Grease Motor Bearings

(Every 2 Years)

Previous:

12/2008

		Date	
Initial	Performed	Reading	
① ✓		9/25	35,500

Due	
9/2010	

8/2010
due 9/10

① Sealed bearings

Digesters

Basement

Sludge Recirculators

Grease Motor #1

-Grease Motor Bearings

(Every 2 Years)

Previous:

04/2009

		Date	
Initial	Performed	Reading	
X	X	X	X

Due	
04/2011	

Grease Motor #2

-Grease Motor Bearings

(Every 2 Years)

Previous:

04/2009

		Date	
Initial	Performed	Reading	
X	X	X	X

Due	
04/2011	

Grease Motor #3

-Grease Motor Bearings

(Every 2 Years)

Previous:

04/2009

		Date	
Initial	Performed	Reading	
X	X	X	X

Due	
04/2011	

Grease Motor #4

-Grease Motor Bearings

(Every 2 Years)

Previous:

04/2009

		Date	
Initial	Performed	Reading	
X	X	X	X

Due	
04/2011	

Recirculator Pump # 1

-Replace Sleeves

(As Needed)

Previous:

Recirculator Pump # 3

-Replace Sleeves

(As Needed)

Previous:

Initial	Performed	Reading

Replace After 2nd Repacking

Initial	Performed	Reading

Replace After 2nd Repacking

Recirculator Pump # 2

-Replace Sleeves

(As Needed)

Previous:

Recirculator Pump # 4

-Replace Sleeves

(As Needed)

Previous:

Initial	Performed	Reading

Replace After 2nd Repacking

Initial	Performed	Reading
✓	9/7	36100

Replace After 2nd Repacking

① factory sleeve installed

MY



East Shore Road Multi Yeared PMs

2010

Sludge Pumps

Grease Motor #1

-Grease Motor Bearings
(Every 2 Years)

Previous:

04/2009

Date		
Initial	Performed	Reading
X	X	X
Due		
04/2011		

Grease Motor #2

-Grease Motor Bearings
(Every 2 Years)

Previous:

04/2009

Date		
Initial	Performed	Reading
X	X	X
Due		
04/2011		

Grease Motor #3

-Grease Motor Bearings
(Every 2 Years)

Previous:

04/2009

Date		
Initial	Performed	Reading
X	X	X
Due		
04/2011		

Grease Motor #4

-Grease Motor Bearings
(Every 2 Years)

Previous:

04/2009

Date		
Initial	Performed	Reading
X	X	X
Due		
04/2011		

G/2010
Value 4/11
du - 12/10

De-watering Building

Main Floor

In Line Polymer Mix Valve

-Disassemble and Clean

(As Needed)

Date	
Initial	Performed
V2	4/7

Date	
Initial	Performed

(additional entries)

Basement

Grease Motor

-Grease Motor Bearings

(Every 2 Years)

Previous:

012/2009

Date		
Initial	Performed	Reading
X	X	X
Due		
12/2011		

Pump Station "A"

Grease Motor #1

-Grease Motor Bearings

(Every 2 Years) 12 SHOTS/OFF

Previous:

12/2008

Date		
Initial	Performed	Reading
V2	6/23	86300
Due		
12/2010		

Grease Motor #2

-Grease Motor Bearings

(Every 2 Years) 12 SHOTS/OFF

Previous:

12/2008

Date		
Initial	Performed	Reading
V2	6/23	45700
Due		
12/2010		

Grease Motor #3

-Grease Motor Bearings

(Every 2 Years) 12 SHOTS/OFF

Previous:

12/2008

Date		
Initial	Performed	Reading
V2	6/23	88000
Due		
12/2010		

Wet Well

Fully Clean Out

(Every 3 Years)

Previous:

12/2008

Date	
Initial	Performed
X	X
Due	
12/2013	

MM East Shore Road - 2 ✓ 2010



East Shore Road Multi Yeared PMs

Pump Station "B" ✓

Grease Motor #1
 Initial Performed Reading
 -Grease Motor Bearings VZ 12/16 26000
 (Every 2 Years) 12 SHOTS/OFF
 Previous: Due
 12/2008 12/2010

Grease Motor #2
 Initial Performed Reading
 -Grease Motor Bearings VZ 12/16 89000
 (Every 2 Years) 12 SHOTS/OFF
 Previous: Due
 12/2008 12/2010

6/2010
due 12/10

Wet Well
 Initial Performed
 Fully Clean Out X X
 (Every 3 Years)
 Previous: Due
 12/2009 12/2012

2010

Pump Station "C" ✓

Grease Motor #1
 Initial Performed Reading
 -Grease Motor Bearings VZ 6/23 85800
 (Every 2 Years) 12 SHOTS/OFF
 Previous: Due
 12/2008 12/2010

Grease Motor #2
 Initial Performed Reading
 -Grease Motor Bearings VZ 6/23 92300
 (Every 2 Years) 12 SHOTS/OFF
 Previous: Due
 12/2008 12/2010

Wet Well ✓
 Initial Performed
 Fully Clean Out X X
 (Every 3 Years)
 Previous: Due
 12/2009 12/2012

due 12/12

Administration Building

Hypo Room ✓
 Dismantle and Overhaul
 Hypo Pumps
 (as needed)
 Initial Performed
VZ 10/28 1/5/11

Well House ✓
 Change Oil
 in Compressor
 SAE 30-NON DETERGENT
 (Every 2 Years)
 Previous: Due
 2/2008 2/2010

Trickling Filter B ✓

Change Upper
 Initial Performed
 Bearing Oil X X
 (Every 2 Years)
 Previous: Due
 6/2009 6/2011

due 6/11

Trickling Filter C ✓

Secondary Sludge Pumping Station
 -Pumps
 Inspect and Change Oil #1
 (Every 2 Years)
 (DIALECTRIC OIL - SUBMERSABLE PUMP)
 Previous: Due
 9/2009 9/2011

Secondary Sludge Pumping Station
 -Pumps
 Inspect and Change Oil #2
 (Every 2 Years)
 (DIALECTRIC OIL - SUBMERSABLE PUMP)
 Previous: Due
 9/2009 9/2011

due 9/11

MY

✓



East Shore Road Multi Yeared PMs

Final Tanks ✓

Grease Motor

-Grease Motor Bearings

(Every 2 Years)

Previous:

2008

Chlorine Mixing Chamber

Initial	Performed	Reading
V2	6/25/10	66K
	5/10	Sealed
		Sealed
		34K

1
2
3
4

Due
2010

2010

6/2010
due 12/10

Grease Motor

-Grease Motor Bearings

(Every 2 Years)

Previous:

2008

Initial	Performed	Reading
V2	6/25/10	49K

Sealed bearings in motor ✓

Due
2010

Effluent Pump House ✓

Effluent Pumps

Grease Motor #1

-Grease Motor Bearings

(Every 2 Years)

Previous:

12/2008

12 SHOTS/OFF

Initial	Performed	Reading
V2	6/23	34800

Due
12/2010

Grease Motor #2

-Grease Motor Bearings

(Every 2 Years)

Previous:

12/2008

12 SHOTS/OFF

Initial	Performed	Reading
V2	6/23	31800

Due
12/2010

Grease Motor:

-Grease Motor Bearings

(Every 2 Years)

Previous:

12/2008

12 SHOTS/OFF

Initial	Performed	Reading
V2	6/23/10	

Due
12/2010

Backwash Pumps

Grease Motor #1

-Grease Motor Bearings

(Every 2 Years)

Previous:

12/2008

8 SHOTS/OFF

Initial	Performed	Reading
V2	6/23	33000

Due
12/2010

Grease Motor #2

-Grease Motor Bearings

(Every 2 Years)

Previous:

12/2008

8 SHOTS/OFF

Initial	Performed	Reading
V2	6/23	33000

Due
12/2010

due 12/10

Plant Water Pumps

Grease Motor #1

-Grease Motor Bearings

(Every 2 Years)

Previous:

12/2008

10 SHOTS/OFF

Initial	Performed	Reading
V2	9/29	6600

Due
12/2010

Grease Motor #2

-Grease Motor Bearings

(Every 2 Years)

Previous:

12/2008

10 SHOTS/OFF

Initial	Performed	Reading
V2	9/29	2900

Due
12/2010

Automatic Strainer

Change Gearbox Oil

85W/140

Previous:

12/2009

Initial	Performed
X	X

Due
12/2011