



# East Shore Road Weekly PMs

Week of : 3/22/10 - 3/26/10

## East Shore Road

### Headworks

#### Main Floor

-Grit Cyclone

Initial Date  
B.u 3.22

Check for Clogging,  
Drain & Nozzle

-Classifier

Initial Date  
B.u 3.22

Hose Down,  
Grease Lower Bearing (12 SHOTS/ON)  
Check Gearbox Oil

-Bubbler Panel

Initial Date  
B.u 3.22

Check Operation,  
Exercise Transfer Chasis

-Hose Off Floor

Make sure entire  
area is hosed down

Initial Date  
B.u 3.22

-Light Bulbs

Check all bulbs.  
Replace any that need  
replacing in Headworks Building

Initial Date  
B.u 3.22

#### Grit Chamber

-Grit Collector

Initial Date  
B.u 3.22

Check Gearbox Oil,  
Worm Gearbox Oil (85-140 Gear Lube)

#### Primary Tanks

-Drives

Initial Date  
B.u 3.22

Check Gearbox Oil  
(AGMA 5)

-Raw Sludge

Initial Date  
B.u 3.22

Pumping Station  
Sludge Pumps, Check Gearbox Oil, Grease Pillow Block

### Digesters

#### Roof

-Flame Traps

Gas Compressors,

Initial Date  
B.u 3.22

Gearbox,  
Check Oil Level (Oils: #2 & 3 - 30 Wt. ; #1 - Synthetic Blower Oil)

-Sweep Floor

Sweep All Levels  
of Digesters Building

Initial Date  
B.u 3.22

#### Main Floor

-Boilers

Initial Date  
B.u 3.22

Water Pressure,  
Expansion, Tank lvl, Drain Methane Lines (DIG. 3 only)

#### Basement

-Re-circulators

Initial Date  
B.u 3.22

Grease Stuffing Box  
(As Needed)

-Digester Drip Traps

Initial Date  
B.u 3.22

Drain Each

### De-Watering Building

#### Main Floor

-Emergency Eye

Wash / Shower,  
Flush Out

Initial Date  
B.u 3.22

-Sweep Floor

Sweep Floor of  
De-Watering Building

Initial Date  
B.u 3.22

### Pump Station "A"

#### Building

-Re-Circulating

Initial Date  
B.u 3.25

Pumps  
Grease Stuffing Box, Hose Down Stuffing Box  
(12 Shots (On))

-Bubbler Panel

Initial Date  
B.u 3.25

Check Operation,  
Exercise Transfer Chasis

-Hose Off Floor

Make sure entire  
area is hosed down

Initial Date  
B.u 3.25

-Light Bulbs

Check all bulbs.  
Replace any that need replacing  
in Pump Station "A"

Initial Date  
B.u 3.25



# East Shore Road Weekly PMs

3/22/10 - 3/26/10

## Pump Station "B"

### Building

-Re-Circulating

Initial Date  
Bill 3-25

-Bubbler Panel

Initial Date  
Bill 3-25

-Sweep Floor

Initial Date  
Bill 3-25

### Pumps

Grease Stuffing Box, Hose Down Stuffing Box  
(NO GREASE)

Check Operation,  
Exercise Transfer Chasis

Sweep All Levels  
of Building "B"

## Pump Station "C"

### Building

-Re-Circulating

Initial Date  
Bill 3-25

-Bubbler Panel

Initial Date  
Bill 3-25

-Sweep Floor

Initial Date  
Bill 3-25

### Pumps

Grease Stuffing Box, Hose Down Stuffing Box  
(NO GREASE)

Check Operation,  
Exercise Transfer Chasis

Sweep All Levels  
of Building "C"

-Light Bulbs

Initial Date  
Bill 3-25

Check all bulbs.  
Replace any that need replacing  
in Pump Station "C"

## Administration Building

-Light Bulbs

Initial Date  
Bill 3-26

Check all bulbs.  
Replace any that need replacing  
in Each Room of the Administration Building

-Toilet Paper and Paper Towels

Initial Date  
Bill 3-26

Check all toilet paper  
and automatic paper towel dispensers in bathrooms  
kitchen area and downstairs. Replace if empty.

## Hypo Room

-Eye Wash/Shower

Initial Date  
Bill 3-26

Flush Out

## Boiler Room

-Compressors

Initial Date  
Bill 3-26

(OFF) Drain Water  
in Tanks, Check Oil Levels

## Final Tanks

-Drives

Initial Date  
Bill 3-24

Check Gearbox Oil  
(AGMA 5)

-Telescoping

Initial Date  
Bill 3-24

Valves  
Check for Clogging

## Sand Filters

-Drained, hosed down

Initial Date  
Bill 3-24

Re-grade sand if needed

-Light Bulbs

Initial Date  
Bill 3-24

Check all bulbs.  
Replace any that need replacing  
in Sand Filter Building

## Sand Beds

-Re-grade Sand #1

Initial Date  
Bill 3-24

-Re-grade Sand #2

Initial Date  
Bill 3-24

## Effluent Pump House

### Main Floor

-Diesel

Initial Date  
Bill 3-25

Generator Kit  
Check Oil Level,

Battery & Radiator

-Exercise Engine a min

Initial Date  
Bill 3-25

of 30 minutes:  
3x/month w/o load  
1x/month underload

Start	End	Hours
5:51	5:09	1

-Bubbler Panels

Initial Date  
Bill 3-25

Check Operation,  
Exercise Transfer Chassis

-Light Bulbs

Initial Date  
Bill 3-25

Check all bulbs.  
Replace any that need replacing  
in Effluent Pump House

-Sweep Floor

Initial Date  
Bill 3-25

Sweep All Levels  
of Effluent Pump House