



# East Shore Road Weekly PMs

Week of : 3/29/10 - 4/2/10

## East Shore Road

### Headworks

#### Main Floor

##### -Grit Cyclone

Check for Clogging,  
Drain & Nozzle

Initial Date  
B.U 4.1

##### -Classifier

Hose Down,  
Grease Lower Bearing (12 SHOTS/ON)  
Check Gearbox Oil

Initial Date  
B.U 4.1

##### -Bubbler Panel

Check Operation,  
Exercise Transfer Chasis

Initial Date  
B.U 4.1

##### -Hose Off Floor

Make sure entire  
area is hosed down

Initial Date  
B.U 4.1

##### -Light Bulbs

Check all bulbs.  
Replace any that need  
replacing in Headworks Building

Initial Date  
B.U 4.1

### Grit Chamber

#### -Grit Collector

Check Gearbox Oil,  
Worm Gearbox Oil (85-140 Gear Lube)

Initial Date  
B.U 4.1

### Primary Tanks

#### -Drives

Check Gearbox Oil  
(AGMA 5)

Initial Date  
B.U 4.1

#### -Raw Sludge

Pumping Station  
Sludge Pumps, Check Gearbox Oil. Grease Pillow Block

Initial Date  
B.U 4.1

### Digesters

#### Roof

##### -Flame Traps

Gas Compressors,

Gearbox,

Check Oil Level (Oils: #2 & 3 - 30 Wt. ; #1 - Synthetic Blower Oil)

Initial Date  
B.U 3-31

##### -Sweep Floor

Sweep All Levels

of Digesters Building

Initial Date  
B.U 3-31

#### Main Floor

##### -Boilers

Water Pressure,

Expansion, Tank IV, Drain Methane Lines (DIG. 3 only)

Initial Date  
B.U 3-31

### Basement

#### -Re-circulators

Grease Stuffing Box  
(As Needed)

Initial Date  
B.U 3-31

#### -Digester Drip Traps

Drain Each

Initial Date  
B.U 3-31

### De-Watering Building

#### Main Floor

##### -Emergency Eye

Wash / Shower,  
Flush Out

Initial Date  
B.U 3-29

##### -Sweep Floor

Sweep Floor of  
De-Watering Building

Initial Date  
B.U 3-29

### Pump Station "A"

#### Building

##### -Re-Circulating

Pumps

Grease Stuffing Box, Hose Down Stuffing Box  
(12 Shots (On))

Initial Date  
B.U 3-29

##### -Bubbler Panel

Check Operation,  
Exercise Transfer Chasis

Initial Date  
B.U 3-29

##### -Hose Off Floor

Make sure entire  
area is hosed down

Initial Date  
B.U 3-29

##### -Light Bulbs

Check all bulbs.

Replace any that need replacing  
in Pump Station "A"

Initial Date  
B.U 3-29



# East Shore Road Weekly PMs

3/29/10 - 4/2/10

## Pump Station "B"

### Building

-Re-Circulating

Initial Date  
Bill 3-31

-Bubbler Panel

Initial Date  
Bill 3-31

-Sweep Floor

Initial Date  
Bill 3-31

### Pumps

Grease Stuffing Box, Hose Down Stuffing Box  
(NO GREASE)

Check Operation,  
Exercise Transfer Chassis

Sweep All Levels  
of Building "B"

## Pump Station "C"

### Building

-Re-Circulating

Initial Date  
Bill 3-31

-Bubbler Panel

Initial Date  
Bill 3-31

-Sweep Floor

Initial Date  
Bill 3-31

### Pumps

Grease Stuffing Box, Hose Down Stuffing Box  
(NO GREASE)

Check Operation,  
Exercise Transfer Chassis

Sweep All Levels  
of Building "C"

-Light Bulbs

Initial Date  
Bill 3-31

Check all bulbs.  
Replace any that need replacing  
in Pump Station "C"

## Administration Building

-Light Bulbs

Initial Date  
Bill 4-2

Check all bulbs.  
Replace any that need replacing  
In Each Room of the Administration Building

-Toilet Paper and Paper Towels

Initial Date  
Bill 4-2

Check all toilet paper  
and automatic paper towel dispensers in bathrooms  
kitchen area and downstairs. Replace if empty.

## Hypo Room

-Eye Wash/Shower

Initial Date  
Bill 4-2

Flush Out

## Boiler Room

-Compressors

Initial Date  
Bill 4-2

(OFF) Drain Water  
In Tanks, Check Oil Levels

## Final Tanks

-Drives

Initial Date  
Bill 3-31

Check Gearbox Oil  
(AGMA 5)

-Telescoping

Initial Date  
Bill 3-31

Valves  
Check for Clogging

## Sand Filters

-Drained, hosed down

Initial Date  
Bill 3-31

Re-grade sand if needed

-Light Bulbs

Initial Date  
Bill 3-31

Check all bulbs.  
Replace any that need replacing  
in Sand Filter Building

## Sand Beds

-Re-grade Sand #1

Initial Date  
Bill 3-31

-Re-grade Sand #2

Initial Date  
Bill 3-31

## Effluent Pump House

### Main Floor

-Diesel

Initial Date  
Bill 4-2

Generator Kit  
Check Oil Level,

-Exercise Engine a min

Initial Date  
Bill 4-2

of 30 minutes:

3x/month w/o load

1x/month underload

Start	End	Hours
516	517	1

Battery & Radiator

-Bubbler Panels

Initial Date  
Bill 4-2

Check Operation,  
Exercise Transfer Chassis

-Light Bulbs

Initial Date  
Bill 4-2

Check all bulbs.  
Replace any that need replacing  
in Effluent Pump House

-Sweep Floor

Initial Date  
Bill 4-2

Sweep All Levels  
of Effluent Pump House