



East Shore Road Weekly PMs

Week of : 5/10/10 - 5/14/10

East Shore Road

Headworks

Main Floor

-Grit Cyclone

Check for Clogging,
Drain & Nozzle

Initial Date
Bill 5.10

-Classifier

Hose Down,
Grease Lower Bearing (12 SHOTS/ON)
Check Gearbox Oil

Initial Date
Bill 5.10

-Bubbler Panel

Check Operation,
Exercise Transfer Chasis

Initial Date
Bill 5.10

-Hose Off Floor

Make sure entire
area is hosed down

Initial Date
Bill 5.10

-Light Bulbs

Check all bulbs.
Replace any that need
replacing in Headworks Building

Initial Date
Bill 5.10

Grit Chamber

-Grit Collector

Check Gearbox Oil,
Worm Gearbox Oil (85-140 Gear Lube)

Initial Date
Bill 5.10

Primary Tanks

-Drives

Check Gearbox Oil
(AGMA 5)

Initial Date
Bill 5.10

-Raw Sludge

Pumping Station
Sludge Pumps, Check Gearbox Oil, Grease Pillow Block

Initial Date
Bill 5.10

Digesters

Roof

-Flame Traps

Gas Compressors,

Gearbox,
Check Oil Level (Oils: #2 & 3 - 30 Wt. ; #1 - Synthetic Blower Oil)

Initial Date
Bill 5.14

-Sweep Floor

Sweep All Levels
of Digesters Building

Initial Date
Bill 5.14

Main Floor

-Boilers

Water Pressure,
Expansion, Tank IV, Drain Methane Lines (DIG. 3 only)

Initial Date
Bill 5.14

Basement

-Re-circulators

Grease Stuffing Box
(As Needed)

Initial Date
Bill 5.14

-Digester Drip Traps

Drain Each

Initial Date
Bill 5.14

De-Watering Building

Main Floor

-Emergency Eye

Wash / Shower,
Flush Out

Initial Date
Bill 5.10

-Sweep Floor

Sweep Floor of
De-Watering Building

Initial Date
Bill 5.10

Pump Station "A"

Building

-Re-Circulating

Pumps
Grease Stuffing Box, Hose Down Stuffing Box
(12 Shots (On))

Initial Date
Bill 5.11

-Bubbler Panel

Check Operation,
Exercise Transfer Chasis

Initial Date
Bill 5.11

-Hose Off Floor

Make sure entire
area is hosed down

Initial Date
Bill 5.11

-Light Bulbs

Check all bulbs.
Replace any that need replacing
in Pump Station "A"

Initial Date
Bill 5.11



East Shore Road Weekly PMs

5/10/10 - 5/14/10

Pump Station "B"

Building

-Re-Circulating

Initial Date
B:11 5.12

-Bubbler Panel

Initial Date
B:11 5.12

-Sweep Floor

Initial Date
B:11 5.12

Pumps

Grease Stuffing Box, Hose Down Stuffing Box
(NO GREASE)

Check Operation,
Exercise Transfer Chassis

Sweep All Levels
of Building "B"

Pump Station "C"

Building

-Re-Circulating

Initial Date
B:11 5.12

-Bubbler Panel

Initial Date
B:11 5.12

-Sweep Floor

Initial Date
B:11 5.12

Pumps

Grease Stuffing Box, Hose Down Stuffing Box
(NO GREASE)

Check Operation,
Exercise Transfer Chassis

Sweep All Levels
of Building "C"

Light Bulbs

Initial Date
B:11 5.12

Check all bulbs.
Replace any that need replacing
in Pump Station "C"

Administration Building

Light Bulbs

Initial Date
B:11 5.14

Check all bulbs.
Replace any that need replacing
in Each Room of the Administration Building

Toilet Paper and Paper Towels

Initial Date
B:11 5.14

Check all toilet paper
and automatic paper towel dispensers in bathrooms
kitchen area and downstairs. Replace if empty.

Hypo Room

Eye Wash/Shower

Initial Date
B:11 5.14

Flush Out

Boiler Room

Compressors

Initial Date
B:11 5.14

(OFF) Drain Water
in Tanks, Check Oil Levels

Final Tanks

Drives

Initial Date
B:11 5.12

Check Gearbox Oil
(AGMA 5)

Telescoping

Initial Date
B:11 5.12

Valves
Check for Clogging

Sand Filters

Drained, hosed down

Initial Date
B:11 5.12

Re-grade sand if needed

Light Bulbs

Initial Date
B:11 5.12

Check all bulbs.
Replace any that need replacing
in Sand Filter Building

Sand Beds

Re-grade Sand #1

Initial Date
B:11 5.12

Re-grade Sand #2

Initial Date
B:11 5.12

Effluent Pump House

Main Floor

Diesel

Initial Date
B:11 5.11

Generator Kit
Check Oil Level,

Exercise Engine a min

Initial Date
B:11 5.11

of 30 minutes:
3x/month w/o load

Start End Hours

5223 5233 1

1x/month underload

Battery & Radiator

Bubbler Panels

Initial Date
B:11 5.11

Check Operation,
Exercise Transfer Chassis

Light Bulbs

Initial Date
B:11 5.11

Check all bulbs.
Replace any that need replacing
in Effluent Pump House

Sweep Floor

Initial Date
B:11 5.11

Sweep All Levels
of Effluent Pump House