



East Shore Road Weekly PMs

Week of : 6/07/10 - 6/11/10

East Shore Road

Headworks

Main Floor

-Grit Cyclone

Check for Clogging,
Drain & Nozzle

Initial Date
Bill 6-8

-Classifier

Hose Down,
Grease Lower Bearing (12 SHOTS/ON)
Check Gearbox Oil

Initial Date
Bill 6-8

-Bubbler Panel

Check Operation,
Exercise Transfer Chasis

Initial Date
Bill 6-8

-Hose Off Floor

Make sure entire
area is hosed down

Initial Date
Bill 6-8

-Light Bulbs

Check all bulbs.
Replace any that need
replacing in Headworks Building

Initial Date
Bill 6-8

Grit Chamber

-Grit Collector

Check Gearbox Oil,
Worm Gearbox Oil (85-140 Gear Lube)

Initial Date
Bill 6-8

Primary Tanks

-Drives

Check Gearbox Oil
(AGMA 5)

Initial Date
Bill 6-8

-Raw Sludge

Pumping Station
Sludge Pumps, Check Gearbox Oil, Grease Pillow Block

Initial Date
Bill 6-8

Digesters

Roof

-Flame Traps

Gas Compressors,
Gearbox,
Check Oil Level (Oils: #2 & 3 - 30 Wl. ; #1 - Synthetic Blower Oil)

Initial Date
Bill 6-10

-Sweep Floor

Sweep All Levels
of Digesters Building

Initial Date
Bill 6-10

Main Floor

-Bollers

Water Pressure,
Expansion, Tank Wl, Drain Methane Lines (DIG. 3 only)

Initial Date
Bill 6-10

Basement

-Re-circulators

Grease Stuffing Box
(As Needed)

Initial Date
Bill 6-10

-Digester Drip Traps

Drain Each

Initial Date
Bill 6-10

De-Watering Building

Main Floor

-Emergency Eye

Wash / Shower,
Flush Out

Initial Date
Bill 6-10

-Sweep Floor

Sweep Floor of
De-Watering Building

Initial Date
Bill 6-10

Pump Station "A"

Building

-Re-Circulating

Pumps
Grease Stuffing Box, Hose Down Stuffing Box
(12 Shots (On))

Initial Date
Bill 6-8

-Bubbler Panel

Check Operation,
Exercise Transfer Chasis

Initial Date
Bill 6-8

-Hose Off Floor

Make sure entire
area is hosed down

Initial Date
Bill 6-8

-Light Bulbs

Check all bulbs.
Replace any that need replacing
in Pump Station "A"

Initial Date
Bill 6-8



East Shore Road Weekly PMs

6/07/10 - 6/11/10

Pump Station "B"

Building

-Re-Circulating

Initial Date
Bill 6-8

-Bubbler Panel

Initial Date
Bill 6-8

-Sweep Floor

Initial Date
Bill 6-8

Pumps

Grease Stuffing Box, Hose Down Stuffing Box
(NO GREASE)

Check Operation,
Exercise Transfer Chassis

Sweep All Levels
of Building "B"

Pump Station "C"

Building

-Re-Circulating

Initial Date
Bill 6-7

-Bubbler Panel

Initial Date
Bill 6-7

-Sweep Floor

Initial Date
Bill 6-7

Pumps

Grease Stuffing Box, Hose Down Stuffing Box
(NO GREASE)

Check Operation,
Exercise Transfer Chassis

Sweep All Levels
of Building "C"

Light Bulbs

Initial Date
Bill 6-7

Check all bulbs.
Replace any that need replacing
in Pump Station "C"

Administration Building

Light Bulbs

Initial Date
Bill 6-9

Check all bulbs.
Replace any that need replacing
in Each Room of the Administration Building

Toilet Paper and Paper Towels

Initial Date
Bill 6-9

Check all toilet paper
and automatic paper towel dispensers in bathrooms
kitchen area and downstairs. Replace if empty.

Hypo Room

Eye Wash/Shower

Initial Date
Bill 6-11

Flush Out

Boiler Room

Compressors

Initial Date
Bill 6-11

(OFF) Drain Water
in Tanks, Check Oil Levels

Final Tanks

Drives

Initial Date
Bill 6-11

Check Gearbox Oil
(AGMA 5)

Telescoping

Initial Date
Bill 6-11

Valves
Check for Clogging

Sand Filters

Drained, hosed down

Initial Date
Bill 6-9

Re-grade sand if needed

Light Bulbs

Initial Date
Bill 6-9

Check all bulbs.
Replace any that need replacing
in Sand Filter Building

Sand Beds

Re-grade Sand #1

Initial Date
Bill 6-9

Re-grade Sand #2

Initial Date
Bill 6-9

Effluent Pump House

Main Floor

Diesel

Initial Date
Bill 6-11

Generator Kill
Check Oil Level,
Battery & Radiator

Exercise Engine a min

Initial Date

of 30 minutes:
3x/month w/o load
1x/month underload

Start End Hours

Temporary generator installed.
Does not need exercising,
(Spoke to Wayne from On Call.)

Bubbler Panels

Initial Date
Bill 6-8

Check Operation,
Exercise Transfer Chassis

Light Bulbs

Initial Date
Bill 6-8

Check all bulbs.
Replace any that need replacing
in Effluent Pump House

Sweep Floor

Initial Date
Bill 6-8

Sweep All Levels
of Effluent Pump House