



# East Shore Road Monthly PMs

Month of : NOVEMBER 2011

## East Shore Road

**Headworks**

Climber Screen Initial Date: AM 11/15

Grease Pin Rollers Initial Date: AM 11/15

Check Gearbox Oil Initial Date: AM 11/15

**Grit Chamber**

Grease Sleeve Bearing Initial Date: AM 11/15

(20 SHOTS/ON (SLOWLY)) Use Grease Type:

Grit Collector Initial Date: AM 11/15

Oil Drive Chain

Grit Pump Initial Date: AM 11/15

Alternate Pump

**Basement**

Sump Pumps Initial Date: AM 11/15

Check Operation & Alternate

Seal Water System Initial Date: AM 11/15

Check Operation of Float Valve

Alternate Pumps Initial Date: AM 11/15

Seal Water Pumps

Clean "Y" Strainer Initial Date: AM 11/15

**Digesters**

**Roof**

Pressure Relief & Vacuum Breakers Initial Date: AM 11/4

Check Operation

Check Drive Belts Initial Date: AM 11/4

Gas Valves Initial Date: AM 11/4

Exercise

Gas Ports Initial Date: AM 11/4

Check for Clogging

**Main Floor**

Gas Flow Charts Initial Date: AM 11/4

Check Operation

**Basement**

Plunger Pumps Initial Date: AM 11/4

Check Gearbox Oil

Grease Shaft Bearings Initial Date: AM 11/4

(4 SHOTS/OFF)

Gas & Sludge Valves Initial Date: AM 11/4

Exercise

Exhaust Fans Initial Date: AM 11/4

Check Operation

Alternate Pumps? Yes  No  Initial Date: AM 11/4

(As Needed)



# East Shore Road Monthly PMs

NOVEMBER 2011

## Pump Station "A"

-Alternate Pumps

Initial Date  
AM 11/15

-Dry Well Valves

Initial Date  
AM 11/15

Exercise

Exercise

## Pump Station "B"

-Dry Well Valves

Initial Date  
AM 11/15

-Re-Circulating Pumps

Initial Date  
AM 11/15

-Check

Alternate Pumps

## Pump Station "C"

-Alternate Pumps

Initial Date

-Dry Well Valves

Initial Date

Exercise

Exercise

Not in use

## Administration Building

Roof

-Hypo Room

Initial Date  
AM 11/22

-Piping Valves & Tanks

Initial Date  
AM 11/22

Hypo Pumps,

Check for Leaks

Check for Leaks, Check Gearbox Oil



# East Shore Road Monthly PMs

NOVEMBER 2011

## Administration Building *(continued)*

### Trickling Filters "A1" & "A2"

Clean Nozzles	Initial	Date	-Flood Media	Initial	Date	-Flood Media	Initial	Date
FlushOut,	AM	11/15	Flood A1	AM	11/15	Flood A2	AM	11/15
Distributor Arms, Grease Bearings								

### Trickling Filters "B"

Clean Nozzles	Initial	Date	-Flood Media	Initial	Date
FlushOut,			Flood B		
Distributor Arms, Grease Bearings					

Not in use

### Trickling Filters "C"

Clean Nozzles	Initial	Date	-Flood Media	Initial	Date
FlushOut,			Flood C		
Distributor Arms, Grease Bearings					

Unable to clean  
No stairs

## Final Tanks

-Old Tanks #1 & 2	Initial	Date
(New Tanks #1)	AM	11/23
Grease Shaft Bearings (10 SHOTS/ON)		

## Effluent Pump House

### Main Floor

-Sump Pump Panel	Initial	Date	-Sampling Machine	Initial	Date	-Exhaust Fan	Initial	Date
	AM	11/15	Change Hose	11/15	AM	Check Operation	11/15	AM

### Automatic Louver

Check Operation	Initial	Date
	AM	11/15

### Basement

-Backwash Pumps	Initial	Date	-Stand-by	Initial	Date
Grease Stuffing Box	AM	11/22	Air Compressors	AM	11/22
(10 SHOTS/ON) *#1 PUMP ONLY*			Exercise		

### Sump Pumps

Check Operation	Initial	Date
	AM	11/22



# East Shore Road Monthly PMs

NOVEMBER 2011

## Effluent Pump House (continued)

### Dry Well

-Exhaust Fan

Check Operation

Initial	Date
AM	11/23

### Chlorine Pump Sectors

-Cylinders Condition Acceptable?

Inspect the 6 cylinders and

determine condition.

Yes

No

Initial	Date
AM	11/23



If No...

Needs to be Replaced..

Date Replaced

# of Spare Cylinders on Hand

# of Spare Cylinders after Replacements

## Garage

-Boiler

Check Operation  
(Turned On & OFF)

Initial	Date
AM	11/22

-Air Compressor

Check Drive Belt,  
Check Oil Level, Drain Water From Tank

Initial	Date
AM	11/22

-Portable Pumps and

Generator  
Exercise and Check Oil

Initial	Date
AM	11/22

-Electric Door

Openers

Check Operation

Initial	Date
AM	11/22

## Portable Light Tower Generator

-Drain Fuel Filter

Check Operation

Initial	Date
AM	11/22

-Check Radiator

Hoses

Initial	Date
AM	11/22

-Change Engine Oil

& Filter

Initial	Date
AM	11/22