



East Shore Road Weekly PMs

Monday - Friday : 11/28/2011 - 12/2/2011

East Shore Road

Headworks

Grit Chamber

-Grit Collector

Initial	Date
AM	12/1

Check Gearbox Oil,
Worm Gearbox Oil (85-140 Gear Lube)

Digesters

Roof

-Flame Traps

Gas Compressors,

Initial	Date
AM	11/28

Gearbox,
Check Oil Level (Oils: #2 & 3 - 30 Wt. ; #1 - Synthetic Blower Oil)

Main Floor

-Boilers

Initial	Date
AM	11/28

Water Pressure,
Expansion, Tank lvl, Drain Methane Lines (DIG. 3 only)

Basement

-Re-circulators

Initial	Date
AM	11/28

Grease Stuffing Box
(As Needed) Use Grease Type:

Effluent Pump House

Main Floor

-Diesel

Initial	Date
AM	12/1

Generator Kil

Check Oil Level,
Battery & Radiator

-Exercise Engine a min	<table border="1"><tr><th>Initial</th><th>Date</th></tr><tr><td>AM</td><td>12/1</td></tr></table>	Initial	Date	AM	12/1		
Initial	Date						
AM	12/1						
of 30 minutes:							
3x/month w/o load	<table border="1"><tr><th>Start</th><th>End</th><th>Hours</th></tr><tr><td>595.5</td><td>595.9</td><td>.30</td></tr></table>	Start	End	Hours	595.5	595.9	.30
Start	End	Hours					
595.5	595.9	.30					
1x/month underload							
Check the One Below that Applies for this Week:							
<table border="1"><tr><td>w/o Load</td><td>underload</td></tr><tr><td><input checked="" type="checkbox"/></td><td><input type="checkbox"/></td></tr></table>	w/o Load	underload	<input checked="" type="checkbox"/>	<input type="checkbox"/>			
w/o Load	underload						
<input checked="" type="checkbox"/>	<input type="checkbox"/>						



EAST SHORE ROAD WEEKLY PMS

Monday - Friday : 11/28/2011 - 12/2/2011

East Shore Road - De-Watering Building Sheets

De-Watering Building

Main Floor

-Emergency Eye Wash/Shower

Initial	Date
DS	11/29

Flush Out

-Sweep Floor

Initial	Date
DS	11/29

Sweep Floor of De-Watering Building

-Check Gearbox Oil

Initial	Date
DS	12/2

-Supply Fans

Initial	Date
DS	11/29

Check Operation

-Louvers

Initial	Date
DS	11/29

Check Operation

Use Oil Type:

Basement

-Plunger Pumps

Initial	Date
DS	12/2

Grease Shaft Bearings.

Check Gearbox Oil

(4 SHOTS/OFF)

-Re-Circulators

Initial	Date
DS	12/2

-Grease Stuffing Boxes

-Dezurik Valves

Initial	Date
DS	11/29

Exercise

Use Grease Type:

Use Grease Type:



East Shore Road Weekly PMs

Monday - Friday : 11/28/2011 - 12/2/2011

East Shore Road - Pumper's Sheets

Headworks

Primary Tanks

-Drives

Initial	Date
GOC	12/2

Check Gearbox Oil

(AGMA 5)

-Raw Sludge

Initial	Date
GOC	12/2

Pumping Station

Sludge Pumps, Check Gearbox Oil, Check for Block

Digesters

Basement

-Digester Drip Traps

Initial	Date
GOC	12/2

Drain Each

-Sump Pumps

Initial	Date
GOC	12/2

Check Operation

Final Tanks

-Drives

Initial	Date
GOC	12/2

Check Gearbox Oil

(AGMA 5)

-Telescoping

Initial	Date
GOC	12/2

Valves

Check for Clogging



East Shore Road Saturday Weekly PMs

Saturday : 12/3/2011

East Shore Road - Saturday PM

This PM Work is to be Done in Between Sampling on Saturday

Please Note Prior to Pumping on Saturday 10" - 12" is to be pumped to Digester 3 unless otherwise instructed prior to pumping process on this day.

Pump Station "A"

Building

-Bubbler Panel

Initial	Date
B.V	12-3

-Sump Pumps

Initial	Date
B.V	12-3

-Exhaust Fans

Initial	Date
B.V	12-3

Check Operation,
Exercise Transfer Chassis
(12 Shots (On))

Check Operation

Check Operation

-Re-Circulating

Initial	Date
B.V	12-3

Pumps

Grease Stuffing Box, Hose Down Stuffing Box
(12 Shots (On)) Use Grease Type:

Pump Station "B"

Building

-Bubbler Panel

Initial	Date
B.V	12-3

-Sump Pumps

Initial	Date
B.V	12-3

-Exhaust Fans

Initial	Date
B.V	12-3

Check Operation,
Exercise Transfer Chassis

Check Operation

Check Operation

-Re-Circulating

Initial	Date
B.V	12-3

Pumps

Hose Down Stuffing Box
(NO GREASE)

Pump Station "C"

Building

-Bubbler Panel

Initial	Date

-Sump Pumps

Initial	Date

-Exhaust Fans

Initial	Date

Check Operation,
Exercise Transfer Chassis

Check Operation

Check Operation

-Re-Circulating

Initial	Date

Pumps

Hose Down Stuffing Box
(NO GREASE)

OFF Line



East Shore Road Saturday Weekly PMs

12/3/2011

Administration Building

Roof

-Exhaust Fan
Check Operation

Initial	Date
Bill	12-3

Hypo Room

-Eye Wash/Shower
Flush Out

Initial	Date
Bill	12-3

Boiler

-Check Operation

Initial	Date
Bill	12-3

Final Tanks

-Telescoping
Valves

-Check for Clogging

Initial	Date
Bill	12-3

Effluent Pump House

Hypo Room

-Bubbler Panels
Check Operation,
Exercise Transfer Chassis

Initial	Date
Bill	12-3



East Shore Road Sunday Weekly PMs

Sunday : 12/4/2011

East Shore Road - Sunday PM

This PM Work is to be Done in Between Sampling on Sunday

Please Note Prior to Pumping on Sunday, 10" - 12" is to be pumped to Digester 3 unless otherwise Instructed prior to pumping process on this day.

Headworks

Main Floor

-Grit Cyclone

Check for Clogging,
Drain & Nozzle

Initial	Date
Bill	12-4

-Rag Pails and Grit

Empty pails and grit.
Cover Fully w/ Sludge
cake or lime

Initial	Date
Bill	12-4

-Bubbler Panel

Check Operation,
Exercise Transfer Chasis

Initial	Date
Bill	12-4

-Wash Floor

Make sure entire floor
is scrubbed and
hosed down. Then
Apply Reodorant.

Initial	Date
Bill	12-4

-Classifier

Hose Down,
Grease Lower Bearing
(12 SHOTS/ON)
Use Grease Type.

Initial	Date
Bill	12-4

Final Tanks

-Telescoping

Valves
Check for Clogging

Initial	Date
Bill	12-4

White Portable Light Tower

Prior to this Maintenance on Sunday, Bring White Portable Light Tower Back to District Grounds from Bayview Pump Station

Engine Maintenance

Check Tire Pressures

Initial	Date
Bill	12-4

Check Engine Oil Level

Initial	Date
Bill	12-4

Check Engine Coolant

Level

Initial	Date
Bill	12-4

Check Fuel Level

Initial	Date
Bill	12-4

Check Alternator

Belt

Initial	Date
Bill	12-4