

Pump Stations Monthly PMs

Month of: January

Manhasset Valley

Main Floor

-Exhaust Air Louver's
Check Operation

Initial	Date
GOC	1/10

-Fresh Air Louver's
Check Operation

Initial	Date
GOC	1/10

-Alarms
Check Operation

Initial	Date
GOC	1/10

Dry Well

-Sump Pumps
Check Operation

Initial	Date
GOC	1/10

-Exhaust Fans
Check Operation

Initial	Date
GOC	1/10

②

Wet Well

-Well
Remove Grease,
Exercise Splitter Valve

Initial	Date
GOC	1/10

③

-Check Oil

Initial	Date
GOC	1/10

-Bypass Channel
Flush Channel
Clean Bar Screen

Initial	Date
GOC	1/10

-Exhaust Fans
Check Operation

Initial	Date
GOC	1/10

Shelter Rock

Main Floor

-CO2 Tank
Check Pressure,
Check for Leaks (950 psi)

Initial	Date
GOC	1/10

-Exhaust Fans
Check Operation

Initial	Date
GOC	1/10

-Alarm System
Check Operation

Initial	Date
GOC	1/10

②

Wet Well

-Remove Rags
and Grease

Initial	Date
GOC	1/10

①

Bayview Pump House

Main Floor

-Panel Boards
Check Blower
Operation

Initial	Date
GOC	1/9

-Exhaust Fans
Check Operation

Initial	Date
GOC	1/9

-Alarms
Check Operation
Check Tank Fill Valve & Operating Pressure

Initial	Date
GOC	1/10

②

Dry Well

-Check Daily Run Time

Initial	Date
GOC	1/10

-Grease Drive Shafts

Initial	Date
GOC	1/10

-Sump Pumps
Check Operation

Initial	Date
GOC	1/9

-Valves
Exercise

Initial	Date
GOC	1/9

-Solenoid Valves
Check Operation

Initial	Date
GOC	1/9

① Rags & grease removed by VACTOR. BEING done during week of the 14th

② setting up schedule to test alarms on monthly basis.
③ going to clean well the week of the 14th

Pump Stations Monthly PMs

Month of: January

Bayview Main Building

Roof

-Exhaust Fans
Check Operation

Initial	Date
GOC	1/9

Hypo Room

-Hypo Pump
Check Oil Level,
Check Operation

Initial	Date
GOC	1/9

-Piping, Tank & Valves
Check for Leaks

Initial	Date
GOC	1/9

-Exhaust Fan
Check Operation,
Check "Y" Strainer on HypoTank

Initial	Date
GOC	1/9

Main Floor

-Alarm Panel
Check Operation

Initial	Date
GOC	1/10

Basement

-Sump Pumps
Check Operation

Initial	Date
GOC	1/9

-Bluebird Pumps
Exercise

Initial	Date
GOC	1/9

Wet Well

-Exhaust Fan
Check Operation

Initial	Date
GOC	1/9

-Well
Remove Grease

Initial	Date
GOC	1/10

-Check Oil Level

Initial	Date
GOC	1/10

Grist Mill

Main Floor

-Exhaust Fans
Check Operation

Initial	Date
GOC	1/10

-Alarm Panel
Check Operation

Initial	Date
GOC	1/10

Dry Well

-Check Valves
Exercise

Initial	Date
GOC	1/10

-Sump Pump
Check Operation

Initial	Date
GOC	1/10

-Exhaust Fan
Check Operation

Initial	Date
GOC	1/10

Wet Well

-Exhaust Fan

Initial	Date
GOC	1/10

Greenleaf Hill

Dry Well

-Alarm Panel
Check Operation

Initial	Date
GOC	1/10

-High Level
Tank Alarms
Check Operation

Initial	Date
GOC	1/10

-Exhaust Fans
Check Operation

Initial	Date
GOC	1/10

Sump Pump #1

Initial	Date
GOC	1/10

Sump Pump #2

Initial	Date
GOC	1/10

Start Cycles #1

Initial	Date
GOC	1/10

Star Cycles #2

Initial	Date
GOC	1/10

Electric Grinder
Reading

--

① setting up schedule for testing alarms on monthly basis,

③ FAN FROZEN NEED TO REPLACE MOTOR

② removing grease the week of the 14TH

④ HAVE TO CLEAN OUT PIT AROUND PUMP (ROBRIS?)