



# ✓ Pump Stations Monthly PMs

Month of: December

## Manhasset Valley ✓

### Main Floor

-Exhaust Air Louver's  
Check Operation

Initial	Date
VZ	12/5

-Fresh Air Louver's  
Check Operation

Initial	Date
VZ	12/5

-Alarms  
Check Operation

Initial	Date

### Dry Well

-Sump Pumps  
Check Operation

Initial	Date
VZ	12/5

-Exhaust Fans  
Check Operation

Initial	Date
VZ	12/5

-"Y" Strainers  
Clean "Y" Strainers

Initial	Date
VZ	12/5

*need to be replaced*

### Wet Well

-Well  
Remove Grease,  
Exercise Splitter Valve

Initial	Date
	<i>Schedule</i>

-Check Oil

Initial	Date
VZ	12/5

-Bypass Channel  
Flush Channel  
Clean Bar Screen

Initial	Date
VZ	12/5

-Exhaust Fans

Check Operation

Initial	Date
VZ	12/5

## Shelter Rock ✓

### Main Floor

-CO2 Tank  
Check Pressure,  
Check for Leaks (950 psi)

Initial	Date
VZ	12/5

-Exhaust Fans  
Check Operation

Initial	Date
VZ	12/5

-Alarm System  
Check Operation

Initial	Date

### Wet Well

-Remove Rags  
and Grease

Initial	Date
	<i>Schedule</i>

## Bayview Pump House ✓

### Main Floor

-Panel Boards  
Check Blower  
Operation

Initial	Date
VZ	12/5

-Exhaust Fans  
Check Operation

Initial	Date
VZ	12/5

-Alarms  
Check Operation  
Check Tank Fill Valve & Operating Pressure

Initial	Date

### Dry Well

-Check Daily Run Time

Initial	Date
VZ	12/5

-Grease Drive Shafts

Initial	Date
VZ	12/5

-Sump Pumps  
Check Operation

Initial	Date
VZ	12/5

-Valves

Exercise

Initial	Date
VZ	12/5

-Solenoid Valves  
Check Operation

Initial	Date
VZ	12/5

-"Y" Strainers  
Clean "Y" Strainers

Initial	Date
VZ	12/5

*wmm*



# Pump Stations Monthly PMs

Month of: December

## Bayview Main Building

### Roof ✓

-Exhaust Fans  
Check Operation

Initial	Date
VZ	12/5

### Hypo Room

-Hypo Pump  
Check Oil Level,  
Check Operation

Initial	Date
VZ	12/5

-Piping, Tank & Valves  
Check for Leaks

Initial	Date
VZ	12/5

-Exhaust Fan  
Check Operation,  
Check "Y" Strainer on HypoTank

Initial	Date
VZ	12/5

### Basement ✓

-Sump Pumps  
Check Operation

Initial	Date
VZ	12/5

-Bluebird Pumps  
Exercise

Initial	Date
VZ	12/1

### Wet Well

-Exhaust Fan  
Check Operation

Initial	Date
VZ	12/5

-Well  
Remove Grease

Initial	Date

*Schedule*

-Check Oil Level

Initial	Date
VZ	12/5

### Grist Mill ✓

### Main Floor

-Exhaust Fans  
Check Operation

Initial	Date
VZ	12/5

-Alarm Panel  
Check Operation

Initial	Date

### Dry Well

-Check Valves  
Exercise

Initial	Date
VZ	12/5

-Sump Pump  
Check Operation

Initial	Date
VZ	12/5

-Exhaust Fan  
Check Operation

Initial	Date
VZ	12/5

### Wet Well

-Exhaust Fan

Initial	Date
VZ	12/5

## Greenleaf Hill ✓

### Dry Well

-Alarm Panel  
Check Operation

Initial	Date

-High Level  
Tank Alarms  
Check Operation

Initial	Date

-Exhaust Fans  
Check Operation

Initial	Date
VZ	12/5

-Sump Pump #1

Initial	Date
VZ	142.3

12/5

-Sump Pump #2

Initial	Date
VZ	3.6

-Start Cycles #1

Initial	Date
VZ	7410

12/5

-Start Cycles #2

Initial	Date
VZ	6542

12/5

-Electric Grinder  
Reading

Initial	Date
VZ	104326

12/5

-"Y" Strainers  
Clean "Y" Strainers

Initial	Date
VZ	12/5

*Needs Replacement due to age*

-Force Main Bypass

Check Valve  
Check operation of  
valves and grease as necessary

Initial	Date
VZ	12/5