



Pump Stations Monthly PMs

Month of: September

Manhasset Valley ✓

Main Floor

-Exhaust Air Louver's
Check Operation

Initial	Date
VZ	9/15

-Fresh Air Louver's
Check Operation

Initial	Date
VZ	9/15

-Alarms
Check Operation

Initial	Date

Dry Well

-Sump Pumps
Check Operation

Initial	Date
VZ	9/15

-Exhaust Fans
Check Operation

Initial	Date
VZ	9/19

②
-"Y" Strainers
Clean "Y" Strainers

Initial	Date
VZ	9/19

Wet Well

-Well
Remove Grease,
Exercise Splitter Valve

Initial	Date
	Schedule

-Check Oil

Initial	Date
VZ	9/19

-Bypass Channel
Flush Channel
Clean Bar Screen

Initial	Date
VZ	9/15

-Exhaust Fans
Check Operation

Initial	Date
VZ	9/19

② W-3 Fan timer stuck
W-2 Fan tripping off -

Shelter Rock ✓

Main Floor

-CO2 Tank
Check Pressure,
Check for Leaks (950 psi)

Initial	Date
VZ	9/5

-Exhaust Fans
Check Operation

Initial	Date
VZ	9/5

-Alarm System
Check Operation

Initial	Date

Wet Well

-Remove Rags
and Grease

Initial	Date
	Schedule

③ Replace Wye Strainer
-"Y" Strainers
Clean "Y" Strainers

Initial	Date
VZ	①

① No Wye Strainer

Bayview Pump House ✓

Main Floor

-Panel Boards
Check Blower
Operation

Initial	Date
VZ	9/19

-Exhaust Fans
Check Operation

Initial	Date
VZ	9/19

-Alarms
Check Operation
Check Tank Fill Valve & Operating Pressure

Initial	Date
VZ	9/19

Dry Well

-Check Daily Run Time

Initial	Date
VZ	9/19

-Grease Drive Shafts

Initial	Date
VZ	9/19

-Sump Pumps
Check Operation

Initial	Date
VZ	9/19

-Valves
Exercise

Initial	Date
VZ	9/19

-Solenoid Valves
Check Operation

Initial	Date
VZ	9/19

-"Y" Strainers
Clean "Y" Strainers

Initial	Date

M



Pump Stations Monthly PMs

Month of September

Bayview Main Building ✓

Roof

-Exhaust Fans
Check Operation

Initial	Date
VZ	9/19

Hypo Room

-Hypo Pump
Check Oil Level,
Check Operation

Initial	Date
VZ	9/19

-Piping, Tank & Valves
Check for Leaks

Initial	Date
VZ	9/19

-Exhaust Fan
Check Operation,
Check "Y" Strainer on Hypo Tank

Initial	Date
VZ	9/19

Main Floor

-Alarm Panel
Check Operation

Initial	Date

delete

Basement

-Sump Pumps
Check Operation

Initial	Date
VZ	9/15

-Bluebird Pumps
Exercise

Initial	Date
VZ	9/19

-"Y" Strainers
Clean "Y" Strainers

Initial	Date
VZ	9/19

delete

Wet Well

-Exhaust Fan
Check Operation

Initial	Date
VZ	9/19

-Well
Remove Grease

Initial	Date

Schedule

-Check Oil Level

Initial	Date
VZ	9/19

Grist Mill ✓

Main Floor

-Exhaust Fans
Check Operation

Initial	Date
VZ	9/19

-Alarm Panel
Check Operation

Initial	Date

-"Y" Strainers
Clean "Y" Strainers

Initial	Date
VZ	

NO WYE STRAINERS

Dry Well

-Check Valves
Exercise

Initial	Date
VZ	9/19

-Sump Pump
Check Operation

Initial	Date
VZ	9/19

-Exhaust Fan
Check Operation

Initial	Date
VZ	9/19

Wet Well

-Exhaust Fan

Initial	Date
VZ	9/19

Greenleaf Hill ✓

Dry Well

-Alarm Panel
Check Operation

Initial	Date

-High Level
Tank Alarms
Check Operation

Initial	Date

-Exhaust Fans
Check Operation

Initial	Date
VZ	9/15

-Sump Pump #1

Initial	Date
1257	9/5

-Sump Pump #2

Initial	Date
3.6	9/5

-Start Cycles #1

Initial	Date
5696	9/5

-Start Cycles #2

Initial	Date
4476	9/5

-Electric Grinder
Reading

Initial	Date
8247	9/5

-"Y" Strainers
Clean "Y" Strainers

Initial	Date
VZ	9/15

frozen

-Force Main Bypass

Check Valve
Check operation of

Initial	Date
VZ	9/5

valves and grease as necessary

M