



Pump Stations Semi Annual PMs

Semi - Annual Months: July - December 2008

Manhasset Valley

Outside

-Valves (Underground)

Initial	Date
V2	8/25

Exercise

- 2 bypass valves stuck open
 - Valve frame syphon does not seal

Shelter Rock

Main Floor

-Window Air Filter

Initial	Date
V2	8/29

Change Filter

Greenleaf Hill

Dry Well

-Remove Grease

Initial	Date
✓	6/24

-Clean Influent Screens

Initial	Date
V2	12/2

-Valves

Initial	Date
V2	10/21

Muffin Monster

-Tighten Bolts

Initial	Date
V2	11/24

PS - SA

[Handwritten scribbles and signatures]