



# Pump Stations Weekly PMs

Week of: 12/29/08

## Manhasset Valley ✓

### Main Floor

-Diesel Generator Kit  
Check Oil,  
Water, Battery Water

Initial Date  
VZ 12/29

-Exercise Engine a min  
of 30 minutes:  
3x/month w/o load  
1x/month underload

Initial Date  
VZ 12/29  
Start End Hours  
0940 1010 .5

-Panel Board  
Blowers  
Check Operation

Initial Date  
VZ 12/29

### Dry Well

-Air Compressors  
Drain Water from Tank,  
Check Operation

Initial Date  
VZ 12/29

-Seal Water  
System  
Check Fill Valve, Alternate Lead Pump,  
Check Operation (42 PSI)

Initial Date  
VZ 12/29

#2 Pump motor  
not working

### Wet Well

-Comminutor  
Check Operation

Initial Date  
VZ 12/29

## Shelter Rock ✓

### Main Floor

-Air Compressors  
Check Operation,  
Drain Water from Tanks

Initial Date  
VZ 12/29

### Dry Well

-Sewer Pumps  
Check Purge Lines

Initial Date  
VZ 12/29

#2 disconnected

-Sump Pump  
Check Operation

Initial Date  
VZ 12/29

### Roof

-Generator Kit  
Check Oil & Water

Initial Date  
VZ 12/29

-Exercise Engine a min  
of 30 minutes:  
3x/month w/o load  
1x/month underload

Initial Date  
VZ 12/29  
Start End Hours  
1020 1040 .35

### Wet Well

-Well  
Check

Initial Date  
VZ 12/29

Schedule training

### Alarms



# Pump Stations Weekly PMs

Week of: 12/29/08

## Bayview Pump House ✓

### Main Floor

#### -Diesel Generator Kit

Check Oil, 

Initial	Date
VL	12/29

  
Check Level in Day Tank

-Exercise Engine a min of 30 minutes:  
3x/month w/o load  
1x/month underload

Initial	Date
VL	12/29

  

Start	End	Hours
1055	1125	.5

### Dry Well

#### -Air Compressors

Drain Water from Tank 

Initial	Date
VL	12/29

#### -Seal Water System

Alternate Lead Pump, 

Initial	Date
VL	12/29

  
Check Tank Fill Valve & Operating Pressure

#### -Sewer Pumps

Check Purge Lines, 

Initial	Date
VL	12/29

  
Check Seal, Water Usage (runs at 25 psi)

*1 Sewer Leaks*

#### -Clear Debris in

Impeller 

Initial	Date
VL	12/29

## Bayview Main Building ✓

### Main Floor

#### -Blue Bird Court Generato

Check Oil and Water, 

Initial	Date
VL	12/29

-Exercise Engine a min of 30 minutes:  
3x/month w/o load  
1x/month underload

Initial	Date
VL	12/29

  

Start	End	Hours
1055	1115	.30

### Basement

#### -Floor Drains

Pump Water 

Initial	Date
VL	12/29

#### -Boiler

Check Operation 

Initial	Date
VL	12/29

  
*boiler off*

#### -Piping

Check for Leaks, 

Initial	Date
VL	12/29

  
Check Seal, Water Usage

### Wet Well

#### -Muffin Monitors

Check Opearation, 

Initial	Date
VL	12/29

  
Clean Debris in Channels



# Pump Stations Weekly PMs

Week of: 12/29/08

## Grist Mill

### Main Floor

-Diesel Generator Kit  
Check Oil & Water,  
Check Battery Water

Initial	Date
V2	12/29

-Exercise Engine a min  
of 30 minutes:  
3x/month w/o load  
1x/month underload

Initial	Date
V2	12/29

  

Start	End	Hours
1055	1125	.5

-Pump Control Panel  
Check Operation

Initial	Date
V2	12/29

### Wet Well

-Comminutor  
Clean Debris in Housing

Initial	Date
V2	12/29

## Greenleaf Hill

### Dry Well

-Generator Kit  
Check Oil & Water,  
Check Battery Water

Initial	Date
V2	12/29

-Exercise Engine a min  
of 30 minutes:  
3x/month w/o load  
1x/month underload

Initial	Date
V2	12/29

  

Start	End	Hours
1310	1330	.35

-Sump Pump  
Check Operation

Initial	Date
V2	12/29