



Pump Stations Monthly PMs

Month of: January 2009

Manhasset Valley ✓

Main Floor

-Exhaust Air Louver's

Initial Date

vr 1/23

Check Operation

-Fresh Air Louver's

Initial Date

vr 1/23

Check Operation

-Alarms

Initial Date

Check Operation

Dry Well

-Sump Pumps

Initial Date

vr 1/23

Check Operation

-Exhaust Fans

Initial Date

vr 1/12

Check Operation

-"Y" Strainers

Initial Date

vr 1/12

Clean "Y" Strainers

Wet Well

-Well

Initial Date

vr 1/12

Remove Grease,
Exercise Splitter Valve

Schedule Cleanings

-Check Oil

Initial Date

vr 1/12

-Bypass Channel

Initial Date

vr 1/12

Flush Channel
Clean Bar Screen

-Exhaust Fans

Initial Date

vr 1/12

Check Operation

Shelter Rock ✓

Main Floor

-CO2 Tank

Initial Date

vr 1/16

Check Pressure,
Check for Leaks (950 psi)

-Exhaust Fans

Initial Date

vr 1/16

Check Operation

-Alarm System

Initial Date

Check Operation

Wet Well

-Remove Rags

Initial Date

vr 1/16

and Grease

Bayview Pump House ✓

Main Floor

-Panel Boards

Initial Date

vr 1/15

Check Blower
Operation

-Exhaust Fans

Initial Date

vr 1/15

Check Operation

-Alarms

Initial Date

vr 1/16

Check Operation
Check Tank Fill Valve & Operating Pressure

Dry Well

-Check Daily Run Time

Initial Date

vr 1/15

-Valves

Initial Date

vr 1/16

Exercise

-Grease Drive Shafts

Initial Date

vr 1/15

-Sump Pumps

Initial Date

vr 1/15

Check Operation

-Solenoid Valves

Initial Date

vr 1/16

Check Operation

-"Y" Strainers

Initial Date

vr 1/16

Clean "Y" Strainers



Pump Stations Monthly PMs

January 2009

Bayview Main Building ✓

Roof

-Exhaust Fans

Initial	Date
VR	1/16

Check Operation

Hypo Room

-Hypo Pump

Initial	Date
VR	1/5

Check Oil Level,
Check Operation

-Piping, Tank & Valves

Initial	Date
VR	1/13

Check for Leaks

-Exhaust Fan

Initial	Date
VR	1/5

Check Operation,
Check "Y" Strainer on Hypo Tank

Basement

-Sump Pumps

Initial	Date
VR	1/13

Check Operation

-Bluebird Pumps

Initial	Date
VR	1/20

Exercise

Wet Well

-Exhaust Fan

Initial	Date
VR	1/20

Check Operation

-Well

Initial	Date
VR	1/20

Remove Grease

Check Oil Level

Initial	Date

Schedule Cleanings

*No delete
Levels to
check in
Wet Well*

Grist Mill ✓

Main Floor

-Exhaust Fans

Initial	Date
VR	1/20

Check Operation

-Alarm Panel

Initial	Date

Check Operation

Dry Well

-Check Valves

Initial	Date
VR	1/23

Exercise

-Sump Pump

Initial	Date
VR	1/23

Check Operation

-Exhaust Fan

Initial	Date
VR	1/23

Check Operation

Wet Well

-Exhaust Fan

Initial	Date
VR	1/23

Greenleaf Hill ✓

Dry Well

-Alarm Panel

Initial	Date

Check Operation

-High Level

Initial	Date
VR	1/20

Tank Alarms
Check Operation

-Exhaust Fans

Initial	Date
VR	1/12

Check Operation

-Sump Pump #1

Initial	Date
VR	1/12
Reading	1460

-Sump Pump #2

Initial	Date
VR	1/12
Reading	3.6

-Start Cycles #1

Initial	Date
VR	1/12
Reading	8477

-Start Cycles #2

Initial	Date
VR	1/12
Reading	8150

-Electric Grinder

Initial	Date
VR	1/12
Reading	11344.8

-"Y" Strainers

Initial	Date
VR	1/12

Clean "Y" Strainers

-Force Main Bypass

Initial	Date
VR	1/23

Check Valve

Check operation of
valves and grease as necessary