



Pump Stations Monthly PMs

Month of: December 2009 ✓

Manhasset Valley

Main Floor

<u>-Exhaust Air Louver's</u>	Initial	Date	<u>-Fresh Air Louver's</u>	Initial	Date	<u>-Alarms</u>	Initial	Date
Check Operation	V2	12/4	Check Operation	V2	12/4	Check Operation		

Dry Well

<u>-Sump Pumps</u>	Initial	Date	<u>-Exhaust Fans</u>	Initial	Date	<u>-"Y" Strainers</u>	Initial	Date
Check Operation	V2	12/4	Check Operation	V2	12/4	Clean "Y" Strainers	V2	12/4

Wet Well

<u>-Well</u>	Initial	Date	<u>-Check Oil</u>	Initial	Date	<u>-Bypass Channel</u>	Initial	Date
Remove Grease, Exercise Splitter Valve	V2	12/11		V2	12/7	Flush Channel Clean Bar Screen	V2	12/4

Schedule water

<u>-Exhaust Fans</u>	Initial	Date
Check Operation	V2	12/4

Shelter Rock

Main Floor

<u>-CO2 Tank</u>	Initial	Date	<u>-Exhaust Fans</u>	Initial	Date	<u>-Alarm System</u>	Initial	Date
Check Pressure, Check for Leaks (950 psi)	V2	12/4	Check Operation	V2	12/4	Check Operation		

Wet Well

<u>-Remove Rags and Grease</u>	Initial	Date						
	V2	12/11						

Schedule water

Water - 2515.4 gallons 12/30
GAJ - 7600 ft³ 12/30

Bayview Pump House

Main Floor

<u>-Panel Boards</u>	Initial	Date	<u>-Exhaust Fans</u>	Initial	Date	<u>-Alarms</u>	Initial	Date
Check Blower Operation	V2	12/11	Check Operation	V2	12/11	Check Operation Check Tank Fill Valve & Operating Pressure	V2	12/11

Dry Well

<u>-Check Daily Run Time</u>	Initial	Date	<u>-Grease Drive Shafts</u>	Initial	Date	<u>-Sump Pumps</u>	Initial	Date
	V2	12/11		V2	12/11	Check Operation	V2	12/11

<u>-Valves Exercise</u>	Initial	Date	<u>-Solenoid Valves</u>	Initial	Date	<u>-"Y" Strainers</u>	Initial	Date
	V2	12/11	Check Operation	V2	12/11	Clean "Y" Strainers	V2	12/11



Pump Stations Monthly PMs

December 2009

Bayview Main Building ✓

Roof

-Exhaust Fans

Initial	Date
VZ	12/18

Check Operation

Hypo Room

-Hypo Pump

Initial	Date
VZ	12/18

Check Oil Level,
Check Operation

-Piping, Tank & Valves

Initial	Date
VZ	12/18

Check for Leaks

-Exhaust Fan

Initial	Date
VZ	12/18

Check Operation,
Check "Y" Strainer on HypoTank

Basement

-Sump Pumps

Initial	Date
VZ	12/18

Check Operation

-Bluebird Pumps

Initial	Date
VZ	12/18

Exercise

Wet Well

-Exhaust Fan

Initial	Date
VZ	12/18

Check Operation

-Well

Initial	Date
VZ	12/18

Remove Grease

Schedule reaction

Grist Mill ✓

Main Floor

-Exhaust Fans

Initial	Date
VZ	12/18

Check Operation

-Alarm Panel

Initial	Date

Check Operation

Dry Well

-Check Valves

Initial	Date
VZ	12/18

Exercise

-Sump Pump

Initial	Date
VZ	12/18

Check Operation

-Exhaust Fan

Initial	Date
VZ	12/18

Check Operation

Wet Well

-Exhaust Fan

Initial	Date
VZ	12/18

Greenleaf Hill ✓

Dry Well

-Alarm Panel

Initial	Date
VZ	12/14

Check Operation

-High Level

Initial	Date

Tank Alarms
Check Operation

-Exhaust Fans

Initial	Date
VZ	12/14

Check Operation

-Sump Pump #1

Initial	Date
VZ	12/14
Reading	176.3

-Sump Pump #2

Initial	Date
VZ	12/14
Reading	3.6

-Start Cycles #1

Initial	Date
VZ	12/14
Reading	17709

-Start Cycles #2

Initial	Date
VZ	12/14
Reading	19848

-Electric Grinder

Initial	Date
VZ	12/14
Reading	17934.5

-"Y" Strainers

Initial	Date
VZ	12/14

Clean "Y" Strainers

-Force Main Bypass

Initial	Date
VZ	12/14

Check Valve
Check operation of
valves and grease as necessary