



Pump Stations Monthly PMs

Month of: September 2009

Manhasset Valley ✓

Main Floor

-Exhaust Air Louver's

Initial	Date
VR	9/14

Check Operation

-Fresh Air Louver's

Initial	Date
VR	9/14

Check Operation

-Alarms

Initial	Date

Check Operation

Dry Well

-Sump Pumps

Initial	Date
VR	9/14

Check Operation

-Exhaust Fans

Initial	Date
VR	9/14

Check Operation

-"Y" Strainers

Initial	Date
VR	9/14

Clean "Y" Strainers

Wet Well

-Well

Initial	Date
VR	9/14

Remove Grease,
Exercise Splitter Valve

-Check Oil

Initial	Date
VR	9/14

-Bypass Channel

Initial	Date
VR	9/14

Flush Channel
Clean Bar Screen

-Exhaust Fans

Initial	Date
VR	9/14

Check Operation

Schedule vacation

Shelter Rock ✓

Main Floor

-CO2 Tank

Initial	Date
VR	9/14

Check Pressure,
Check for Leaks (950 psi)

-Exhaust Fans

Initial	Date
VR	9/14

Check Operation

-Alarm System

Initial	Date

Check Operation

Wet Well

-Remove Raqs

Initial	Date
VR	9/14

and Grease

Schedule vacation

Bayview Pump House ✓

Main Floor

-Panel Boards

Initial	Date
VR	9/11

Check Blower
Operation

-Exhaust Fans

Initial	Date
VR	9/11

Check Operation

-Alarms

Initial	Date
VR	9/13

Check Operation
Check Tank Fill Valve & Operating Pressure

Dry Well

-Check Daily Run Time

Initial	Date
VR	9/11

-Grease Drive Shafts

Initial	Date
VR	9/11

-Sump Pumps

Initial	Date
VR	9/13

Check Operation

-Valves

Initial	Date
VR	9/13

Exercise

-Solenoid Valves

Initial	Date
VR	9/13

Check Operation

-"Y" Strainers

Initial	Date
VR	9/13

Clean "Y" Strainers



Pump Stations Monthly PMs

September 2009

Bayview Main Building ✓

Roof

-Exhaust Fans

Check Operation

Initial	Date
VR	9/10

Hypo Room

-Hypo Pump

Check Oil Level,
Check Operation

Initial	Date
VR	9/18

-Piping, Tank & Valves

Check for Leaks

Initial	Date
VR	9/18

-Exhaust Fan

Check Operation,
Check "Y" Strainer on HypoTank

Initial	Date
VR	9/18

Basement

-Sump Pumps

Check Operation

Initial	Date
VR	9/18

-Bluebird Pumps

Exercise

Initial	Date
VR	9/18

Wet Well

-Exhaust Fan

Check Operation

Initial	Date
VR	9/18

-Well

Remove Grease

Initial	Date
VR	9/18

Schedule notes

Grist Mill ✓

Main Floor

-Exhaust Fans

Check Operation

Initial	Date
VR	9/11

-Alarm Panel

Check Operation

Initial	Date

Dry Well

-Check Valves

Exercise

Initial	Date
VR	9/11

-Sump Pump

Check Operation

Initial	Date
VR	9/11

-Exhaust Fan

Check Operation

Initial	Date
VR	9/11

Wet Well

-Exhaust Fan

Initial	Date
VR	9/11

Greenleaf Hill ✓

Dry Well

-Alarm Panel

Check Operation

Initial	Date

-High Level

Tank Alarms
Check Operation

Initial	Date

-Exhaust Fans

Check Operation

Initial	Date
VR	9/14

-Sump Pump #1

Initial	Date
VR	9/14
Reading	175.6

-Sump Pump #2

Initial	Date
VR	9/14
Reading	3.6

-Start Cycles #1

Initial	Date
VR	9/14
Reading	15340

-Start Cycles #2

Initial	Date
VR	9/14
Reading	16893

-Electric Grinder

Reading

Initial	Date
VR	9/14
Reading	16983.8

-"Y" Strainers

Clean "Y" Strainers

Initial	Date
VR	9/14

-Force Main Bypass

Check Valve

Check operation of
valves and grease as necessary

Initial	Date
VR	9/14