



Pump Stations Multi-Yearred PMs

Multi Yearred for: 2009

Shelter Rock ✓

Wet Well

Sewer Pump #1

-Change Oil

Use Hyvolt II

Previous :

4/2007

Initial	Date		Reading
	Performed		
v2	4/22		7315.6
Due			
4/2009			

Sewer Pump #2

-Change Oil

Use Hyvolt II

Previous :

4/2007

Initial	Date		Reading
	Performed		
v2	4/20		6738.9
Due			
4/2009			

Bayview Pump House ✓

Main Floor

Pump Motor #1

-Grease Bearings

Change oil

Previous :

11/2008

Initial	Date		Reading
	Performed		
X	X		X
Due			
11/2010			

Pump Motor #2

-Grease Bearings

Change oil

Previous :

11/2008

Initial	Date		Reading
	Performed		
X	X		X
Due			
11/2010			

Pump Motor #3

-Grease Bearings

Change oil

Previous :

11/2008

Initial	Date		Reading
	Performed		
X	X		X
Due			
11/2010			

change to yearly

Grist Mill Pump Station ✓

Dry Well

Sewer Pump #1

-Change Oil

Use Hyvolt II

Previous :

2/2008

Initial	Date		Reading
	Performed		
X	X		X
Due			
2/2010			

Sewer Pump #2

-Change Oil

Use Hyvolt II

Previous :

2/2008

Initial	Date		Reading
	Performed		
X	X		X
Due			
2/2010			