



# Pump Stations Quarterly PMs

Quarter: 4 2009

## Manhasset Valley ✓

### Main Floor

-Diesel Generator Kit

Clean Battery Terminals

Initial Date  
VZ 10/19

-Panel Board

Blowers  
Change Filter

Initial Date  
VZ 12/14

### Dry Well

-Valves

Exercise

Initial Date  
VZ 11/16

-Pumps & Check Valves

Inspect Pump Housing  
Make Sure to Clean

Initial Date  
VZ 12/14 (1)

-Pumps & Check Valves

Inspect Check Valve  
Operation

Initial Date  
VZ 12/14 (1)

### Wet Well

-Sluice Gates

Exercise,

Clean Threads (Every 3 Months)

Initial Date  
VZ 11/19

## Shelter Rock ✓

### Dry Well

-Valves

Exercise

Initial Date  
VZ 11/24

-Pumps & Check Valves

Inspect Pump Housing  
Make Sure to Clean

Initial Date  
VZ 12/14 (1)

-Pumps & Check Valves

Inspect Check Valves  
Make Sure to Clean

Initial Date  
VZ 12/14 (1)

### Roof

-Clean Battery Terminals

Initial Date  
VZ 11/20

## Bayview Pump House ✓

### Main Floor

-Diesel Generator Kit

Clean Battery Terminals

Initial Date  
VZ 10/30

-Reverse or Change

Filters

Initial Date  
VZ 10/20

### Dry Well

-Pumps & Check Valves

Inspect Pump Housing  
Make Sure to Clean

Initial Date  
VZ 12/14 (1)

-Pumps & Check Valves

Inspect Check Valves  
Make Sure to Clean

Initial Date  
VZ 12/14 (1)

-Adjust Impeller #1

Clearance

Initial Date  
VZ 10/30

-Adjust Impeller #2

Clearance

Initial Date  
VZ 10/30

-Adjust Impeller #3

Clearance

Initial Date  
VZ 10/30

(1) Pumps and checks in working order



# Pump Stations Quarterly PMs

Q 4 2009

## Bayview Main House ✓

### Wet Well

-Well

Exercise Gate Valves

Initial	Date
VZ	11/19

① Splitter valve extension broken

-Pumps & Check Valves

Inspect Pump Housing

Make Sure to Clean

Initial	Date
VZ	12/19

-Pumps & Check Valves

Inspect Check Valves

Make Sure to Clean

Initial	Date
VZ	12/19

### Outside

-Underground Valves

Initial	Date
VZ	12/17

### Bluebird Pumps

-Pumps & Check Valves

Inspect Pump Housing

Make Sure to Clean

Initial	Date
VZ	12/14

-Pumps & Check Valves

Inspect Check Valves

Make Sure to Clean

Initial	Date
VZ	12/14

## Grist Mill ✓

### Dry Well

-Sewer Pumps

Check Oil

Initial	Date
VZ	11/19

### Wet Well

-Valves

Exercise

Initial	Date
VZ	11/19

-Pumps & Check Valves

Inspect Pump Housing

Make Sure to Clean

Initial	Date
VZ	12/14

-Pumps & Check Valves

Inspect Check Valves

Make Sure to Clean

Initial	Date
VZ	12/14

## Greenleaf Hill ✓

-Pull Pumps

and Inspect

Initial	Date
VZ	11/20

⇒

-Debris in the

Impeller?

Yes

No

Date

11/20
-------

-Grease Pump Rails

Initial	Date
VZ	11/20

-Check Oil Level

in Pumps

Initial	Date
VZ	11/20

② Pumps and Checkvalves in working order