



Pump Stations Semi Annual PMs

Semi - Annual Months: July - December 2009

Manhasset Valley

Outside

-Valves (Underground)

Initial	Date
vr	11/19

2 - valves stuck open
1 - valve not sealing

Exercise

Bayview Pump House

Wet Well

-Muffin Monitors

#1	
Initial	Date
vr	11/20 ①

-Muffin Monitors

#2	
Initial	Date
vr	11/20

Adjust Cutters

-Muffin Monitors

Adjust Cutters

#3	
Initial	Date
	

delete

① cutters worn

Greenleaf Hill ✓

Dry Well

-Remove Grease

Initial	Date
vr	11/20

-Clean Influent

Initial	Date
vr	11/20

Screens

-Valves

Initial	Date
vr	11/20

Muffin Monster

-Tighten Bolts

Initial	Date
vr	11/20