



Pump Stations Weekly PMs

Week of: 01/05/09

Manhasset Valley

Main Floor

-Diesel Generator Kit

Check Oil,
Water, Battery Water

Initial Date
V2 1/5

-Exercise Engine a min
of 30 minutes:
3x/month w/o load
1x/month underload

Initial Date
V2 1/5
Start End Hours
9:30 9:00 .5

-Panel Board

Blowers
Check Operation

Initial Date
V2 1/5

Dry Well

-Air Compressors

Drain Water from Tank,
Check Operation

Initial Date
V2 1/5

-Seal Water System

Check Fill Valve, Alternate Lead Pump,
Check Operation (42 PSI)

Initial Date
V2 1/5

Wet Well

-Comminutor

Check Operation

Initial Date
V2 1/5

Shelter Rock

Main Floor

-Air Compressors

Check Operation,
Drain Water from Tanks

Initial Date
V2 1/5

Dry Well

-Sewer Pumps

Check Purge Lines

Initial Date
V2 1/5

-Sump Pumps

Check Operation

Initial Date
V2 1/5

Roof

-Generator Kit

Check Oil & Water

Initial Date
V2 1/5

-Exercise Engine a min
of 30 minutes:
3x/month w/o load
1x/month underload

Initial Date
V2 1/5
Start End Hours
09:15 09:30 .35

Wet Well

-Well

Check

Initial Date
V2 1/5



Pump Stations Weekly PMs

Week of: 01/05/09

Bayview Pump House

Main Floor

-Diesel Generator Kit

Check Oil,

Check Level in Day Tank

Initial Date
V2 1/5

-Exercise Engine a min
of 30 minutes:

3x/month w/o load

1x/month underload

Initial Date
V2 1/5

Start End Hours
10:45 11:15 .5

Dry Well

-Air Compressors

Drain Water from Tank

Initial Date
V2 1/5

-Seal Water System

Alternate Lead Pump,

Check Tank Fill Valve & Operating Pressure

Initial Date
V2 1/5

-Sewer Pumps

Check Purge Lines,

Check Seal, Water Usage (runs at 25 psi)

Initial Date
V2 1/5

Several Leaks

-Clear Debris in

Impeller

Initial Date
V2 1/5

Bayview Main Building

Main Floor

-Blue Bird Court Generator

Check Oil and Water,

Initial Date
V2 1/5

-Exercise Engine a min
of 30 minutes:

3x/month w/o load

1x/month underload

Initial Date
V2 1/5

Start End Hours
10:10 11:10 .35

Basement

-Floor Drains

Pump Water

Initial Date
V2 1/5

-Boiler

Check Operation

Initial Date
V2 1/5

boiler off

-Piping

Check for Leaks,

Check Seal, Water Usage

Initial Date
V2 1/5

Wet Well

-Muffin Monitors

Check Operation,

Clean Debris in Channels

Initial Date
V2 1/5



Pump Stations Weekly PMs

Week of: 01/05/09

Grist Mill

Main Floor

-Diesel Generator Kit
Check Oil & Water,
Check Battery Water

Initial	Date
V2	1/5

-Exercise Engine a min
of 30 minutes:
3x/month w/o load
1x/month underload

Initial	Date	
V2	1/5	
Start	End	Hours
200	230	15

-Pump Control Panel
Check Operation

Initial	Date
V2	1/5

Wet Well

-Comminutor
Clean Debris in Housing

Initial	Date
V2	1/5

Greenleaf Hill

Dry Well

-Generator Kit
Check Oil & Water,
Check Battery Water

Initial	Date
V2	1/5

-Exercise Engine a min
of 30 minutes:
3x/month w/o load
1x/month underload

Initial	Date	
V2	1/5	
Start	End	Hours
1220	1330	135

-Sump Pump
Check Operation

Initial	Date
V2	1/5