



Pump Stations Weekly PMs

Week of: 01/12/09

Manhasset Valley ✓

Main Floor

-Diesel Generator Kit
Check Oil,
Water, Battery Water

Initial Date
JL 1/12

-Exercise Engine a min
of 30 minutes:
3x/month w/o load
1x/month underload

Initial Date
JL 1/12
Start End Hours
0854 10

-Panel Board
Blowers
Check Operation

Initial Date
[] []

Dry Well

-Air Compressors
Drain Water from Tank,
Check Operation

Initial Date
JL 1/12

-Seal Water
System
Check Fill Valve, Alternate Lead Pump,
Check Operation (42 PSI)

Initial Date
JL 1/12

① ENGINE SHUT OFF ON LOW OIL PRESSURE
CALLED - ON CALL
Ran engine 1/13 - 20 minutes

Wet Well

-Comminutor
Check Operation

Initial Date
JL 1/12

Shelter Rock V

Main Floor

-Air Compressors
Check Operation,
Drain Water from Tanks

Initial Date
JL 1/12

Dry Well

-Sewer Pumps
Check Purge Lines

Initial Date
JL 1/12

-Sump Pumps
Check Operation

Initial Date
JL 1/12

#2 disconnected

Roof

-Generator Kit
Check Oil & Water

Initial Date
JL 1/12

-Exercise Engine a min
of 30 minutes:
3x/month w/o load
1x/month underload

Initial Date
JL 1/12
Start End Hours
0940 1000 .35

Wet Well

-Well
Check

Initial Date
JL 1/12

needs cleaning



Pump Stations Weekly PMs

Week of: 01/12/09

Bayview Pump House ✓

Main Floor

-Diesel Generator Kit

Check Oil,
Check Level in Day Tank

Initial Date
V2 1/13

-Exercise Engine a min
of 30 minutes:
3x/month w/o load
1x/month underload

Initial Date
V2 1/13
Start End Hours
9:35 10:05 .5

Dry Well

-Air Compressors

Drain Water from Tank

Initial Date
V2 1/12

-Seal Water System
Alternate Lead Pump,
Check Tank Fill Valve & Operating Pressure

Initial Date
V2 1/12

-Sewer Pumps

Check Purge Lines,
Check Seal, Water Usage (runs at 25 psi)

Initial Date
V2 1/12

Several Leaks

-Clear Debris in

Impeller

Initial Date
V2 1/13

Bayview Main Building ✓

Main Floor

-Blue Bird Court Generator

Check Oil and Water,

Initial Date
V2 1/13

-Exercise Engine a min
of 30 minutes:
3x/month w/o load
1x/month underload

Initial Date
V2 1/13
Start End Hours
09:40 10:00 .33

Basement

-Floor Drains

Pump Water

Initial Date
V2 1/13

-Boiler

Check Operation

Initial Date
V2 1/13
off

-Piping

Check for Leaks,

Check Seal, Water Usage

Initial Date
V2 1/13

Wet Well

-Muffin Monitors

Check Operation,

Clean Debris in Channels

Initial Date
V2 1/12

W



Pump Stations Weekly PMs

Week of: 01/12/09

Grist Mill ✓

Main Floor

-Diesel Generator Kit
Check Oil & Water,
Check Battery Water

Initial Date
V2 1/12

-Exercise Engine a min
of 30 minutes:
3x/month w/o load
1x/month underload

Initial Date
V2 1/12
Start End Hours
1020 1050 .35

-Pump Control Panel
Check Operation

Initial Date
V2 1/12

Wet Well

-Comminutor
Clean Debris in Housing

Initial Date
V2 1/12

Greenleaf Hill ✓

Dry Well

-Generator Kit
Check Oil & Water,
Check Battery Water

Initial Date
V2 1/12

-Exercise Engine a min
of 30 minutes:
3x/month w/o load
1x/month underload

Initial Date
V2 1/12
Start End Hours
1310 1330 .35

-Sump Pump
Check Operation

Initial Date
V2 1/12

W