



# Pump Stations Weekly PMs

Week of: 1/19/09 - 1/23/09

## Manhasset Valley ✓

### Main Floor

#### -Diesel Generator Kit

Check Oil,  
Water, Battery Water

Initial Date  
VZ 1/20

#### -Exercise Engine a min

of 30 minutes:  
3x/month w/o load

Initial Date  
VZ 1/20

Start End Hours  
0830 0900 .5

1x/month underload

#### -Panel Board

Blowers  
Check Operation

Initial Date  
VZ 1/20

### Dry Well

#### -Air Compressors

Drain Water from Tank,  
Check Operation

Initial Date  
VZ 1/20

#### -Seal Water

#### System

Check Fill Valve, Alternate Lead Pump,  
Check Operation (42 PSI)

Initial Date  
VZ 1/20

### Wet Well

#### -Comminutor

Check Operation

Initial Date  
VZ 1/20

## Shelter Rock ✓

### Main Floor

#### -Air Compressors

Check Operation,  
Drain Water from Tanks

Initial Date  
VZ 1/20

### Dry Well

#### -Sewer Pumps

Check Purge Lines

Initial Date  
VZ 1/20

#### -Sump Pumps

Check Operation

Initial Date  
VZ 1/20

### Roof

#### -Generator Kit

Check Oil & Water

Initial Date  
VZ 1/20

#### -Exercise Engine a min

of 30 minutes:  
3x/month w/o load

Initial Date  
VZ 1/20

Start End Hours  
0915 0925 .35

1x/month underload

### Wet Well

#### -Well

Check

Initial Date  
VZ 1/20

Schedule Cleanings



# Pump Stations Weekly PMs

1/19/09 - 1/23/09

## Bayview Pump House ✓

### Main Floor

-Diesel Generator Kit

Check Oil,  
Check Level in Day Tank

Initial Date  
VZ 1/20

-Exercise Engine a min  
of 30 minutes:  
3x/month w/o load  
1x/month underload

Initial Date  
VZ 1/20  
Start End Hours  
1045 1115 .5

### Dry Well

-Air Compressors

Drain Water from Tank

Initial Date  
VZ 1/20

-Seal Water System

Alternate Lead Pump,  
Check Tank Fill Valve & Operating Pressure

Initial Date  
VZ 1/20

-Sewer Pumps

Check Purge Lines,  
Check Seal, Water Usage (runs at 25 psi)

Initial Date  
VZ 1/20

Several Leaks

-Clear Debris in

Impeller

Initial Date  
VZ 1/20

## Bayview Main Building ✓

### Main Floor

-Blue Bird Court Generator

Check Oil and Water,

Initial Date  
VZ 1/20

-Exercise Engine a min  
of 30 minutes:  
3x/month w/o load  
1x/month underload

Initial Date  
VZ 1/20  
Start End Hours  
1055 1115 .33

### Basement

-Floor Drains

Pump Water

Initial Date  
VZ 1/20

-Boiler

Check Operation

Initial Date  
VZ 1/20

boiler off

-Piping

Check for Leaks,  
Check Seal, Water Usage

Initial Date  
VZ 1/20

### Wet Well

-Muffin Monitors

Check Operation,  
Clean Debris in Channels

Initial Date  
VZ 1/20



# Pump Stations Weekly PMs

1/19/09 - 1/23/09

## Grist Mill ✓

### Main Floor

-Diesel Generator Kit

Check Oil & Water,  
Check Battery Water

Initial	Date
VZ	1/20

-Exercise Engine a min  
of 30 minutes:  
3x/month w/o load  
1x/month underload

Initial	Date
VZ	1/20

  

Start	End	Hours
1300	1315	.25

-Pump Control Panel  
Check Operation

Initial	Date
VZ	1/20

### Wet Well

-Comminutor

Clean Debris in Housing

Initial	Date
VZ	1/20

---

## Greenleaf Hill ✓

### Dry Well

-Generator Kit

Check Oil & Water,  
Check Battery Water

Initial	Date
VZ	1/20

-Exercise Engine a min  
of 30 minutes:  
3x/month w/o load  
1x/month underload

Initial	Date
VZ	1/19

  

Start	End	Hours
1310	1330	.33

-Sump Pump  
Check Operation

Initial	Date
VZ	1/20