



# Pump Stations Weekly PMs

Week of: 10/19/09 - 10/23/09

## Manhasset Valley

### Main Floor

#### -Diesel Generator Kit

Check Oil,  
Water, Battery Water

Initial	Date
Bill	10-19

#### -Exercise Engine a min

of 30 minutes:  
3x/month w/o load  
1x/month underload

Initial	Date
Bill	10-19

  

Start	End	Hours
1369	1370	30 min

#### -Panel Board

Blowers  
Check Operation

Initial	Date
Bill	10-19

### Dry Well

#### -Air Compressors

Drain Water from Tank,  
Check Operation

Initial	Date
Bill	10-19

#### -Seal Water

System  
Check Fill Valve, Alternate Lead Pump,  
Check Operation (42 PSI)

Initial	Date
Bill	10-19

### Wet Well

#### -Comminutor

Check Operation

Initial	Date
Bill	10-19

## Shelter Rock

### Main Floor

#### -Air Compressors

Check Operation,  
Drain Water from Tanks

Initial	Date
Bill	10-19

### Dry Well

#### -Sewer Pumps

Check Purge Lines

Initial	Date
Bill	10-19

#### -Sump Pumps

Check Operation

Initial	Date
Bill	10-19

### Roof

#### -Generator Kit

Check Oil & Water

Initial	Date
Bill	10-19

#### -Exercise Engine a min

of 30 minutes:  
3x/month w/o load  
1x/month underload

Initial	Date
Bill	10-19

  

Start	End	Hours
3170	3172	

### Wet Well

#### -Well

Check

Initial	Date
Bill	10-19



# Pump Stations Weekly PMs

10/19/09 - 10/23/09

## Bayview Pump House

### Main Floor

-Diesel Generator Kit

Initial Date

B:11 10.19

Check Oil,  
Check Level in Day Tank

-Exercise Engine a min

Initial Date

B:11 10.19

of 30 minutes:  
3x/month w/o load

Start End Hours  
876.1 876.9 40min

1x/month underload

### Dry Well

-Air Compressors

Initial Date

B:11 10.19

Drain Water from Tank

-Seal Water System

Initial Date

B:11 10.19

Alternate Lead Pump,  
Check Tank Fill Valve & Operating Pressure

-Sewer Pumps

Initial Date

B:11 10.19

Check Purge Lines,  
Check Seal, Water Usage (runs at 25 psi)

-Clear Debris in

Initial Date

B:11 10.19

Impellers

## Bayview Main Building

### Main Floor

-Blue Bird Court Generator

Initial Date

B:11 10.19

Check Oil and Water,

-Exercise Engine a min

Initial Date

B:11 10.19

of 30 minutes:

Start End Hours  
639.8 640.2 30min

3x/month w/o load

1x/month underload

### Basement

-Floor Drains

Initial Date

B:11 10.19

Pump Water

-Boiler

Initial Date

B:11 10.19

Check Operation

-Piping

Initial Date

B:11 10.19

Check for Leaks,  
Check Seal, Water Usage

### Wet Well

-Muffin Monitors

Initial Date

B:11 10.19

Check Operation,  
Clean Debris in Channels



# Pump Stations Weekly PMs

10/19/09 - 10/23/09

## Grist Mill

### Main Floor

-Diesel Generator Kit

Check Oil & Water,  
Check Battery Water

Initial Date  
Bill 10-19

-Exercise Engine a min  
of 30 minutes:  
3x/month w/o load  
1x/month underload

Initial Date  
Bill 10-19  
Start End Hours  
1028.7 1029.4 35min

-Pump Control Panel

Check Operation

Initial Date  
Bill 10-19

### Wet Well

-Comminutor

Clean Debris in Housing

Initial Date  
Bill 10-19

## Greenleaf Hill

### Dry Well

-Generator Kit

Check Oil & Water,  
Check Battery Water

Initial Date  
Bill 10-19

-Exercise Engine a min  
of 30 minutes:  
3x/month w/o load  
1x/month underload

Initial Date  
Bill 10-19  
Start End Hours  
300.0 300.1

-Sump Pump

Check Operation

Initial Date  
Bill 10-19