



# Pump Stations Weekly PMs

Week of: 11/9/09 - 11/13/09

## Manhasset Valley ✓

### Main Floor

#### -Diesel Generator Kit

Check Oil,  
Water, Battery Water

Initial	Date
V2	11/9

-Exercise Engine a min  
of 30 minutes:  
3x/month w/o load  
1x/month underload

Initial	Date	
V2	11/9	
Start	End	Hours
0900	0930	.5

#### -Panel Board

Blowers  
Check Operation

Initial	Date
V2	11/9

### Dry Well

#### -Air Compressors

Drain Water from Tank,  
Check Operation

Initial	Date
V2	11/9

#### -Seal Water

System  
Check Fill Valve, Alternate Lead Pump,  
Check Operation (42 PSI)

Initial	Date
V2	11/9

### Wet Well

#### -Comminutor

Check Operation

Initial	Date
V2	11/9

At----

## Shelter Rock ✓

### Main Floor

#### -Air Compressors

Check Operation,  
Drain Water from Tanks

Initial	Date
V2	11/9

### Dry Well

#### -Sewer Pumps

Check Purge Lines

Initial	Date
V2	11/9

#### -Sump Pumps

Check Operation

Initial	Date
V2	11/9

#2 disconnected

### Roof

#### -Generator Kit

Check Oil & Water

Initial	Date
V2	11/9

#### -Exercise Engine a min

of 30 minutes:  
3x/month w/o load  
1x/month underload

Initial	Date	
V2	11/9	
Start	End	Hours
0945	1005	.33

### Wet Well

#### -Well

Check

Initial	Date
V2	11/9

Schedule visitor



# Pump Stations Weekly PMs

11/9/09 - 11/13/09

## Bayview Pump House ✓

### Main Floor

-Diesel Generator Kit

Check Oil,  
Check Level in Day Tank

Initial	Date
VR	11/9

-Exercise Engine a min

of 30 minutes:  
3x/month w/o load  
1x/month underload

Initial	Date
VR	11/9

Start	End	Hours
1330	1400	.5

### Dry Well

-Air Compressors

Drain Water from Tank

Initial	Date
VR	11/9

-Seal Water System

Alternate Lead Pump,  
Check Tank Fill Valve & Operating Pressure

Initial	Date
VR	11/9

-Sewer Pumps

Check Purge Lines,  
Check Seal, Water Usage (runs at 25 psi)

Initial	Date
VR	11/9

-Clear Debris in

Impellers

Initial	Date
VR	11/9

## Bayview Main Building ✓

### Main Floor

-Blue Bird Court Generator

Check Oil and Water,

Initial	Date
VR	11/9

-Exercise Engine a min

of 30 minutes:  
3x/month w/o load  
1x/month underload

Initial	Date
VR	11/9

Start	End	Hours
1335	1405	.5

### Basement

-Floor Drains

Pump Water

Initial	Date
VR	11/9

-Boiler

Check Operation

Initial	Date
VR	11/9

boiler off line

-Piping

Check for Leaks,  
Check Seal, Water Usage

Initial	Date
VR	11/9

### Wet Well

-Muffin Monitors

Check Operation,  
Clean Debris in Channels

Initial	Date
VR	11/9



# Pump Stations Weekly PMs

11/9/09 - 11/13/09

## Grist Mill ✓

### Main Floor

-Diesel Generator Kit

Check Oil & Water,  
Check Battery Water

Initial	Date
V2	11/9

-Exercise Engine a min  
of 30 minutes:  
3x/month w/o load  
1x/month underload

Initial	Date
V2	10/30

Start	End	Hours
10:30	11:20	.5

-Pump Control Panel

Check Operation

Initial	Date
V2	11/9

### Wet Well

-Comminutor

Clean Debris in Housing

Initial	Date
V2	11/9

## Greenleaf Hill ✓

### Dry Well

-Generator Kit

Check Oil & Water,  
Check Battery Water

Initial	Date
V2	11/9

-Exercise Engine a min  
of 30 minutes:  
3x/month w/o load  
1x/month underload

Initial	Date
V2	11/9

Start	End	Hours
13:00	14:05	.33

-Sump Pump

Check Operation

Initial	Date
V2	11/9