



Pump Stations Weekly PMs

Week of: 11/23/09 - 11/27/09

Manhasset Valley

Main Floor

-Diesel Generator Kit

Check Oil,
Water, Battery Water

Initial Date
VJ 11/23

-Exercise Engine a min
of 30 minutes:
3x/month w/o load
1x/month underload

Initial Date
VJ 11/23
Start End Hours
0845 0915 .5

-Panel Board

Blowers
Check Operation

Initial Date
VJ 11/23

Dry Well

-Air Compressors

Drain Water from Tank,
Check Operation

Initial Date
VJ 11/23

-Seal Water

System
Check Fill Valve, Alternate Lead Pump,
Check Operation (42 PSI)

Initial Date
VJ 11/23

Wet Well

-Comminutor

Check Operation

Initial Date
VJ 11/23

Shelter Rock

Main Floor

-Air Compressors

Check Operation,
Drain Water from Tanks

Initial Date
VJ 11/23

Dry Well

-Sewer Pumps

Check Purge Lines

Initial Date
VJ 11/23

-Sump Pumps

Check Operation

Initial Date
VJ 11/23

Roof

#1 disconnected

-Generator Kit

Check Oil & Water

Initial Date
VJ 11/23

-Exercise Engine a min
of 30 minutes:
3x/month w/o load
1x/month underload

Initial Date
VJ 11/23
Start End Hours
0950 1010 .33

Wet Well

-Well

Check

Initial Date
VJ 11/23



Pump Stations Weekly PMs

11/23/09 - 11/27/09

Bayview Pump House ✓

Main Floor

-Diesel Generator Kit

Check Oil,
Check Level in Day Tank

Initial Date
VZ 11/23

-Exercise Engine a min
of 30 minutes:
3x/month w/o load
1x/month underload

Initial Date
VZ 11/23
Start End Hours
1110 1140 .5

Dry Well

-Air Compressors

Drain Water from Tank

Initial Date
VZ 11/23

-Seal Water System
Alternate Lead Pump,
Check Tank Fill Valve & Operating Pressure

Initial Date
VZ 11/23

-Sewer Pumps

Check Purge Lines,
Check Seal, Water Usage (runs at 25 psi)

Initial Date
VZ 11/23

-Clear Debris in
Impellers

Initial Date
[] []

Bayview Main Building ✓

Main Floor

-Blue Bird Court Generator

Check Oil and Water,

Initial Date
VZ 11/23

-Exercise Engine a min
of 30 minutes:
3x/month w/o load
1x/month underload

Initial Date
VZ 11/23
Start End Hours
1100 1125 .33

Basement

-Floor Drains

Pump Water

Initial Date
VZ 11/23

-Boiler

Check Operation

Initial Date
VZ 11/23

boiler off
line

-Piping

Check for Leaks,
Check Seal, Water Usage

Initial Date
VZ 11/23

Wet Well

-Muffin Monitors

Check Operation,
Clean Debris in Channels

Initial Date
VZ 11/23

#1 off line



Pump Stations Weekly PMs

11/23/09 - 11/27/09

Grist Mill ✓

Main Floor

-Diesel Generator Kit

Check Oil & Water,
Check Battery Water

Initial Date

✓ 11/23

-Exercise Engine a min

of 30 minutes:
3x/month w/o load

1x/month underload

Initial Date

✓ 11/23

Start End Hours

1330 1400 .5

-Pump Control Panel

Check Operation

Initial Date

✓ 11/23

Wet Well

-Comminutor

Clean Debris in Housing

Initial Date

✓ 11/23

Greenleaf Hill ✓

Dry Well

-Generator Kit

Check Oil & Water,
Check Battery Water

Initial Date

✓ 11/23

-Exercise Engine a min

of 30 minutes:
3x/month w/o load

1x/month underload

Initial Date

✓ 11/23

Start End Hours

1320 1340 .33

-Sump Pump

Check Operation

Initial Date

✓ 11/23