



Pump Stations Weekly PMs

Week of: 11/30/09 - 12/04/09

Manhasset Valley ✓

Main Floor

-Diesel Generator Kit
Check Oil,
Water, Battery Water

Initial Date
V2 11/30

-Exercise Engine a min
of 30 minutes:
3x/month w/o load
1x/month underload

Initial Date
V2 11/30
Start End Hours
0800 0920 .5

-Panel Board
Blowers
Check Operation

Initial Date
V2 11/30

Dry Well

-Air Compressors
Drain Water from Tank,
Check Operation

Initial Date
V2 11/20

-Seal Water
System
Check Fill Valve, Alternate Lead Pump,
Check Operation (42 PSI)

Initial Date
V2 11/20

Wet Well

-Comminutor
Check Operation

Initial Date
V2 11/20

Shelter Rock ✓

Main Floor

-Air Compressors
Check Operation,
Drain Water from Tanks

Initial Date
V2 11/30

Dry Well

-Sewer Pumps
Check Purge Lines

Initial Date
V2 11/30

-Sump Pumps
Check Operation

Initial Date
V2 11/30

Roof

-Generator Kit
Check Oil & Water

Initial Date
V2 11/30

-Exercise Engine a min
of 30 minutes:
3x/month w/o load
1x/month underload

Initial Date
V2 11/30
Start End Hours
0944 1000 .33

Wet Well

-Well
Check

Initial Date
V2 11/30

2 disconnected



Pump Stations Weekly PMs

11/30/09 - 12/04/09

Bayview Pump House ✓

Main Floor

-Diesel Generator Kit

Initial Date
V2 11/30

Check Oil,
Check Level in Day Tank

-Exercise Engine a min
of 30 minutes:
3x/month w/o load
1x/month underload

Initial Date
V2 11/30
Start End Hours
1355 1425 .5

Dry Well

-Air Compressors

Initial Date
V2 11/30

Drain Water from Tank

-Seal Water System

Initial Date
V2 11/30

Alternate Lead Pump,
Check Tank Fill Valve & Operating Pressure

-Sewer Pumps

Initial Date
V2 11/30

Check Purge Lines,
Check Seal, Water Usage (runs at 25 psi)

-Clear Debris in

Initial Date
V2 11/30

Impellers

Bayview Main Building ✓

Main Floor

-Blue Bird Court Generator

Initial Date
V2 11/30

Check Oil and Water,

-Exercise Engine a min
of 30 minutes:
3x/month w/o load
1x/month underload

Initial Date
V2 11/30
~~1400~~ 1430
Start End Hours
1400 1430 .5

Basement

-Floor Drains

Initial Date
V2 11/30

Pump Water

-Boiler

Initial Date
V2 11/30

Check Operation

-Piping

Initial Date
V2 11/30

Check for Leaks,
Check Seal, Water Usage

broken off
LINE

Wet Well

-Muffin Monitors

Initial Date
V2 11/30

Check Operation,
Clean Debris in Channels



Pump Stations Weekly PMs

11/30/09 - 12/04/09

Grist Mill ✓

Main Floor

-Diesel Generator Kit

Check Oil & Water,
Check Battery Water

Initial	Date
V2	11/30

-Exercise Engine a min
of 30 minutes:
3x/month w/o load
1x/month underload

Initial	Date
V2	11/30

Start	End	Hours
1030	1100	.5

-Pump Control Panel

Check Operation

Initial	Date
V2	11/30

Wet Well

-Comminutor

Clean Debris in Housing

Initial	Date
V2	11/30

Greenleaf Hill ✓

Dry Well

-Generator Kit

Check Oil & Water,
Check Battery Water

Initial	Date
V2	11/30

-Exercise Engine a min
of 30 minutes:
3x/month w/o load
1x/month underload

Initial	Date
V2	11/30

Start	End	Hours
1310	1330	.23

-Sump Pump

Check Operation

Initial	Date
V2	11/30