



# Pump Stations Weekly PMs

Week of: 3/23/09 - 3/27/09

## Manhasset Valley ✓

### Main Floor

#### -Diesel Generator Kit

Check Oil,  
Water, Battery Water

Initial Date

VZ 3/23

#### -Exercise Engine a min

of 30 minutes:  
3x/month w/o load

1x/month underload

Initial Date

VZ 3/23

Start End Hours

0900 0920 .5

#### -Panel Board

#### Blowers

Check Operation

Initial Date

VZ 3/23

### Dry Well

#### -Air Compressors

Drain Water from Tank,  
Check Operation

Initial Date

VZ 3/23

#### -Seal Water

#### System

Check Fill Valve, Alternate Lead Pump,  
Check Operation (42 PSI)

Initial Date

VZ 3/23

### Wet Well

#### -Comminutor

Check Operation

Initial Date

VZ 3/23

## Shelter Rock ✓

### Main Floor

#### -Air Compressors

Check Operation,  
Drain Water from Tanks

Initial Date

VZ 3/23

### Dry Well

#### -Sewer Pumps

Check Purge Lines

Initial Date

VZ 3/23

#2 des connected

#### -Sump Pump

Check Operation

Initial Date

VZ 3/23

Approved by [signature]

### Roof

#### -Generator Kit

Check Oil & Water

Initial Date

VZ 3/23

#### -Exercise Engine a min

of 30 minutes:  
3x/month w/o load

1x/month underload

Initial Date

VZ 3/23

Start End Hours

0930 0950 .35

### Wet Well

#### -Well

Check

Initial Date

VZ 3/23

Schedule vector



# Pump Stations Weekly PMs

3/23/09 - 3/27/09

## Bayview Pump House ✓

### Main Floor

-Diesel Generator Kit

Check Oil,  
Check Level in Day Tank

Initial Date  
VR 3/23

-Exercise Engine a min  
of 30 minutes:  
3x/month w/o load  
1x/month underload

Initial Date  
VR 3/23  
Start End Hours  
12:30 1:00 .5

### Dry Well

-Air Compressors

Drain Water from Tank

Initial Date  
VR 3/23

-Seal Water System  
Alternate Lead Pump,  
Check Tank Fill Valve & Operating Pressure

Initial Date  
VR 3/23

-Sewer Pumps

Check Purge Lines,  
Check Seal, Water Usage (runs at 25 psi)

Initial Date  
VR 3/23

*Several Leaks*

-Clear Debris in

Impeller

Initial Date  
VR 3/23

## Bayview Main Building ✓

### Main Floor

-Blue Bird Court Generator

Check Oil and Water,

Initial Date  
VR 3/23

-Exercise Engine a min  
of 30 minutes:  
3x/month w/o load  
1x/month underload

Initial Date  
VR 3/23  
Start End Hours  
1:30 1:40 .5

### Basement

-Floor Drains

Pump Water

Initial Date  
VR 3/23

-Boiler  
Check Operation

Initial Date  
VR 3/23

-Piping

Check for Leaks,  
Check Seal, Water Usage

Initial Date  
VR 3/23

*boiler off*

### Wet Well

-Muffin Monitors

Check Operation,  
Clean Debris in Channels

Initial Date  
VR 3/23



# Pump Stations Weekly PMs

3/23/09 - 3/27/09

## **Crist Mill** ✓

### Main Floor

-Diesel Generator Kit

Check Oil & Water,  
Check Battery Water

| Initial | Date |
|---------|------|
| V2      | 3/23 |

-Exercise Engine a min  
of 30 minutes:  
3x/month w/o load  
1x/month underload

| Initial | Date |
|---------|------|
| V2      | 3/23 |

  

| Start | End  | Hours |
|-------|------|-------|
| 1040  | 1100 | .5    |

-Pump Control Panel

Check Operation

| Initial | Date |
|---------|------|
| V2      | 3/23 |

### Wet Well

-Comminutor

Clean Debris in Housing

| Initial | Date |
|---------|------|
| V2      | 3/23 |

## **Greenleaf Hill** ✓

### Dry Well

-Generator Kit

Check Oil & Water,  
Check Battery Water

| Initial | Date |
|---------|------|
| V2      | 3/23 |

-Exercise Engine a min  
of 30 minutes:  
3x/month w/o load  
1x/month underload

| Initial | Date |
|---------|------|
| V2      | 3/23 |

  

| Start | End  | Hours |
|-------|------|-------|
| 1420  | 1440 | .35   |

-Sump Pump

Check Operation

| Initial | Date |
|---------|------|
| V2      | 3/23 |