



Pump Stations Weekly PMs

Week of: 3/9/09 - 3/13/09

Manhasset Valley ✓

Main Floor

-Diesel Generator Kit

Check Oil,
Water, Battery Water

| Initial | Date |
|---------|------|
| VR | 3/9 |

-Exercise Engine a min
of 30 minutes:
3x/month w/o load
1x/month underload

| Initial | Date | |
|---------|------|-------|
| VR | 3/9 | |
| Start | End | Hours |
| 0850 | 0920 | .5 |

-Panel Board

Blowers
Check Operation

| Initial | Date |
|---------|------|
| VR | 3/9 |

Dry Well

-Air Compressors

Drain Water from Tank,
Check Operation

| Initial | Date |
|---------|------|
| VR | 3/9 |

-Seal Water

System
Check Fill Valve, Alternate Lead Pump,
Check Operation (42 PSI)

| Initial | Date |
|---------|------|
| VR | 3/9 |

Wet Well

-Comminutor

Check Operation

| Initial | Date |
|---------|------|
| VR | 3/9 |

Shelter Rock ✓

Main Floor

-Air Compressors

Check Operation,
Drain Water from Tanks

| Initial | Date |
|---------|------|
| VR | 3/9 |

Dry Well

-Sewer Pumps

Check Purge Lines

| Initial | Date |
|---------|------|
| VR | 3/9 |

-Sump Pumps

Check Operation

| Initial | Date |
|---------|------|
| VR | 3/9 |

#2 disconnected

Roof

-Generator Kit

Check Oil & Water

| Initial | Date |
|---------|------|
| VR | 3/9 |

-Exercise Engine a min
of 30 minutes:
3x/month w/o load
1x/month underload

| Initial | Date | |
|---------|------|-------|
| VR | 3/9 | |
| Start | End | Hours |
| 0935 | 0955 | .35 |

Wet Well

-Well

Check

| Initial | Date |
|---------|------|
| VR | 3/9 |

Schedule cleanings



Pump Stations Weekly PMs

3/9/09 - 3/13/09

Bayview Pump House ✓

Main Floor

-Diesel Generator Kit

Check Oil,
Check Level in Day Tank

| Initial | Date |
|---------|------|
| V2 | 3/9 |

-Exercise Engine a min
of 30 minutes:
3x/month w/o load
1x/month underload

| Initial | Date |
|---------|------|
| V2 | 3/9 |

| Start | End | Hours |
|-------|------|-------|
| 1335 | 1405 | .5 |

Dry Well

-Air Compressors

Drain Water from Tank

| Initial | Date |
|---------|------|
| V2 | 3/9 |

-Seal Water System

Alternate Lead Pump,
Check Tank Fill Valve & Operating Pressure

| Initial | Date |
|---------|------|
| V2 | 3/9 |

-Sewer Pumps

Check Purge Lines,
Check Seal, Water Usage (runs at 25 psi)
several leaks

| Initial | Date |
|---------|------|
| V2 | 3/9 |

-Clear Debris in

Impeller

| Initial | Date |
|---------|------|
| V2 | 3/9 |

Bayview Main Building ✓

Main Floor

-Blue Bird Court Generator

Check Oil and Water,

| Initial | Date |
|---------|------|
| V2 | 3/9 |

-Exercise Engine a min
of 30 minutes:
3x/month w/o load
1x/month underload

| Initial | Date |
|---------|------|
| V2 | 3/9 |

| Start | End | Hours |
|-------|------|-------|
| 1330 | 1400 | .5 |

Basement

-Floor Drains

Pump Water

| Initial | Date |
|---------|------|
| V2 | 3/9 |

-Boiler

Check Operation

| Initial | Date |
|---------|------|
| V2 | 3/9 |

boiler OK

-Piping

Check for Leaks,
Check Seal, Water Usage

| Initial | Date |
|---------|------|
| V2 | 3/9 |

Wet Well

-Muffin Monitors

Check Operation,
Clean Debris in Channels

| Initial | Date |
|---------|------|
| V2 | 3/9 |



Pump Stations Weekly PMs

3/9/09 - 3/13/09

Grist Mill ✓

Main Floor

-Diesel Generator Kit

Check Oil & Water,
Check Battery Water

| Initial | Date |
|---------|------|
| V2 | 3/9 |

-Exercise Engine a min
of 30 minutes:
3x/month w/o load
1x/month underload

| Initial | Date |
|---------|------|
| V2 | 3/9 |

| Start | End | Hours |
|-------|------|-------|
| 1020 | 1050 | .5 |

-Pump Control Panel

Check Operation

| Initial | Date |
|---------|------|
| V2 | 3/9 |

Wet Well

-Comminutor

Clean Debris in Housing

| Initial | Date |
|---------|------|
| V2 | 3/9 |

Greenleaf Hill ✓

Dry Well

-Generator Kit

Check Oil & Water,
Check Battery Water

| Initial | Date |
|---------|------|
| V2 | 3/9 |

-Exercise Engine a min
of 30 minutes:
3x/month w/o load
1x/month underload

| Initial | Date |
|---------|------|
| V2 | 3/9 |

| Start | End | Hours |
|-------|------|-------|
| 1310 | 1330 | .33 |

-Sump Pump

Check Operation

| Initial | Date |
|---------|------|
| V2 | 3/9 |