



Pump Stations Weekly PMs

Week of: 4/6/09 - 4/10/09

Manhasset Valley V

Main Floor

-Diesel Generator Kit

Check Oil,
Water, Battery Water

Initial Date

V2 3/6

-Exercise Engine a min

of 30 minutes:

3x/month w/o load

1x/month underload

Initial Date

V2 3/6

Start End Hours

0845 0915 .5

-Panel Board

Blowers
Check Operation

Initial Date

V2 3/6

Dry Well

-Air Compressors

Drain Water from Tank,
Check Operation

Initial Date

V2 3/6

-Seal Water

System

Check Fill Valve, Alternate Lead Pump,
Check Operation (42 PSI)

Initial Date

V2 3/6

Wet Well

-Comminutor

Check Operation

Initial Date

V2 3/6

Shelter Rock V

Main Floor

-Air Compressors

Check Operation,
Drain Water from Tanks

Initial Date

V2 3/6

Dry Well

-Sewer Pumps

Check Purge Lines

Initial Date

V2 3/6

-Sump Pumps

Check Operation

Initial Date

V2 3/6

Roof

-Generator Kit

Check Oil & Water

Initial Date

V2 3/6

-Exercise Engine a min

of 30 minutes:

3x/month w/o load

1x/month underload

Initial Date

V2 3/6

Start End Hours

0930 0950 .35

Wet Well

-Well

Check

Initial Date

V2 3/6

Schedule vacation

2 disconnected



Pump Stations Weekly PMs

4/6/09 - 4/10/09

Bayview Pump House ✓

Main Floor

-Diesel Generator Kit

Check Oil,
Check Level in Day Tank

Initial Date
V2 3/6

-Exercise Engine a min
of 30 minutes:
3x/month w/o load
1x/month underload

Initial Date
V2 3/6
Start End Hours
1315 1345 .5

Dry Well

-Air Compressors

Drain Water from Tank

Initial Date
V2 3/6

-Seal Water System

Alternate Lead Pump,
Check Tank Fill Valve & Operating Pressure

Initial Date
V2 3/6

-Sewer Pumps

Check Purge Lines,
Check Seal, Water Usage (runs at 25 psi)

Initial Date
V2 3/6

Several Leaks

-Clear Debris in

Impeller

Initial Date
V2 3/6

Bayview Main Building ✓

Main Floor

-Blue Bird Court Generator

Check Oil and Water,

Initial Date
V2 3/6

-Exercise Engine a min
of 30 minutes:
3x/month w/o load
1x/month underload

Initial Date
V2 3/6
Start End Hours
1330 1400 .5

Basement

-Floor Drains

Pump Water

Initial Date
V2 3/6

-Boiler

Check Operation

Initial Date
V2 3/6

-Piping

Check for Leaks,
Check Seal, Water Usage

Initial Date
V2 3/6

Wet Well

-Muffin Monitors

Check Operation,
Clean Debris in Channels

Initial Date
V2 3/6



Pump Stations Weekly PMs

4/6/09 - 4/10/09

Grist Mill ✓

Main Floor

-Diesel Generator Kit

Check Oil & Water,
Check Battery Water

Initial	Date
V2	3/6

-Exercise Engine a min
of 30 minutes:
3x/month w/o load
1x/month underload

Initial	Date	
V2	3/6	
Start	End	Hours
1040	1110	:5

-Pump Control Panel

Check Operation

Initial	Date
V2	3/6

Wet Well

-Comminutor

Clean Debris in Housing

Initial	Date
V2	3/6

Greenleaf Hill ✓

Dry Well

-Generator Kit

Check Oil & Water,
Check Battery Water

Initial	Date
V2	3/6

-Exercise Engine a min
of 30 minutes:
3x/month w/o load
1x/month underload

Initial	Date	
V2	3/6	
Start	End	Hours
1410	1430	.33

-Sump Pump

Check Operation

Initial	Date
V2	3/6