



Pump Stations Weekly PMs

Week of: 5/4/09 - 5/8/09

Manhasset Valley ✓

Main Floor

-Diesel Generator Kit

Check Oil,
Water, Battery Water

Initial Date
V2 5/5

-Exercise Engine a min
of 30 minutes:
3x/month w/o load
1x/month underload

Initial Date
V2 5/5
Start End Hours
0845 0915 .5

-Panel Board

Blowers
Check Operation

Initial Date
V2 5/5

Dry Well

-Air Compressors

Drain Water from Tank,
Check Operation

Initial Date
V2 5/5

-Seal Water

System
Check Fill Valve, Alternate Lead Pump,
Check Operation (42 PSI)

Initial Date
V2 5/5

Wet Well

-Comminutor

Check Operation

Initial Date
V2 5/5

Shelter Rock ✓

Main Floor

-Air Compressors

Check Operation,
Drain Water from Tanks

Initial Date
V2 5/5

Dry Well

-Sewer Pumps

Check Purge Lines

Initial Date
V2 5/5

-Sump Pumps

Check Operation

Initial Date
V2 5/5

Roof

-Generator Kit

Check Oil & Water

Initial Date
V2 5/5

-Exercise Engine a min
of 30 minutes:
3x/month w/o load
1x/month underload

Initial Date
V2 5/5
Start End Hours
0930 0950 .33

Wet Well

-Well

Check

Initial Date
V2 5/5

Schedule change



Pump Stations Weekly PMs

5/4/09 - 5/8/09

Bayview Pump House ✓

Main Floor

-Diesel Generator Kit

Check Oil,
Check Level in Day Tank

Initial Date
V2 5/5

-Exercise Engine a min
of 30 minutes:
3x/month w/o load
1x/month underload

Initial Date
V2 5/5
Start End Hours
11:05 11:45 .5

Dry Well

-Air Compressors

Drain Water from Tank

Initial Date
V2 5/5

-Seal Water System

Alternate Lead Pump,
Check Tank Fill Valve & Operating Pressure

Initial Date
V2 5/5

-Sewer Pumps

Check Purge Lines,
Check Seal, Water Usage (runs at 25 psi)

Initial Date
V2 5/5

-Clear Debris in

Impellers

Initial Date
V2 5/5

Bayview Main Building ✓

Main Floor

-Blue Bird Court Generator

Check Oil and Water,

Initial Date
V2 5/5

-Exercise Engine a min
of 30 minutes:
3x/month w/o load
1x/month underload

Initial Date
V2 5/5
Start End Hours
11:00 11:15 .25

Basement

-Floor Drains

Pump Water

Initial Date
V2 5/5

-Boiler

Check Operation

Initial Date
V2 5/5
boiler ok

-Piping

Check for Leaks,
Check Seal, Water Usage

Initial Date
V2 5/5

Wet Well

-Muffin Monitors

Check Operation,
Clean Debris in Channels

Initial Date
V2 5/5



Pump Stations Weekly PMs

5/4/09 - 5/8/09

Grist Mill ✓

Main Floor

-Diesel Generator Kit

Check Oil & Water,
Check Battery Water

Initial	Date
v2	5/5

-Exercise Engine a min
of 30 minutes:
3x/month w/o load
1x/month underload

Initial	Date
v2	5/5

Start	End	Hours
1030	1100	.3

-Pump Control Panel

Check Operation

Initial	Date
v2	5/5

Wet Well

-Comminutor

Clean Debris in Housing

Initial	Date
v2	5/5

Greenleaf Hill ✓

Dry Well

-Generator Kit

Check Oil & Water,
Check Battery Water

Initial	Date
v2	5/5

-Exercise Engine a min
of 30 minutes:
3x/month w/o load
1x/month underload

Initial	Date
v2	5/5

Start	End	Hours
1300	1320	.33

-Sump Pump

Check Operation

Initial	Date
v2	5/5