



Pump Stations Weekly PMs

Week of: 6/1/09 - 6/5/09

Manhasset Valley

Main Floor

-Diesel Generator Kit
Check Oil,
Water, Battery Water

Initial Date
V2 6/1

-Exercise Engine a min
of 30 minutes:
3x/month w/o load
1x/month underload

Initial Date
V2 6/1
Start End Hours
0915 0945 .5

-Panel Board
Blowers
Check Operation

Initial Date
V2 6/1

Dry Well

-Air Compressors

Drain Water from Tank,
Check Operation

Initial Date
V2 6/1

-Seal Water
System

Check Fill Valve, Alternate Lead Pump,
Check Operation (42 PSI)

Initial Date
V2 6/1

Wet Well

-Comminutor

Check Operation

Initial Date
V2 6/1

Shelter Rock

Main Floor

-Air Compressors

Check Operation,
Drain Water from Tanks

Initial Date
V2 6/1

Dry Well

-Sewer Pumps

Check Purge Lines

Initial Date
V2 6/1

-Sump Pumps

Check Operation

Initial Date
V2 6/1

Roof

-Generator Kit

Check Oil & Water

#2 document for

Initial Date
V2 6/1

-Exercise Engine a min
of 30 minutes:
3x/month w/o load
1x/month underload

Initial Date
V2 6/1
Start End Hours
1010 1030 .33

Wet Well

-Well

Check

Initial Date
V2 6/1

Schedule Vector



Pump Stations Weekly PMs

6/1/09 - 6/5/09

Bayview Pump House

Main Floor

-Diesel Generator Kit

Check Oil,
Check Level in Day Tank

Initial Date
V2 6/1

-Exercise Engine a min
of 30 minutes:
3x/month w/o load
1x/month underload

Initial Date
V2 6/1

Start End Hours
1345 1415 .5

Dry Well

-Air Compressors

Drain Water from Tank

Initial Date
V2 6/1

-Seal Water System

Alternate Lead Pump,
Check Tank Fill Valve & Operating Pressure

Initial Date
V2 6/1

-Sewer Pumps

Check Purge Lines,
Check Seal, Water Usage (runs at 25 psi)

Initial Date
V2 6/1

-Clear Debris in

Impellers

Initial Date
V2 6/1

Bayview Main Building

Main Floor

-Blue Bird Court Generator

Check Oil and Water,

Initial Date
V2 6/1

-Exercise Engine a min
of 30 minutes:
3x/month w/o load
1x/month underload

Initial Date
V2 6/1

Start End Hours
1345 1405 .25

Basement

-Floor Drains

Pump Water

Initial Date
V2 6/1

-Boiler

Check Operation

Initial Date
V2 6/1

boiler off

-Piping

Check for Leaks,

Check Seal, Water Usage

Initial Date
V2 6/1

Wet Well

-Muffin Monitors

Check Operation,
Clean Debris in Channels

Initial Date
V2 6/1



Pump Stations Weekly PMs

6/1/09 - 6/5/09

Grist Mill ✓

Main Floor

-Diesel Generator Kit

Check Oil & Water,
Check Battery Water

Initial Date

VJ 6/1

-Exercise Engine a min

of 30 minutes:

3x/month w/o load

1x/month underload

Initial Date

VJ 6/1

Start End Hours

1235 125 .50

-Pump Control Panel

Check Operation

Initial Date

VJ 6/1

Wet Well

-Comminutor

Clean Debris in Housing

Initial Date

VJ 6/1

Greenleaf Hill ✓

Dry Well

-Generator Kit

Check Oil & Water,
Check Battery Water

Initial Date

VJ 6/1

-Exercise Engine a min

of 30 minutes:

3x/month w/o load

1x/month underload

Initial Date

VJ 6/1

Start End Hours

1300 1320 .33

-Sump Pump

Check Operation

Initial Date

VJ 6/1

W

✓