



Pump Stations Weekly PMs

Week of: 6/29/09 - 7/03/09

Manhasset Valley

Main Floor

-Diesel Generator Kit

Check Oil,
Water, Battery Water

Initial Date
AM 6/29

-Exercise Engine a min

of 30 minutes:
3x/month w/o load

1x/month underload

Initial Date
AM 6/29

Start End Hours
8:00 8:30 .30

-Panel Board

Blowers
Check Operation

Initial Date
AM 6/29

Dry Well

-Air Compressors

Drain Water from Tank,
Check Operation

Initial Date
AM 6/29

-Seal Water

System
Check Fill Valve, Alternate Lead Pump,
Check Operation (42 PSI)

Initial Date
AM 6/29

Wet Well

-Comminutor

Check Operation

Initial Date
AM 6/29

Shelter Rock

Main Floor

-Air Compressors

Check Operation,
Drain Water from Tanks

Initial Date
AM 6/29

Dry Well

-Sewer Pumps

Check Purge Lines

Initial Date
AM 6/29

-Sump Pumps

Check Operation

Initial Date
AM 6/29

Roof

-Generator Kit

Check Oil & Water

Initial Date
AM 6/29

-Exercise Engine a min

of 30 minutes:
3x/month w/o load

1x/month underload

Initial Date
AM 6/29

Start End Hours
11:00 11:30 .30

Wet Well

-Well

Check

Initial Date
AM 6/29

schedule vacator



Pump Stations Weekly PMs

6/29/09 - 7/03/09

Bayview Pump House

Main Floor

-Diesel Generator Kit

Check Oil,
Check Level in Day Tank

Initial Date
AM 6/29

-Exercise Engine a min

of 30 minutes:
3x/month w/o load
1x/month underload

Initial Date
AM 6/29

Start End Hours
2:00 2:30 .30

Dry Well

-Air Compressors

Drain Water from Tank

Initial Date
AM 6/29

-Seal Water System

Alternate Lead Pump,
Check Tank Fill Valve & Operating Pressure

Initial Date
AM 6/29

-Sewer Pumps

Check Purge Lines,
Check Seal, Water Usage (runs at 25 psi)

Initial Date
AM 6/29

-Clear Debris in

Impellers

Initial Date
AM 6/29

Bayview Main Building

Main Floor

-Blue Bird Court Generator

Check Oil and Water,

Initial Date
AM 6/29

-Exercise Engine a min

of 30 minutes:
3x/month w/o load
1x/month underload

Initial Date
AM 6/29

Start End Hours
2:00 2:30 .30

Basement

-Floor Drains

Pump Water

Initial Date
AM 6/29

-Boiler

Check Operation

Initial Date
AM 6/29
DFJ

-Piping

Check for Leaks,
Check Seal, Water Usage

Initial Date
AM 6/29

Wet Well

-Muffin Monitors

Check Operation,
Clean Debris in Channels

Initial Date
AM 6/29



Pump Stations Weekly PMs

6/29/09 - 7/03/09

Grist Mill

Main Floor

-Diesel Generator Kit

Check Oil & Water,
Check Battery Water

Initial Date
AM 7/2

-Exercise Engine a min
of 30 minutes:
3x/month w/o load
1x/month underload

Initial Date
AM 7/2
Start End Hours
2:00 2:30 .30

-Pump Control Panel

Check Operation

Initial Date
AM 7/2

Wet Well

-Comminutor

Clean Debris in Housing

Initial Date
AM 7/2

Greenleaf Hill

Dry Well

-Generator Kit

Check Oil & Water,
Check Battery Water

Initial Date
AM 7/2

-Exercise Engine a min
of 30 minutes:
3x/month w/o load
1x/month underload

Initial Date
AM 6/29
Start End Hours
1:00 1:30 .30

-Sump Pump

Check Operation

Initial Date
AM 7/2