



Pump Stations Weekly PMs

Week of: 7/6/09 - 7/10/09 ✓

Manhasset Valley

Main Floor

-Diesel Generator Kit
Check Oil,
Water, Battery Water

Initial Date
VZ 7/6

-Exercise Engine a min
of 30 minutes:
3x/month w/o load
1x/month underload

Initial Date
VZ 7/6
Start End Hours
0830 0900 .5

-Panel Board
Blowers
Check Operation

Initial Date
VZ 7/6

Dry Well

-Air Compressors
Drain Water from Tank,
Check Operation

Initial Date
VZ 7/6

-Seal Water
System
Check Fill Valve, Alternate Lead Pump,
Check Operation (42 PSI)

Initial Date
VZ 7/6

Wet Well

-Comminutor
Check Operation

Initial Date
VZ 7/6

Shelter Rock ✓

Main Floor

-Air Compressors
Check Operation,
Drain Water from Tanks

Initial Date
VZ 7/6

Dry Well

-Sewer Pumps
Check Purge Lines

Initial Date
VZ 7/6

-Sump Pumps
Check Operation

Initial Date
VZ 7/6

Roof

-Generator Kit
Check Oil & Water

Initial Date
VZ 7/6

-Exercise Engine a min
of 30 minutes:
3x/month w/o load
1x/month underload

Initial Date
VZ 7/6
Start End Hours
0920 0940 .33

Wet Well

-Well
Check

Initial Date
VZ 7/6

Schedule action

#2 disconnected



Pump Stations Weekly PMs

7/6/09 - 7/10/09

Bayview Pump House

Main Floor

-Diesel Generator Kit

Check Oil,
Check Level in Day Tank

Initial Date
V2 7/6

-Exercise Engine a min
of 30 minutes:
3x/month w/o load
1x/month underload

Initial Date
V2 7/6
Start End Hours
1400 1430 .5

Dry Well

-Air Compressors

Drain Water from Tank

Initial Date
V2 7/6

-Seal Water System

Alternate Lead Pump,
Check Tank Fill Valve & Operating Pressure

Initial Date
V2 7/6

-Sewer Pumps

Check Purge Lines,
Check Seal, Water Usage (runs at 25 psi)

Initial Date
V2 7/6

-Clear Debris in

Impellers

Initial Date
V2 7/6

Bayview Main Building

Main Floor

-Blue Bird Court Generator

Check Oil and Water,

Initial Date
V2 7/6

-Exercise Engine a min
of 30 minutes:
3x/month w/o load
1x/month underload

Initial Date
V2 7/6
Start End Hours
1405 1435 .5

Basement

-Floor Drains

Pump Water

Initial Date
V2 7/6

-Boiler

Check Operation

Initial Date
V2 7/6
boiler off

-Piping

Check for Leaks,
Check Seal, Water Usage

Initial Date
V2 7/6

Wet Well

-Muffin Monitors

Check Operation,
Clean Debris in Channels

Initial Date
V2 7/6



Pump Stations Weekly PMs

7/6/09 - 7/10/09

Grist Mill ✓

Main Floor

-Diesel Generator Kit

Check Oil & Water,
Check Battery Water

Initial	Date
V2	7/6

-Exercise Engine a min
of 30 minutes:
3x/month w/o load
1x/month underload

Initial	Date
V2	7/6

Start	End	Hours
1015	1045	.5

-Pump Control Panel

Check Operation

Initial	Date
V2	7/6

Wet Well

-Comminutor

Clean Debris in Housing

Initial	Date
V2	7/6

Greenleaf Hill ✓

Dry Well

-Generator Kit

Check Oil & Water,
Check Battery Water

Initial	Date
V2	7/6

-Exercise Engine a min
of 30 minutes:
3x/month w/o load
1x/month underload

Initial	Date
V2	7/6

Start	End	Hours
1310	1330	.33

-Sump Pump

Check Operation

Initial	Date
V2	7/6