



Pump Stations Weekly PMs

Week of: 8/3/09 - 8/7/09

Manhasset Valley ✓

Main Floor

-Diesel Generator Kit

Check Oil,
Water, Battery Water

Initial Date

VZ 8/3

-Exercise Engine a min

of 30 minutes:

3x/month w/o load

1x/month underload

Initial Date

VZ 8/3

Start End Hours

0900 0930 .5

-Panel Board

Blowers

Check Operation

Initial Date

VZ 8/3

Dry Well

-Air Compressors

Drain Water from Tank,
Check Operation

Initial Date

VZ 8/3

-Seal Water

System

Check Fill Valve, Alternate Lead Pump,
Check Operation (42 PSI)

Initial Date

VZ 8/3

Wet Well

-Comminutor

Check Operation

Initial Date

VZ 8/3

Shelter Rock ✓

Main Floor

-Air Compressors

Check Operation,
Drain Water from Tanks

Initial Date

VZ 8/3

Dry Well

-Sewer Pumps

Check Purge Lines

Initial Date

VZ 8/3

-Sump Pumps

Check Operation

Initial Date

VZ 8/3

Roof

-Generator Kit

Check Oil & Water

Initial Date

VZ 8/3

-Exercise Engine a min

of 30 minutes:

3x/month w/o load

1x/month underload

Initial Date

VZ 8/3

Start End Hours

1000 1030 .5

Wet Well

-Well

Check

Initial Date

VZ 8/3

Schedule vacation

#2 disconnected



Pump Stations Weekly PMs

8/3/09 - 8/7/09

Bayview Pump House ✓

Main Floor

-Diesel Generator Kit

Check Oil,
Check Level in Day Tank

Initial	Date
VZ	8/3

-Exercise Engine a min
of 30 minutes:
3x/month w/o load
1x/month underload

Initial	Date
VZ	8/3

Start	End	Hours
1400	1430	.5

Dry Well

-Air Compressors

Drain Water from Tank

Initial	Date
VZ	8/3

-Seal Water System
Alternate Lead Pump,
Check Tank Fill Valve & Operating Pressure

Initial	Date
VZ	8/3

-Sewer Pumps

Check Purge Lines,
Check Seal, Water Usage (runs at 25 psi)

Initial	Date
VZ	8/3

#3 has sewage leaks

-Clear Debris in

Impellers

Initial	Date
VZ	8/3

Bayview Main Building ✓

Main Floor

-Blue Bird Court Generator

Check Oil and Water,

Initial	Date
VZ	8/3

-Exercise Engine a min
of 30 minutes:
3x/month w/o load
1x/month underload

Initial	Date
VZ	8/3

Start	End	Hours
1410	1440	.5

Basement

-Floor Drains

Pump Water

Initial	Date
VZ	8/3

-Boiler

Check Operation

Initial	Date
VZ	8/3

boiler off

-Piping

Check for Leaks,
Check Seal, Water Usage

Initial	Date
VZ	8/3

Wet Well

-Muffin Monitors

Check Operation,
Clean Debris in Channels

Initial	Date
VZ	8/3

W



Pump Stations Weekly PMs

8/3/09 - 8/7/09

Grist Mill ✓

Main Floor

-Diesel Generator Kit

Check Oil & Water,
Check Battery Water

Initial Date
V2 8/3

-Exercise Engine a min
of 30 minutes:
3x/month w/o load
1x/month underload

Initial Date
V2 8/3
Start End Hours
1160 1130 .5

-Pump Control Panel

Check Operation

Initial Date
V2 8/3

Wet Well

-Comminutor

Clean Debris in Housing

Initial Date
V2 8/3

Greenleaf Hill ✓

Dry Well

-Generator Kit

Check Oil & Water,
Check Battery Water

Initial Date
V2 8/3

-Exercise Engine a min
of 30 minutes:
3x/month w/o load
1x/month underload

Initial Date
V2 8/3
Start End Hours
1310 1330 .37

-Sump Pump

Check Operation

Initial Date
V2 8/3