



Pump Stations Monthly PMs

Month of: January 2010

Manhasset Valley ✓

Main Floor

-Exhaust Air Louver's
Check Operation

Initial	Date
V2	1/15

-Fresh Air Louver's
Check Operation

Initial	Date
V2	1/15

-Alarms
Check Operation

Initial	Date

Dry Well

-Sump Pumps
Check Operation

Initial	Date
V2	1/15

-Exhaust Fans
Check Operation

Initial	Date
V2	1/15

-"Y" Strainers
Clean "Y" Strainers

Initial	Date
V2	1/15

Wet Well

-Well
Remove Grease,
Exercise Splitter Valve

Initial	Date
V2	1/28

-Check Oil

Initial	Date
V2	1/15

-Bypass Channel
Flush Channel
Clean Bar Screen

Initial	Date
V2	1/15

-Exhaust Fans
Check Operation

Initial	Date
V2	1/15

Shelter Rock ✓

Main Floor

-CO2 Tank
Check Pressure,
Check for Leaks (950 psi)

Initial	Date
V2	1/11

-Exhaust Fans
Check Operation

Initial	Date
V2	1/11

-Alarm System
Check Operation

Initial	Date

Wet Well

-Remove Rags
and Grease

Initial	Date
V2	1/28

Bayview Pump House ✓

Main Floor

-Panel Boards
Check Blower
Operation

Initial	Date
V2	1/22

-Exhaust Fans
Check Operation

Initial	Date
V2	1/22

-Alarms
Check Operation
Check Tank Fill Valve & Operating Pressure

Initial	Date
V2	1/19

Dry Well

-Check Daily Run Time

Initial	Date
V2	1/11

-Grease Drive Shafts

Initial	Date
V2	1/22

-Sump Pumps
Check Operation

Initial	Date
V2	1/22

-Valves
Exercise

Initial	Date
V2	1/11

-Solenoid Valves
Check Operation

Initial	Date
V2	1/11

-"Y" Strainers
Clean "Y" Strainers

Initial	Date
V2	1/23



Pump Stations Monthly PMs

January

2010

Bayview Main Building ✓

Roof

-Exhaust Fans

Check Operation

Initial	Date
VZ	1/22

Hypo Room

-Hypo Pump

Check Oil Level,
Check Operation

Initial	Date
VZ	1/22

-Piping, Tank & Valves

Check for Leaks

Initial	Date
VZ	1/22

-Exhaust Fan

Check Operation,
Check "Y" Strainer on HypoTank

Initial	Date
VZ	1/22

Basement

-Sump Pumps

Check Operation

Initial	Date
VZ	1/22

-Bluebird Pumps

Exercise

Initial	Date
VZ	1/22

Wet Well

-Exhaust Fan

Check Operation

Initial	Date
VZ	1/22

-Well

Remove Grease

Initial	Date
VZ	1/26

Grist Mill ✓

Main Floor

-Exhaust Fans

Check Operation

Initial	Date
VZ	1/22

-Alarm Panel

Check Operation

Initial	Date

Dry Well

-Check Valves

Exercise

Initial	Date
VZ	1/19

-Sump Pump

Check Operation

Initial	Date
VZ	1/22

-Exhaust Fan

Check Operation

Initial	Date
VZ	1/22

Wet Well

-Exhaust Fan

Initial	Date
VZ	1/22

Greenleaf Hill ✓

Dry Well

-Alarm Panel

Check Operation

Initial	Date

-High Level

Tank Alarms
Check Operation

Initial	Date

-Exhaust Fans

Check Operation

Initial	Date
VZ	1/11

-Sump Pump #1

Initial	Date
VZ	1/11
Reading	1798

-Sump Pump #2

Initial	Date
VZ	1/11
Reading	3.6

-Start Cycles #1

Initial	Date
VZ	1/11
Reading	18971

-Start Cycles #2

Initial	Date
VZ	1/11
Reading	21311

-Electric Grinder

Reading

Initial	Date
VZ	1/11
Reading	17931.5

-"Y" Strainers

Clean "Y" Strainer

Initial	Date
VZ	1/11

-Force Main Bypass

Check Valve
Check operation of

valves and grease as necessary

Initial	Date
VZ	1/11