



Pump Stations Monthly PMs

Month of: December 2010

Manhasset Valley ✓

Main Floor

-Exhaust Air Louver's

Check Operation

Initial	Date
VZ	12/1

-Fresh Air Louver's

Check Operation

Initial	Date
VZ	12/1

-Alarms

Check Operation

Initial	Date

Dry Well

-Sump Pumps

Check Operation

Initial	Date
VZ	12/1

-Exhaust Fans

Check Operation

Initial	Date
VZ	12/1

-"Y" Strainers

Clean "Y" Strainers

Initial	Date
VZ	12/1

Wet Well

-Well

Remove Grease,
Exercise Splitter Valve

Initial	Date
VZ	12/1

-Check Oil

OK

Initial	Date
VZ	12/1

-Bypass Channel

Flush Channel
Clean Bar Screen

Initial	Date
VZ	12/1

-Exhaust Fans

Check Operation

Initial	Date
VZ	12/1

Shelter Rock ✓

Main Floor

-CO2 Tank

Check Pressure,
Check for Leaks (950 psi)

Initial	Date
VZ	12/1

-Exhaust Fans

Check Operation

Initial	Date
VZ	12/1

-Alarm System

Check Operation

Initial	Date

Wet Well

-Remove Rags
and Grease

Initial	Date
VZ	12/21

OK

Bayview Pump House ✓

Main Floor

-Panel Boards

Check Blower
Operation

Initial	Date
VZ	12/6

-Exhaust Fans

Check Operation

Initial	Date
VZ	12/6

-Alarms

Check Operation
Check Tank Fill Valve & Operating Pressure

Initial	Date

Dry Well

-Check Daily Run Time

Initial	Date
VZ	12/6

-Grease Drive Shafts

Initial	Date
VZ	12/6

-Sump Pumps

Check Operation

Initial	Date
VZ	12/6

-Valves

Exercise

Initial	Date
VZ	12/6

-Solenoid Valves

Check Operation

Initial	Date
VZ	12/6

-"Y" Strainers

Clean "Y" Strainers

Initial	Date
VZ	12/6



Pump Stations Monthly PMs

December 2010

Bayview Main Building ✓

Roof

-Exhaust Fans

Check Operation

Initial	Date
vr	12/6

Hypo Room

-Hypo Pump

Check Oil Level,
Check Operation

Initial	Date
vr	12/6

-Piping, Tank & Valves

Check for Leaks

Initial	Date
vr	12/6

-Exhaust Fan

Check Operation,
Check "Y" Strainer on Hypo Tank

Initial	Date
vr	12/6

Basement

-Sump Pumps

Check Operation

Initial	Date
vr	12/6

-Bluebird Pumps

Exercise

Initial	Date
vr	12/6

Wet Well

-Exhaust Fan

Check Operation

Initial	Date
vr	12/6

-Well

Remove Grease

Initial	Date
vr	12/22

① Vaction check

Grist Mill ✓

Main Floor

-Exhaust Fans

Check Operation

Initial	Date
vr	12/13

-Alarm Panel

Check Operation

Initial	Date

Dry Well

-Check Valves

Exercise

Initial	Date
vr	12/13

-Sump Pump

Check Operation

Initial	Date
vr	12/13

-Exhaust Fan

Check Operation

Initial	Date
vr	12/13

Wet Well

-Exhaust Fan

Initial	Date
vr	12/13

Greenleaf Hill ✓

Dry Well

-Alarm Panel

Check Operation

Initial	Date
vr	12/6

-High Level

Tank Alarms
Check Operation

Initial	Date

-Exhaust Fans

Check Operation

Initial	Date
vr	12/6

-Sump Pump #1

Initial	Date
vr	12/6
Reading	228.0

-Sump Pump #2

Initial	Date
vr	12/6
Reading	3.6

-Start Cycles #1

Initial	Date
vr	12/6
Reading	0

-Start Cycles #2

Initial	Date
vr	12/6
Reading	0

-Electric Grinder

Reading

Initial	Date
vr	12/6
Reading	23642.1

-"Y" Strainers

Clean "Y" Strainers

Initial	Date
vr	12/6

-Force Main Bypass

Check Valve

Check operation of
valves and grease as necessary

Initial	Date
vr	12/6