



Pump Stations Monthly PMs

Month of: February 2010

Manhasset Valley ✓

Main Floor

-Exhaust Air Louver's

Initial	Date
VR	2/5

Check Operation

-Fresh Air Louver's

Initial	Date
VR	2/5

Check Operation

-Alarms

Initial	Date

Check Operation

Dry Well

-Sump Pumps

Initial	Date
VR	2/5

Check Operation

-Exhaust Fans

Initial	Date
VR	2/5

Check Operation

-"Y" Strainers

Initial	Date
VR	2/5

Clean "Y" Strainers

Wet Well

-Well

Initial	Date
VR	2/5

Remove Grease,
Exercise Splitter Valve

-Check Oil

Initial	Date
VR	2/12

-Bypass Channel

Initial	Date
VR	2/5

Flush Channel
Clean Bar Screen

-Exhaust Fans

Initial	Date
VR	2/12

Check Operation

Shelter Rock ✓

Main Floor

-CO2 Tank

Initial	Date
VR	2/5

Check Pressure,
Check for Leaks (950 psi)

-Exhaust Fans

Initial	Date
VR	2/5

Check Operation

-Alarm System

Initial	Date

Check Operation

Wet Well

-Remove Rags
and Grease

Initial	Date
VR	2/22

Schedule action

Bayview Pump House ✓

Main Floor

-Panel Boards

Initial	Date
VR	2/12

Check Blower
Operation

-Exhaust Fans

Initial	Date
VR	2/5

Check Operation

-Alarms

Initial	Date
VR	2/5

Check Operation
Check Tank Fill Valve & Operating Pressure

Dry Well

-Check Daily Run Time

Initial	Date
VR	2/5

-Grease Drive Shafts

Initial	Date
VR	2/5

-Sump Pumps

Initial	Date
VR	2/5

Check Operation

-Valves

Initial	Date
VR	2/12

Exercise

-Solenoid Valves

Initial	Date
VR	2/12

Check Operation

-"Y" Strainers

Initial	Date
VR	2/12

Clean "Y" Strainers



Pump Stations Monthly PMs

February 2010

Bayview Main Building ✓

Roof

-Exhaust Fans

Check Operation

Initial	Date
VZ	2/12

Hypo Room

-Hypo Pump

Check Oil Level,
Check Operation

Initial	Date
VZ	2/12

-Piping, Tank & Valves

Check for Leaks

Initial	Date
VZ	2/12

-Exhaust Fan

Check Operation,
Check "Y" Strainer on HypoTank

Initial	Date
VZ	2/12

Basement

-Sump Pumps

Check Operation

Initial	Date
VZ	2/12

-Bluebird Pumps

Exercise

Initial	Date
VZ	2/12

Wet Well

-Exhaust Fan

Check Operation

Initial	Date
VZ	2/12

-Well

Remove Grease

Initial	Date
VZ	2/12

schedule v action

Grist Mill ✓

Main Floor

-Exhaust Fans

Check Operation

Initial	Date
VZ	2/19

-Alarm Panel

Check Operation

Initial	Date

Dry Well

-Check Valves

Exercise

Initial	Date
VZ	2/19

-Sump Pump

Check Operation

Initial	Date
VZ	2/19

-Exhaust Fan

Check Operation

Initial	Date
VZ	2/19

Wet Well

-Exhaust Fan

Initial	Date
VZ	2/19

Greenleaf Hill ✓

Dry Well

-Alarm Panel

Check Operation

Initial	Date

-High Level

Tank Alarms
Check Operation

Initial	Date

-Exhaust Fans

Check Operation

Initial	Date
VZ	2/15

-Sump Pump #1

Initial	Date
VZ	2/15
Reading	179.8

-Sump Pump #2

Initial	Date
VZ	2/15
Reading	3.6

-Start Cycles #1

Initial	Date
VZ	2/15
Reading	19619

-Start Cycles #2

Initial	Date
VZ	2/15
Reading	21920

-Electric Grinder

Reading

Initial	Date
VZ	2/15
Reading	17934.9

-"Y" Strainers

Clean "Y" Strainers

Initial	Date
VZ	2/15

-Force Main Bypass

Check Valve

Check operation of
valves and grease as necessary

Initial	Date
VZ	2/15