



# Pump Stations Monthly PMs

Month of: March 2010

## Mamhasset Valley

✓

### Main Floor

#### -Exhaust Air Louver's

Initial	Date
VR	3/5

Check Operation

#### -Fresh Air Louver's

Initial	Date
VR	3/5

Check Operation

#### -Alarms

Initial	Date

Check Operation

### Dry Well

#### -Sump Pumps

Initial	Date
VR	3/5

Check Operation

#### -Exhaust Fans

Initial	Date
VR	3/5

Check Operation

#### -"Y" Strainers

Initial	Date
VR	3/5

Clean "Y" Strainers

### Wet Well

#### -Well

Initial	Date
VR	3/19

Remove Grease,  
Exercise Splitter Valve

*schedule water*

#### -Check Oil

Initial	Date
VR	3/5

#### -Bypass Channel

Initial	Date
VR	3/12

Flush Channel  
Clean Bar Screen

#### -Exhaust Fans

Initial	Date
VR	3/12

Check Operation

## Shelter Rock

✓

### Main Floor

#### -CO2 Tank

Initial	Date
VR	3/5

Check Pressure,  
Check for Leaks (950 psi)

#### -Exhaust Fans

Initial	Date
VR	3/5

Check Operation

#### -Alarm System

Initial	Date

Check Operation

### Wet Well

#### -Remove Rags

Initial	Date
VR	3/19

and Grease

*schedule water*

## Bayview Pump House

✓

### Main Floor

#### -Panel Boards

Initial	Date
VR	3/8

Check Blower  
Operation

#### -Exhaust Fans

Initial	Date
VR	3/12

Check Operation

#### -Alarms

Initial	Date
VR	3/12

Check Operation  
Check Tank Fill Valve & Operating Pressure

### Dry Well

#### -Check Daily Run Time

Initial	Date
VR	3/8

#### -Grease Drive Shafts

Initial	Date
VR	3/5

#### -Sump Pumps

Initial	Date
VR	3/5

Check Operation

#### -Valves

Initial	Date
VR	3/8

Exercise

#### -Solenoid Valves

Initial	Date
VR	3/5

Check Operation

#### -"Y" Strainers

Initial	Date
VR	3/5

Clean "Y" Strainers

M Pump Stations - 1 ✓

6/25/05 9:00



# Pump Stations Monthly PMs

March

2010

## Bayview Main Building ✓

### Roof

-Exhaust Fans

Check Operation

Initial	Date
VZ	3/19

### Hypo Room

-Hypo Pump

Check Oil Level,  
Check Operation

Initial	Date
VZ	3/15

-Piping, Tank & Valves

Check for Leaks

Initial	Date
VZ	3/15

-Exhaust Fan

Check Operation,  
Check "Y" Strainer on HypoTank

Initial	Date
VZ	3/15

### Basement

-Sump Pumps

Check Operation

Initial	Date
VZ	3/19

-Bluebird Pumps

Exercise

Initial	Date
VZ	3/15

### Wet Well

-Exhaust Fan

Check Operation

Initial	Date
VZ	3/19

-Well

Remove Grease

Initial	Date
VZ	3/12

Schedule vacation

## Grist Mill ✓

### Main Floor

-Exhaust Fans

Check Operation

Initial	Date
VZ	3/12

-Alarm Panel

Check Operation

Initial	Date

### Dry Well

-Check Valves

Exercise

Initial	Date
VZ	3/12

-Sump Pump

Check Operation

Initial	Date
VZ	3/12

-Exhaust Fan

Check Operation

Initial	Date
VZ	3/12

① Under belt fan does well fan #12 330

①

### Wet Well

-Exhaust Fan

Initial	Date
VZ	3/12

## Greenleaf Hill ✓

### Dry Well

-Alarm Panel

Check Operation

Initial	Date

-High Level

Tank Alarms  
Check Operation

Initial	Date

-Exhaust Fans

Check Operation

Initial	Date
VZ	3/12

-Sump Pump #1

Initial	Date
VZ	3/11
Reading	183.2

-Sump Pump #2

Initial	Date
VZ	3/11
Reading	3.6

-Start Cycles #1

Initial	Date
VZ	3/11
Reading	20445

-Start Cycles #2

Initial	Date
VZ	3/11
Reading	22719

-Electric Grinder

Reading

Initial	Date
VZ	3/11
Reading	17934.5

-"Y" Strainers

Clean "Y" Strainer#

Initial	Date
VZ	3/12

-Force Main Bypass

Check Valve

Check operation of  
valves and grease as necessary

Initial	Date
VZ	3/12

M Pump Stations - 2 ✓