



Pump Stations Monthly PMs

Month of: May 2010

Manhasset Valley ✓

Main Floor

-Exhaust Air Louver's

Initial	Date
✓	5/10

Check Operation

-Fresh Air Louver's

Initial	Date
✓	5/10

Check Operation

-Alarms

Initial	Date

Check Operation

Dry Well

-Sump Pumps

Initial	Date
✓	5/10

Check Operation

-Exhaust Fans

Initial	Date
✓	5/10

Check Operation

-"Y" Strainers

Initial	Date
✓	5/10

Clean "Y" Strainers

Wet Well

-Well

Initial	Date
✓	5/20

Remove Grease,
Exercise Splitter Valve

Schedule Vector

-Check Oil

Initial	Date
✓	5/10

Check Operation

-Bypass Channel

Initial	Date
✓	5/21

Flush Channel
Clean Bar Screen

-Exhaust Fans

Initial	Date
✓	5/21

Check Operation

Shelter Rock ✓

Main Floor

-CO2 Tank

Initial	Date
✓	5/10

Check Pressure,
Check for Leaks (950 psi)

-Exhaust Fans

Initial	Date
✓	5/10

Check Operation

-Alarm System

Initial	Date

Check Operation

Wet Well

-Remove Rags
and Grease

Initial	Date
✓	5/7

Bayview Pump House ✓

Main Floor

-Panel Boards

Initial	Date
✓	5/14

Check Blower
Operation

-Exhaust Fans

Initial	Date
✓	5/14

Check Operation

~~-Alarms~~

Initial	Date
✓	5/24

Check Operation
Check Tank Fill Valve & Operating Pressure

Dry Well

-Check Daily Run Time

Initial	Date
✓	5/14

-Valves
Exercise

-Grease Drive Shafts

Initial	Date
✓	5/14

-Solenoid Valves
Check Operation

-Sump Pumps

Initial	Date
✓	5/14

Check Operation

-"Y" Strainers

Initial	Date
✓	5/14

Clean "Y" Strainers



Pump Stations Monthly PMs

May

2010

Bayview Main Building

Roof

-Exhaust Fans

Check Operation

Initial	Date
V2	5/17

✓

Hypo Room

-Hypo Pump

Check Oil Level,
Check Operation

Initial	Date
V2	5/17

-Piping, Tank & Valves

Check for Leaks

Initial	Date
V2	5/17

-Exhaust Fan

Check Operation,
Check "Y" Strainer on HypoTank

Initial	Date
V2	5/17

Basement

-Sump Pumps

Check Operation

Initial	Date
V2	5/17

-Bluebird Pumps

Exercise

Initial	Date
V2	5/17

Wet Well

-Exhaust Fan

Check Operation

Initial	Date
V2	5/17

-Well

Remove Grease

Initial	Date
V2	5/17

Grist Mill

✓

Main Floor

-Exhaust Fans

Check Operation

Initial	Date
V2	5/24

-Alarm Panel

Check Operation

Initial	Date

Dry Well

-Check Valves

Exercise

Initial	Date
V2	5/24

-Sump Pump

Check Operation

Initial	Date
V2	5/24

-Exhaust Fan

Check Operation

Initial	Date
V2	5/24

Wet Well

-Exhaust Fan

Initial	Date
V2	5/24

Greenleaf Hill

✓

Dry Well

-Alarm Panel

Check Operation

Initial	Date

-High Level

Tank Alarms
Check Operation

Initial	Date

-Exhaust Fans

Check Operation

Initial	Date
V2	5/10

-Sump Pump #1

Initial	Date
V2	5/10
Reading	205.9

-Sump Pump #2

Initial	Date
V2	5/10
Reading	3.6

-Start Cycles #1

Initial	Date
V2	5/10
Reading	418

-Start Cycles #2

Initial	Date
V2	5/10
Reading	427

-Electric Grinder

Reading

Initial	Date
V2	5/10
Reading	18603.5

-"Y" Strainers

Clean "Y" Strainers

Initial	Date
V2	5/10

-Force Main Bypass

Check Valve

Check operation of
valves and grease as necessary

Initial	Date
V2	5/10