



# Pump Stations Monthly PMs ✓

Month of: September 2010

## Manhasset Valley ✓

### Main Floor

-Exhaust Air Louver's

Check Operation

Initial	Date
vr	9/10

-Fresh Air Louver's

Check Operation

Initial	Date
vr	9/10

-Alarms

Check Operation

Initial	Date

### Dry Well

-Sump Pumps

Check Operation

Initial	Date
vr	9/10

-Exhaust Fans

Check Operation

Initial	Date
vr	9/10

-"Y" Strainers

Clean "Y" Strainers

Initial	Date
vr	9/10

### Wet Well

-Well

Remove Grease,  
Exercise Splitter Valve

Initial	Date
vr	9/10

-Check Oil

Initial	Date
vr	9/10

-Bypass Channel

Flush Channel  
Clean Bar Screen

Initial	Date
vr	9/10

-Exhaust Fans

Check Operation

Initial	Date
vr	9/10

## Shelter Rock ✓

### Main Floor

-CO2 Tank

Check Pressure,  
Check for Leaks (950 psi)

Initial	Date
vr	9/20

-Exhaust Fans

Check Operation

Initial	Date
vr	9/20

-Alarm System

Check Operation

Initial	Date

### Wet Well

-Remove Rags  
and Grease

Initial	Date
vr	9/10

## Bayview Pump House ✓

### Main Floor

-Panel Boards

Check Blower  
Operation

Initial	Date
vr	9/20

-Exhaust Fans

Check Operation

Initial	Date
vr	9/20

-Alarms

Check Operation  
Check Tank Fill Valve & Operating Pressure

Initial	Date

### Dry Well

-Check Daily Run Time

Initial	Date
vr	9/7

-Grease Drive Shafts

Initial	Date
vr	9/17

-Sump Pumps

Check Operation

Initial	Date
vr	9/10

-Valves

Exercise

Initial	Date
vr	9/7

-Solenoid Valves

Check Operation

Initial	Date
vr	9/7

-"Y" Strainers

Clean "Y" Strainers

Initial	Date
vr	9/7



# Pump Stations Monthly PMs

September 2010

## Bayview Main Building ✓

### Roof

-Exhaust Fans

Check Operation

Initial	Date
vr	9/14

### Hypo Room

-Hypo Pump

Check Oil Level,  
Check Operation

Initial	Date
vr	9/14

-Piping, Tank & Valves

Check for Leaks

Initial	Date
vr	9/14

-Exhaust Fan

Check Operation,  
Check "Y" Strainer on HypoTank

Initial	Date
vr	9/14

### Basement

-Sump Pumps

Check Operation

Initial	Date
vr	9/14

-Bluebird Pumps

Exercise

Initial	Date
vr	9/14

### Wet Well

-Exhaust Fan

Check Operation

Initial	Date
vr	9/20

-Well

Remove Grease

Initial	Date
vr	9/17

## Grist Mill ✓

### Main Floor

-Exhaust Fans

Check Operation

Initial	Date
vr	9/17

-Alarm Panel

Check Operation

Initial	Date

### Dry Well

-Check Valves

Exercise

Initial	Date
vr	9/24

-Sump Pump

Check Operation

Initial	Date
vr	9/24

-Exhaust Fan

Check Operation

Initial	Date
vr	9/24

### Wet Well

-Exhaust Fan

Initial	Date
vr	9/24

## Greenleaf Hill ✓

### Dry Well

-Alarm Panel

Check Operation

Initial	Date
vr	9/7

-High Level

Tank Alarms

Check Operation

Initial	Date

-Exhaust Fans

Check Operation

Initial	Date
vr	9/7

-Sump Pump #1

Initial	Date
vr	9/7
Reading	223.5

-Sump Pump #2

Initial	Date
vr	9/7
Reading	3.6

-Start Cycles #1

Initial	Date
vr	9/7
Reading	803

-Start Cycles #2

Initial	Date
vr	9/7
Reading	569

-Electric Grinder

Reading

Initial	Date
vr	9/7
Reading	21493.4

-"Y" Strainers

Clean "Y" Strainers

Initial	Date
vr	9/7

-Force Main Bypass

Check Valve

Check operation of

valves and grease as necessary

Initial	Date
vr	9/2